

Advanced Designs for Net Zero Buildings

**Charles Eley, P.E., Fellow ASHRAE,
Fellow AIA, LEED® AP**

Copyright

Copyright © 2018, 2019, 2020 by ASHRAE. All rights reserved. No part of this presentation may be reproduced without written permission from ASHRAE, nor may any part of this presentation be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, photocopying, recording, or other) without written permission from ASHRAE.

ASHRAE has compiled this presentation with care, but ASHRAE has not investigated and ASHRAE expressly disclaims any duty to investigate any product, service, process, procedure, design or the like, that may be described herein. The appearance of any technical data or editorial material in this presentation does not constitute endorsement, warranty or guaranty by ASHRAE of any product, service, process, procedure, design, or the like. ASHRAE does not warrant that the information in this publication is free of errors. The user assumes the entire risk of the use of the use of any information in this presentation.



AIA/CES Registered Provider

ASHRAE is a Registered Provider with The American Institute of Architects Continuing Education Systems. Credit earned on completion of this program will be reported to CES Records for AIA members. Certificates of Attendance for non-AIA members are available on request.

This program is registered with the AIA/CES for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product. Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.



EDUCATION PARTNER

Advanced Designs for Net Zero Buildings

By ASHRAE

GBCI cannot guarantee that course sessions will be delivered to you as submitted to GBCI. However, any course found to be in violation of the standards of the program, or otherwise contrary to the mission of GBCI, shall be removed. Your course evaluations will help us uphold these standards.

Course ID: 920015146

Approved for:

3

General CE hours

0

LEED-specific hours

☐☐☐☐☐☐

Target Audience

Consulting engineers, Architects, Developers, Owners, Architectural and Engineering Students, Facility managers, Contractors)

This course is for professional engineers and architects who want to expand their practice to include the design, construction and operation of zero net energy buildings. The course will begin with a definition of a ZNE building.

- The first principle of ZNE design is to make the building as energy efficient as possible.
- On-site renewable energy systems will then be added to achieve ZNE.
- If adequate on-site ZNE is not feasible, then options for off-site renewable energy should be explored.
- The test for ZNE is at the energy meter, so proper commissioning and operator training is critical to success.

The ZNE principles outlined above will be presented with case studies and examples showing how other design professionals have met the ZNE goal.

Learning Objectives

At the conclusion of this course, attendees will :

- Understand what a zero-net energy building is.
- Analyze a building's energy components and how these can be reduced to a minimum.
- Show compliance to zero net energy at the design phase.
- Identify system operation that should be measured and verified after construction.
- Provide owner information on how to operate zero net energy buildings and their systems.

Agenda


Topic	Approximate Time
Introduction to Zero Net Energy (ZNE)	10 minutes
Source Energy and the California Grid	15 minutes
Time Dependent Source (TDS) Energy	10 minutes
HVAC and Thermal Comfort	15 minutes
Energy Modeling in the Design Process	10 minutes
Break	20 minutes
EUI Targets and Potential	10 minutes
Renewable Energy Systems	25 minutes
Making It All Work	10 minutes
Practical Examples	15 minutes
Closing Comments	5 minutes
Wrap-Up	10 minutes

Introduction to Zero Net Energy (ZNE)

United States Energy Flows – 2019




Estimated U.S. Energy Consumption in 2019: 100.2 Quads




Source: LLNL March, 2020. Data is based on DOE/EIA MER (2019). If this information or a reproduction of it is used, credit must be given to the Lawrence Livermore National Laboratory and the Department of Energy, under whose auspices the work was performed. Distributed electricity represents only retail electricity sales and does not include self-generation. EIA reports consumption of renewable resources (i.e., hydro, wind, geothermal and solar) for electricity in BTU-equivalent values by assuming a typical fossil fuel plant heat rate. The efficiency of electricity production is calculated as the total retail electricity delivered divided by the primary energy input into electricity generation. End use efficiency is estimated as 65% for the residential sector, 65% for the commercial sector, 21% for the transportation sector and 49% for the industrial sector, which was updated in 2017 to reflect DOE's analysis of manufacturing. Totals may not equal sum of components due to independent rounding. LLNL-MI-410527

Estimated U.S. Carbon Dioxide Emissions in 2018: ~5,268 Million Metric Tons



Source: LLNL July, 2019. Data is based on DOE/EIA MER (2018). If this information or a reproduction of it is used, credit must be given to the Lawrence Livermore National Laboratory and the Department of Energy, under whose auspices the work was performed. Carbon emissions are attributed to their physical source, and are not allocated to end use for electricity consumption in the residential, commercial, industrial and transportation sectors. Petroleum consumption in the electric power sector includes the non-renewable portion of municipal solid waste. Combustion of biologically derived fuels is assumed to have zero net carbon emissions - the lifecycle emissions associated with producing biofuels are included in commercial and industrial emissions. Totals may not equal sum of components due to independent rounding errors. LLNL-MI-410527

DOE Common Definition



Zero Net Energy
Net Zero Energy
Zero Energy

Living Buildings



Nearly Zero Energy
Zero Net Ready
Ultra-Low Energy

Zero Electric
Zero Carbon




ZNE Definition

- The sum of all **source** energy that is **delivered** to the property line must be less than the energy that is **exported** from the property.
- All energy use is included:
 - Electricity
 - Gas
 - District energy
- EV charging is considered exported energy if the vehicles are used off site.
- No on-site combustion is allowed for International Living Building Institute certified ZNE buildings.




Portfolios, Campuses, and Communities




**Contiguous boundary,
usually the same owner**






**Multiple owners,
noncontiguous
boundary**



**Single owner or
manager,
noncontiguous
boundary**

Dry Creek Elementary School District






Portfolio Example




Energy Accounting

British Thermal Unit (Btu)		kiloWatt-hour (kWh)		kiloJoule (kJ)
1 Btu	=	.000293 kWh	=	1.055 kJ
3,412 Btu	=	1 kWh	=	3,600 kJ
0.948 Btu	=	.000278 kWh	=	1 kJ



Energy Accounting



Energy Type	Source Multiplier	Common Energy Units	Site Btu/unit	Source Btu/unit
Imported Electricity	3.15	kWh	3412	10,751
Exported Renewable Electricity	3.15	kWh	3412	10,751
Natural Gas	1.09	Therms	100,000	109,000
Fuel Oil (1,2,4,5,6,Diesel, Kerosene)	1.19	Gallons	138,000	164,220
Propane & Liquid Propane	1.15	Gallons	91,000	104,650
Steam	1.45	lb	1000	1450
Hot Water	1.35	million Btu	1,000,000	1,350,000
Chilled Water	1.04	million Btu	1,000,000	1,040,000
Coal or Other	1.05	short ton	19,210,000	20,170,000

Revised values published
In Standard 189.1-2020

Notes: The Btu per lb of steam will vary depending on how much the steam is superheated.

Source: DOE Common Definition and ASHRAE Standard 105

Example calculation for mixed fuel building:

Source Energy (Btu) = kWh × 10,751 + Therms × 109,000

All Electric Buildings	
Site Energy	Equal difficulty in achieving ZNE
Source Energy (recommended)	
Energy Cost (flat rate)	

Table: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley, Island Press, 2016.










Source Energy and the California Grid

California BEES 1975–2005

- For three decades, California used flat source energy multipliers:
 - 3.0 for electricity
(1 kWh = 10,236 Btu)
 - 1.0 for gas
(1 therm = 100,000 Btu)
- Replaced by time-dependent valued (TDV) energy in 2005





	Megawatts
 Solar	11,439
 Wind	6,295
 Small hydro	1,238
 Geothermal	1,790
 Biofuels	997
 Storage battery	134*
TOTAL	21,893

Source: CalISO.com

Source Energy and the California Grid



Fuel Type	California In-State Generation (GWh)	Percent of California In-State Generation	Northwest Imports (GWh)	Southwest Imports (GWh)	California Energy Mix (GWh)	California Power Mix
Coal	302	0.15%	409	11,364	12,075	1.18%
Large Hydro	36,920	17.89%	4,531	1,536	42,987	14.72%
Natural Gas	89,564	43.40%	46	8,705	98,315	23.67%
Nuclear	17,925	8.69%	0	8,594	26,519	9.08%
Oil	33	0.02%	0	0	33	0.01%
Other	409	0.20%	0	0	409	0.14%
Renewables	61,183	29.65%	12,502	10,999	84,684	29.00%
Biomass	5,827	2.82%	1,015	32	6,874	2.35%
Geothermal	11,745	5.69%	23	937	12,705	4.35%
Small Hydro	6,413	3.11%	1,449	5	7,867	2.70%
Solar	24,331	11.79%	0	5,465	29,796	10.20%
Wind	12,867	6.24%	10,015	4,560	27,442	9.40%
Unspecified	N/A	N/A	22,385	4,632	27,017	9.25%
Total	206,336	100.00%	39,873	45,830	292,039	100.00%

Source: http://www.energy.ca.gov/almanac/electricity_data/total_system_power.html



Senate Bill 100
(recently signed by
Governor Brown)

33%
2020

50%
2026

60%
2030

100%
2045


Source Energy and the California Grid

Fossil Fuel Equivalency

Estimated U.S. Energy Consumption in 2017: 97.7 Quads



Fossil Fuel Generators




Source: LLNL April, 2018. Data is based on DOE/EIA MER (2017). If this information or a reproduction of it is used, credit must be given to the Lawrence Livermore National Laboratory and the Department of Energy, under whose auspices the work was performed. This chart was revised in 2017 to reflect changes made in mid-2016 to the Energy Information Administration's analysis methodology and reporting. The efficiency of electricity production is calculated as the total retail electricity delivered divided by the primary energy input into electricity generation. End use efficiency is estimated as 65% for the residential sector, 65% for the commercial sector, 21% for the transportation sector, and 49% for the industrial sector which was updated in 2017 to reflect DOE's analysis of manufacturing. Totals may not equal sum of components due to independent rounding. LLNL-MI-410527

Fossil Fuel Equivalency Approach

Primary Energy



Electricity Production

~ 10,000 Btu





1 kWh

~ 10,000 Btu



1 kWh

~ 10,000 Btu




1 kWh

- Source energy is unaffected as more clean generators are added to the grid.
- The source-site multiplier for wind, solar and other renewables is the same as fossil generators.

Primary Energy

Electricity Production

3,412 Btu




1 kWh

3,412 Btu



1 kWh

3,412 Btu




1 kWh

- Recommended by DOE.
- The source-site multiplier for wind, solar and other renewables is 1.0.

Primary Energy

ZERO Btu




1 kWh

ZERO Btu



1 kWh

ZERO Btu



1 kWh


Electricity Production

- Wind, solar and gravity are free.
- The source-site multiplier for wind, solar and other renewables is ZERO.
- Source energy and carbon emissions track each other exactly.

Source Energy and the California Grid




ASCC Alaska Grid	2.52
ASCC Miscellaneous (not a grid, delete)	1.21
WECC Southwest	2.75
WECC California	1.94
ERCOT All	2.58
FRCC All	2.97
HICC Miscellaneous	2.86
HICC Oahu	3.83
MRO East	3.08
MRO West	2.50
NPCC New England	2.87
WECC Northwest	1.39
NPCC NYC/Westchester	2.92
NPCC Long Island	2.90
NPCC Upstate NY	1.97
RFC East	3.05
RFC Michigan	3.06
RFC West	3.14
WECC Rockies	2.33
SPP North	2.67
SPP South	2.46
SERC Mississippi Valley	2.95
SERC Midwest	3.20
SERC South	3.04
SERC Tennessee Valley	3.02
SERC Virginia/Carolina	3.11
United States as a Whole	2.64




Source : Standard 189.1-2020

Assumes zero heat rate for non-combustible renewable energy.




Time Dependent Source (TDS) Energy

Time Dependent Source (TDS) Energy



Time Dependent Source (TDS) Energy




KQED

The bar chart illustrates the hourly volume of tweets for the #COVID19 hashtag over a seven-day period. The vertical axis (y-axis) measures the number of tweets, with a scale from 0.00 to 8.00 in increments of 1.00. The horizontal axis (x-axis) lists the days of the week: Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, and Sunday. Each day's data is represented by a series of blue bars, where the height of each bar corresponds to the number of tweets in that specific hour. The chart shows a consistent pattern of activity, with peaks typically occurring in the late morning and late afternoon/early evening, and a significant decline in activity during the nighttime hours. The highest peak is observed on Sunday, reaching approximately 7.2 tweets per hour.


SUNSHINE STATE


A photograph of three young women wearing 3D glasses, smiling and looking upwards, likely at a movie screen. The woman on the left is wearing a blue lanyard. The woman in the middle is pointing her finger. The woman on the right is wearing a plaid shirt. The background is dark and out of focus.

Time-Dependent Source Energy (kBtu/kWh)



Hourly Carbon Emissions (tons/kWh)






Time Dependent Source (TDS) Energy




Building
Electricity
Load



Building Envelope

Building Envelope



SHEARING LAYERS OF CHANGE. Because of the different rates of change of its components, a building is always tearing itself apart.



Building Envelope



Building Envelope



**BORA Architects
ARUP**





Image: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley, Island Press, 2016.



Two Tabor Center—Denver CO



- The new 30- to 33-story Two Tabor Center has been designed with a focus on providing tenants a productive and healthy work environment that is employee-centric and provides easy access to the many amenities of Tabor Center and the 16th Street Mall.
- Two Tabor Center will add approximately 637,000 to 692,000 rentable square feet of class AA office space to Tabor Center, creating one of the largest office complexes in Denver with over 1,217,000 rentable square feet of office space. Retail space occupies the ground level of Two Tabor Center along 17 St. and Larimer Street. Entrances to a 1700-space underground parking garage.

Glazing Comparison


Name	Cavity	U factor	SC	SHGC	Tvis
VNE 1-53	Air (10%)/ Argon (90%)	0.201	0.256	0.223	0.587
VNE 1-53	Air (100%)	0.289	0.264	0.23	0.487
VNE 1-63	Air (10%)/ Argon (90%)	0.209	0.327	0.284	0.619
VP 1-13	Air (10%)/ Argon (90%)	0.404	0.228	0.198	0.128
VRE 1-38	Air (10%)/ Argon (90%)	0.213	0.26	0.226	0.361
VUE 1-30	Air (10%)/ Argon (90%)	0.204	0.195	0.169	0.307
90.1		0.420	0.450	0.400	

Comparison of glass types

	Cavity	floor area	Solar Radiation (Btu/h)	Transmission (Btu/h)	total	Envelope load per SF floor area (Btuh/sf)
VUE1-30 (40%)	Air(10%)/Argon (90%)	765,272	1,133,853	629,567	1,763,420	2.30
VNE4-53 (40%)	Air(10%)/Argon (90%)	765,272	1,496,149	623,118	2,119,268	2.77
VRE1-38 (40%)	Air(10%)/Argon (90%)	765,272	1,516,277	648,914	2,165,191	2.83
VP1-13 (40%)	Air(10%)/Argon (90%)	765,272	1,328,420	1,059,492	2,387,911	3.12
VNE1-63 (40%)	Air(10%)/Argon (90%)	765,272	1,905,410	640,315	2,545,725	3.33
VUE1-30 (65%)	Air(10%)/Argon (90%)	765,272	1,842,511	824,042	2,666,553	3.48
VNE1-53 (65%)	Air(10%)/Argon (90%)	765,272	2,431,243	788,959	3,220,201	4.21
VNE4-53 (65%)	Air(10%)/Argon (90%)	765,272	2,431,243	813,563	3,244,805	4.24
VRE1-38 (65%)	Air(10%)/Argon (90%)	765,272	2,463,950	855,480	3,319,430	4.34
VP1-13 (65%)	Air(10%)/Argon (90%)	765,272	2,158,682	1,522,669	3,681,351	4.81
ASHRAE 90.1 (40%)	Air(10%)/Argon (90%)	765,272	2,683,676	1,093,886	3,777,561	4.94
VNE1-63 (65%)	Air(10%)/Argon (90%)	765,272	3,096,291	841,508	3,937,799	5.15
ASHRAE 90.1 (65%)		765,272	4,360,973	1,578,560	5,939,533	7.76
VNE1-53 Air (65%)	Air (100%)	765,272	2,507,560	995,206	3,502,765	4.58




Constant Temperature 60% glass




Variable Temperature 60% glass Net Zero

Both lighting and plug loads are lower



Using Photovoltaics to Take Tabor II to Net Zero



Metric	Value
Annual energy (year 1)	4,369,936 kWh
Capacity factor (year 1)	19.2%
Energy yield (year 1)	1,680 kWh/kW
Performance ratio (year 1)	0.81
Levelized COE (nominal)	6.05 ¢/kWh
Levelized COE (real)	4.83 ¢/kWh
Electricity bill without system (year 1)	\$519,583
Electricity bill with system (year 1)	\$167,846
Net savings with system (year 1)	\$351,738
Net present value	\$525,719
Simple payback period	11.9 years
Discounted payback period	NaN
Net capital cost	\$4,732,172
Equity	\$1,892,869
Debt	\$2,839,303

Advanced Building Envelope Concepts

RNL Architects
Stantec






Image: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley Island Press, 2016.









Lighting and Daylighting


Power over Ethernet (PoE)
allows individual LED lighting
fixtures to be directly addressed
and controlled.



Source: Maxim Integrated; published in LEDs Magazine, September 2015.




Lighting and Daylighting



Dynamic Daylighting Metrics

Spatial Daylight Autonomy (sDA)

Figure 1. Spatial Daylight Autonomy (sDA) Evaluation



- The percent of the space where daylight illumination is above 300 lux for 50% or more of the time during standard operating hours.
- These pass/fail examples are for attempting to achieve an sDA of 55%.
- See IES LM-83 for more details.

Annual Sunlight Exposure (ASE)

Figure 2a. Classroom with Exterior Overhang and Light Shelf





Figure 2b. Classroom without Exterior Overhang or Light Shelf




sDA_{300 lux, 50%}

51%–100%
0–50%

ASE_{1,000 lux}

250+ hours
0–250 hours

- Represents the percent of the space when illumination exceeds 1000 lux for more than 250 hours per year.
- Recommended criteria for regularly occupied spaces is from 15% to 25%.
- ASE is a proxy for glare and overheating
- See IES LM-83 for more details.



IES LM-83 Recommendations

	Minimum sDA _{300,50%}	Maximum ASE _{1000,250}
Classrooms	75%	15%
Gymnasiums/Multipurpose Rooms	55%	25%
Library Reading Area	55%	25%
Administrative Offices	55%	15%

<https://patternguide.advancedbuildings.net>

Daylighting Pattern Guide

[Home](#)

[Patterns](#)

[Using this Guide](#)

[About](#)

[DPG+E Development](#)



Pattern 2: Window Area (Window Spacing) 50% Glazing Area

5 of 5

Slideshow




Vertical windows comprising 50 percent of the wall area provide daylight illumination that meets or exceeds commonly accepted minimum daylight illumination criteria at approximately 80 percent of the adjacent 26'-0" section. Some contrast remains between the interior surfaces and the glazing, though the "back" wall (at left) shows a substantial increase in surface brightness to balance the luminosity across the section. Note that at this window to wall ratio, the vertical windows are geometrically equivalent to the horizontal band when bounded by a 2'-6" sill and a 9'-6" head height.




80%
of floor area is
above 300 lux

LUX



HVAC and Thermal Comfort




A comparisons of systems for New York and Los Angeles Locations



Annual Electric Energy by End Use										
		Annual Source Energy		Annual Site Energy		Lighting	HVAC Energy		Peak	
Los Angeles		total	EUI	Electric	Nat Gas	Electric	Electric	Nat Gas	total	Electric Cooling
Annual Energy Use (kWh)		MBtu	kBtu/sf/yr	kWh	Therms	kWh	kWh	Therms	MBtu	kW tons
0	Base Design - VAV	29,779	165	2,679,658	23,422	599,160	796,725	124	2732	938 391
1	0+Fan Coils	31,813	177	2,879,748	23,276	599,160	996,816	7	3403	948 389
2	0+Radiant Ceiling	26,668	148	2,376,977	23,301	599,160	494,044	35	1690	795 330
3	0+Active Beams	26,824	149	2,392,191	23,309	599,160	509,257	37	1742	818 346
New York										
0	Base Design - VAV	29,992	167	2,594,809	34,236	599,160	711,876	8412	3271	1025 456
1	0+Fan Coils	31,795	177	2,814,940	29,727	599,160	932,006	3924	3573	1031 513
2	0+Radiant Ceiling	27,349	152	2,336,119	34,295	599,160	453,185	8482	2395	862 426
3	0+Active Beams	27,564	153	2,356,092	34,400	599,160	473,158	8585	2473	873 461

What is Thermal Comfort

- Space dry-bulb temperature
 - Space humidity content
 - Space air movement
 - Space mean radiant temperature (MRT)
 - Occupants are seated
 - Clothing may vary
-
- Percent persons dissatisfied (PPD)
 - Predicted mean vote (PMV)



Natural Ventilation Points

- Natural ventilation can be used under certain conditions
- Natural ventilation air movement is dependent upon buoyancy, wind, or buoyancy and wind driven air outside air.
- There are presently no limitations on space humidity when utilizing natural ventilation; however, space humidity limits must be taken into account.
- The occurrence of natural ventilation is not predictable.
- If the openings are manual, then natural ventilation could be operated outside of recommended conditions.
- In a mixed-mode system there is a chance of surface condensation when switching from conditioning the space to naturally ventilating the space.

Energy Modeling in the Design Process


Methods of Assessing ZNE

Operational Assessment


- Based on utility bills
- Actual building operation
- Based on actual weather

Asset Assessment

- Based on energy model
- Standard modeling assumptions
- Standard weather file



Proposed Design Energy Model



Baseline Building Energy Model



Both models use the same:

- Energy simulation software
- Temperature set points
- Hours of operation
- Plug loads
- Occupants
- etc.

Energy (Source)


Same form and configuration but upgraded or downgraded to meet roughly Standard 90.1-2004

≤

ZERO

- Insulation U-factors
- Fenestration area, SHGC, and U-factor
- Lighting power and controls
- Standard HVAC system and equipment efficiencies

PCI = Performance Cost Index




Accurately estimating building operation and weather is critically important when the target is ZNE.


Goldstein, David, and Charles Eley. A Classification of Building Energy Performance Indices, *Energy Efficiency*, Volume 7, Issue 1, February 2014. See Eley.com.

Break

EUI Targets and Potential

Typical EUIs for Offices





	Pacific Coast	Warm and Dry	Hot and Humid	Warm and Humid	Cold and Dry	Cold and Humid	Arctic
CZ->	(3c, 4c)	(2b, 3b, 4b)	(1a, 2a)	(3a, 4a)	(5b, 6b)	(5a, 6a, 7)	(8)
Warehouses	34	20	23	40	53	65	161
Offices	58	62	69	69	69	77	126
Retail	101	86	99	114	122	142	249
Schools	70	59	71	78	77	91	165
Apartments	62	42	52	69	73	86	153
Hotels	122	99	119	126	126	134	151
Healthcare	232	202	232	242	218	238	281
Restaurants	558	497	522	569	598	660	965

Source: EnergyPlus simulations of prototype buildings modified to match characteristics of pre-2000 buildings, NREL.

From: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley, Island Press, 2016.

	Pacific Coast	Warm and Dry	Hot and Humid	Warm and Humid	Cold and Dry	Cold and Humid	Artic
	(3c, 4c)	(2b, 3b, 4b)	(1a, 2a)	(3a, 4a)	(5b, 6b)	(5a, 6a, 7)	(8)
Warehouses	16	15	12	17	20	26	33
Offices	22	31	33	32	31	34	41
Retail	35	46	49	47	48	50	68
Schools	35	48	48	51	53	61	76
Office w/ Data Center	62	69	71	70	72	77	88
Hotels	57	75	80	78	77	83	100
Healthcare	101	108	117	116	111	120	140
Restaurants	360	431	414	471	513	574	759

Source: EnergyPlus simulations of prototype buildings in minimum compliance with Standard 90.1-2013, PNNL.

Source: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley, Island Press, 2016.

	Pacific Coast	Warm and Dry	Hot and Humid	Warm and Humid	Cold and Dry	Cold and Humid	Artic
	(3c, 4c)	(2b, 3b, 4b)	(1a, 2a)	(3a, 4a)	(5b, 6b)	(5a, 6a, 7)	(8)
Warehouses	6	6	5	6	7	8	7
Offices	8	10	11	11	11	11	12
Retail	13	18	18	17	18	19	27
Schools	16	21	23	22	21	23	26
Apartments	24	30	29	31	32	34	35
Offices/Data Center	43	47	47	44	47	46	47
Hotels	40	49	49	51	51	54	58
Healthcare	33	34	33	37	33	33	72
Restaurants	265	323	324	336	343	353	377


Study did not look at comprehensive measures to reduce cooking and refrigeration energy.

Source: ASHRAE Research Project 1651-RP, Glazer.

From: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley, Island Press, 2016.


EUI Examples





Taking Will County Courthouse to Net Zero

Monthly Energy and Load




Metric	Value
Annual energy (year 1)	1,661,297 kWh
Capacity factor (year 1)	15.8%
Energy yield (year 1)	1,386 kWh/kW
Performance ratio (year 1)	0.83
Levelized COE (nominal)	7.34 ¢/kWh
Levelized COE (real)	5.86 ¢/kWh
Electricity bill without system (year 1)	\$202,787
Electricity bill with system (year 1)	\$68,061
Net savings with system (year 1)	\$134,726
Net present value	\$4,616
Simple payback period	15.5 years
Discounted payback period	NaN
Net capital cost	\$2,179,913
Equity	\$871,965
Debt	\$1,307,948






	Description	Energy Breakdown per Conditioned Floor Area, kBtu/sq.ft.-yr									
		Space Heating	Space Cooling	Interior Lighting	Receptacle	Fans	Heat Rejection	Pumps	Domestic Hot Water	Total	% better
Baseline	2008 Title-24 Standard System Type 4, Overhead VAV w / Reheat	5.02	6.32	9.95	10.09	3.53	4.09	2.18	5.77	46.95	N/A
Proposed	Overhead VAV w / Reheat, Thermal Storage	4.84	3.58	6.45	10.09	3.02	2.58	0.90	5.77	37.23	20.7%

Energy Breakdown n per Conditioned Floor Area, kBtu/sq.ft.- yr



Taking San Bernardino Courthouse to Net Zero



Metric	Value
Annual energy (year 1)	4,369,936 kWh
Capacity factor (year 1)	19.2%
Energy yield (year 1)	1,680 kWh/kW
Performance ratio (year 1)	0.81
Levelized COE (nominal)	6.05 ¢/kWh
Levelized COE (real)	4.83 ¢/kWh
Electricity bill without system (year 1)	\$519,583
Electricity bill with system (year 1)	\$167,846
Net savings with system (year 1)	\$351,738
Net present value	\$525,719
Simple payback period	11.9 years
Discounted payback period	NaN
Net capital cost	\$4,732,172
Equity	\$1,892,869
Debt	\$2,839,303

Renewable Energy Systems



Primary source of on-site renewable energy for ZNE buildings




Zero Net Energy Center, Oakland



- **Limited on-site potential for ZNE buildings**
- **More potential is at the utility scale**

Modern Wind Turbines





Simon Pierce, Quechee, Vermont




↓
Limited or no
on-site renewable
energy potential

Source Heat Pump
Cooling Mode

Available energy

Geothermal Resource of the United States
Locations of Identified Hydrothermal Sites and
Favorability of Deep Enhanced Geothermal Systems (EGS)



Regenerative but not renewable in the same sense as wind and solar.

SCIENTIFIC
AMERICAN




Congress Says Biomass Is Carbon-Neutral, but Scientists Disagree

Using wood as fuel source could actually increase CO₂ emissions


By Chelsea Harvey, Niina Heikkinen, E&E News on March 23, 2018





Monocrystalline


30%




Polycrystalline

60%

**Costs are less than
\$4/W before tax
credits or incentives**



Best Research-Cell Efficiencies



SYSTEM INFO

Modify the inputs below to run the simulation.

DC System Size (kW):

Module Type:

Array Type:

System Losses (%):

Tilt (deg):

Azimuth (deg):

+ Advanced Parameters

Calculate System Losses Breakdown

Modify the parameters below to change the overall System Losses percentage for your system.

Soiling (%): [i](#)

Shading (%): [i](#)

Snow (%): [i](#)

Mismatch (%): [i](#)

Wiring (%): [i](#)

Connections (%): [i](#)

Light-Induced Degradation (%): [i](#)

Nameplate Rating (%): [i](#)

Age (%): [i](#)

Availability (%): [i](#)

Estimated System Losses:

14.08%

Shading

Reduction in the incident solar radiation from shadows caused by objects near the array such as buildings or trees, or by self-shading for fixed arrays or arrays with two-axis tracking. PVWatts® calculates self-shading losses for one-axis trackers, so you should not use the shading loss to account for self-shading with the one-axis trac...

[Click for more information](#)

Article on carbon neutral x 31 Google Calendar - Week x solar panel efficiency site x System Advisor Model (S x

Secure | <https://sam.nrel.gov>

Apps ★ Bookmarks Outlook Web App WebAccess Teaming Site off-line | Charles Enlighten CHPS Sustainability Diction About AIA IgCC COMNET Standing C Pandora Radio - Liste UTC Gateway

NREL System Advisor Model (SAM)
NATIONAL RENEWABLE ENERGY LABORATORY

Login Register

HOME DOWNLOAD SDK SUPPORT RESOURCES CONTACT ACCOUNT ABOUT


Welcome to SAM

published by admin on Mon, 2010-04-05 16:58

The System Advisor Model (SAM) is a performance and financial model designed to facilitate decision making for people involved in the renewable energy industry:

- Project managers and engineers
- Policy analysts
- Technology developers
- Researchers

Download a published description of SAM 2014.1.14 (PDF 1.6 MB)



Metric	Value
Annual energy	37,213,862 kWh
Capacity factor	25.2%
First year kWh/kWDC	3,861 kWh/kW
Performance ratio	0.82
PPA price (Year 1)	19.28 c/kWh
PPA price escalation	1.00 %
Levelized PPA price (nominal)	11.20 c/kWh
Levelized cost (nominal)	10.48 c/kWh
Net present value	\$2,728,050
Internal rate of return (IRR)	11.00 %
Year IRR is achieved	20 year
IRR at end of analysis period	12.26 %
Initial cost	\$41,172,380
Initial cost less cash incentives	\$41,172,380
Equity	\$23,476,956
Debt	\$23,706,422
Debt fraction	52.71 %

SAM's results summary table and graphs.

<https://sam.nrel.gov/about>

NREL efficiency-c...png 040318_ZERO Co...pptx WG07DA89_rene...docx WG07DA89_rene...docx GoToMeeting Ope...exe

Show all

SAM includes performance models for the following technologies

- Photovoltaic systems (flat-plate and concentrating)
- Battery storage model for photovoltaic systems
- Parabolic trough concentrating solar power
- Power tower concentrating solar power (molten salt and direct steam)
- Linear Fresnel concentrating solar power
- Dish-Stirling concentrating solar power
- Process heat parabolic trough and linear direct steam
- A simple "generic model" for conventional thermal
- Solar water heating for residential or commercial buildings
- Wind power (large and small)
- Geothermal power and geothermal co-production
- ~~Biomass power~~

<i>Climate</i>	<i>Orientation</i>	<i>0° Tilt</i>	<i>10° Tilt</i>	<i>20° Tilt</i>	<i>30° Tilt</i>	<i>40° Tilt</i>	<i>50° Tilt</i>	<i>60° Tilt</i>
Warm and Dry (Los Angeles)	East	1,414	1,385	1,336	1,269	1,191	1,105	1,013
	Southeast	1,414	1,470	1,493	1,486	1,450	1,383	1,292
	South	1,414	1,518	1,581	1,605	1,594	1,540	1,451
	Southwest	1,414	1,433	1,545	1,560	1,537	1,483	1,399
	West	1,414	1,425	1,409	1,368	1,310	1,236	1,149
Pacific Coast (San Francisco)	East	1,378	1,353	1,304	1,244	1,172	1,092	1,010
	Southeast	1,378	1,437	1,467	1,466	1,434	1,373	1,289
	South	1,378	1,485	1,553	1,582	1,571	1,523	1,436
	Southwest	1,378	1,464	1,518	1,534	1,518	1,466	1,389
	West	1,378	1,389	1,372	1,336	1,282	1,213	1,132

Source: PV Watt Calculations.


Source: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley, Island Press, 2016.

	Pacific Coast	Warm and Dry	Hot and Humid	Warm and Humid	Cold and Dry	Cold and Humid	Artic
	(3c, 4c)	(2b, 3b, 4b)	(1a, 2a)	(3a, 4a)	(5b, 6b)	(5a, 6a, 7)	(8)
Horizontal Production (kWh/y)/kW (stc)	1,378	1,414	1,359	1,316	1,311	1,138	748
Horizontal Production (kBtu/y)/kW (stc)	4,702	4,825	4,637	4,490	4,473	3,883	2,552
kBtu/ft ² -y of Collector Area	72	74	71	69	69	60	39



Maximum site EUI to achieve ZNE for a one-story building with the roof covered with PVs.

Source: Design Professionals Guide to Zero Net Energy Buildings, Charles Eley, Island Press, 2016.

Challenging Building Types and Climates



1.00



	<i>Pacific Coast</i>	<i>Warm and Dry</i>	<i>Hot and Humid</i>	<i>Warm and Humid</i>	<i>Cold and Dry</i>	<i>Cold and Humid</i>	<i>Arctic</i>
Warehouses	0.08	0.08	0.07	0.09	0.10	0.13	0.19
Offices	0.11	0.14	0.15	0.15	0.15	0.18	0.30
Retail	0.18	0.24	0.25	0.25	0.26	0.32	0.67
Schools	0.22	0.28	0.32	0.32	0.31	0.38	0.66
Apartments	0.33	0.40	0.41	0.44	0.47	0.57	0.90
Off/Data Center	0.59	0.63	0.66	0.64	0.68	0.77	1.19
Hotels	0.55	0.66	0.69	0.74	0.75	0.90	1.48
Healthcare	0.87	0.86	0.96	0.96	0.95	1.10	1.83
Restaurants	3.66	4.35	4.53	4.87	4.99	5.91	9.01


ZNE feasible for four stories or more

ZNE feasible for two-story buildings

ZNE feasible for one-story buildings

PV on roof not enough

Source: Design Professionals Guide to Zero Net Energy Buildings,
Charles Eley, Island Press, 2016.




PV Examples

Water and Life Museum, Hemet

- 50,000 ft² PV panels
- Daily production 2550 kWh (based on 5.5 hour/day FTE)
- Power consumed by building in 12 hours (3729 kWh)
- 68% solar power contribution








Meter Configurations and Off-Site

PV system is located behind the meter, a common arrangement for small and medium-sized buildings


Customer pays for the net energy that is used (e.g. delivered electricity minus exported electricity)

Meter can “run backwards”



Content From ZERO Code

Renewable energy system is on a separate meter and the owner is compensated through a feed-in tariff
Common arrangement for direct PPAs




Content From ZERO Code

Renewable energy system is on a separate meter and the owner is compensated through a feed-in tariff

Common arrangement for direct PPAs

A certain amount of energy (and RECs) are allocated to one or more buildings on the campus




Content From ZERO Code

Renewable energy system is moved off-site and supplies the grid.

Renewable energy credits can be used to track production and assign it to the building.

Economies of scale can be achieved with larger renewable energy systems.



Off-Site Renewable Energy Procurement Options

Class One

- Self Owned
- Community Solar
- Virtual PPA
- Renewable Energy Investment Trust

- ☐ High probability of additionality
- ☐ Long-term commitment

Class Two

- Direct Access to Wholesale Market
- Green Tariffs

- ☐ Medium probability of additionality
- ☐ Customers can easily opt out

Class Three

- Unbundled RECs

- ☐ Little chance of additionality
- ☐ Least desirable option

See zero-code.org for more details.



Meter Configurations and Off-Site



Palo Alto Campus



All Electric Central Plant



73 MW Solar System in California Desert



Not the actual site



DECEMBER 3, 2018

Stanford to go 100 percent solar by 2021

A second solar-generating plant, to be built in the next three years, will complete the university's transition to clean power and further shrink campus greenhouse gas emissions.



BY CHRIS PEACOCK

Stanford's solar future is growing even brighter.


A new solar generating plant – Stanford's second – announced today, will enable the university to use 100 percent renewable electricity in three years, more than two decades ahead of California's goal of a carbon-free grid by 2045.

Completing the university's transition to clean power, Stanford finalized an agreement to collaborate with Recurrent Energy on an 88-megawatt solar photovoltaic plant to be constructed in central California, near Lemoore. The plant is scheduled to go online






On-campus rooftop solar power and two solar generating stations together will produce enough clean renewable electricity each year to equal the university's annual electricity consumption. (Image credit: M. Scott Gould)


Stanford's Path to Reduced Emissions




Making It All Work










<http://greentechadvocates.com/2013/05/07/plug-loads-a-growing-concern/>





Annual Reports




KPI Reports



Energy Centre Reports



Building Performance Reports




Profile Reports



Comparison Reports



Multiple Meter Reports



Carbon Emissions Reports

Practical Examples








SUSTAINABLE STRATEGIES

Passive Strategies


- 1 Thermal mass: CMU walls, insulated on the outside, exposed on the inside
- 2 Thermal mass: concrete floor, for night ventilation cooling
- 3 Heavily insulated roof, partially shaded by solar panels
- 4 Sunshading
- 5 Trees for shade
- 6 Natural cross-ventilation
- 7 Balanced, fully-daylit interior
- 8 Certified sustainably-harvested framing lumber
- 9 Exterior circulation between rooms: less building and conditioned space
- 10 Flyash in concrete and grout

Active Strategies

- 11 Power off the grid: solar panels for all electricity, HVAC and domestic hot water
- 12 Wastewater treated on site for irrigation and recycling as flushing water
- 13 Stormwater retained on site to recharge groundwater
- 14 Ceiling fans
- 15 Water mister to cool and humidify air before entering building
- 16 High-efficiency water fountains to cool and humidify air








OFF-GRID COMMUNITY

The carbon footprint of the community will be identified, this represents the base case for our study. This number will be lowered through two methods, the production of onsite renewable energy and energy conservation measures to make renewable energy feasible.

Where we are now, in 2007


If our site were to be developed today, in 2007, it would generate **74 million pounds** of Carbon through usage and conditioning.

In addition, 86,000 pounds of Carbon will be generated from automobiles.



So we can produce our own on-site renewable energy:

- Solar Power
- Wind Power
- Cogeneration (Biomass)



BUT we can reduce energy consumption by:

- Using Natural Ventilation and Radiant Floors to reduce consumption in our homes
- Using Active Beams to reduce consumption in our offices
- Employing Ultra-efficient Building Systems

Energy Conservation Measure	Energy Footprint (kWh)	Carbon Footprint (lbs CO ₂)
Carbon Reduction by Production		
Solar Power	18,231,002	-14,422,493
Wind Turbines	18,231,002	-2,180,014
Cogeneration	24,038,449	-26,884,053
Carbon Reduction by Conservation		
Natural Ventilation	31,268,180	-24,336,250
Active Beams	15,381,549	-2,675,063
Absorption Chiller from Cogeneration	18,234,383	-1,362,527
Net Consumption	0 kWh	0 lbs

The carbon footprint of the community was reduced through a two stage process: renewable production and energy conservation. While both methods reduce our carbon footprint significantly, neither one alone is enough to completely offset the overall carbon production.

Through the use of renewable energy production methods, we can consume energy whose generation produced very little carbon. Solar panels and wind turbines harness the power of nature to produce electricity, converting sunlight and wind energy respectively. Cogeneration burns methane to produce heat and electricity, and is the primary source of onsite energy.

Energy conservation is used to bring consumption levels down to a point where renewable energy can meet the demand. Natural ventilation is used in the residences, while an active beam system is used in the offices. Natural ventilation does not involve any mechanical systems, and thus consumes no electricity. Active beams provide efficient cooling to the space. An absorption chiller, using heat from the cogeneration facility, further reduces consumption by reclaiming energy that would usually be wasted.



site plan

Location	San Francisco, CA
Latitude	37° 46' 30"
Longitude	122° 29' 30"
Nearest Interstate Highway	101
Nearest Airport	San Francisco International
Nearest Harbor	San Francisco Bay
Nearest Major Road	101

Land Utilization

Our land use was mostly devoted towards medium density residence zones that allow for an efficient use of the land while giving us critical mass for the public transportation system.

The high density offices were placed in the south, close to the railway station and the commercial zones.

Wind turbines were placed on the West side of the site, in the direction of the prevailing wind.



Rain Water Collection

In order to reduce potable water usage from the mains a system for rainwater harvesting can be implemented. The harvested rainwater is collected from the roof and stored for future use as gray water usage; i.e. landscape irrigation and

Due to the high rainfall experienced in San Francisco, it is possible to reclaim enough water for site landscaping. Flora for landscaping will be selected to suit the local environment, with special attention to plants that do not require excessive watering during the summer months, when rainwater is scarce. plumbing.

Average Precipitation in San Francisco											
Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
6.0 in	5.2 in	5.1 in	4.0 in	3.2 in	2.1 in	1.0 in	0.5 in	0.2 in	0.1 in	0.1 in	0.2 in

Transportation


There will be no cars on site. There is sufficient public transportation to commute comfortably. Normally, for this type of space there would be approximately 6000 cars. By making this a car-free site we are saving more than **86,000 lbs** of carbon from being emitted each year.

We will have a lend-a-bike system (check in/check out bicycles go from A to B). Similar to Lyon, France's Vélo-V idea. Extract a bike with a prepaid card (in Lyon it is 5 Euros a year to sign up (\$6 USD) + 0.5 Euros per 1.5 hours).



Off-Grid Competition

OGIC 07-12





34.0 MWh
cogeneration

18.2 MWh
solar panels

optimized **heating & cooling**
-7.9 MWh


wind turbines
3.0 MWh




- Heating and Cooling in Residences and Other Spaces:
The residential units will be naturally ventilated without an artificial cooling system. We will implement strategies to provide crosswind ventilation and stacking effect ventilation. Vertical operable windows, for as large an operable area, on the west side (the side with the summer breeze) and at low level are ideal. The exhaust air would come out of a window on the east side at high level. A radiant floor system will be used to provide heating for the space when temperatures drop.
- Heating and Cooling for Offices:
Active beams represent the most efficient method of cooling available today. Cooling is provided by a combination of cool air and chilled water. Warm air near the beam is induced into the active beam and over a series of chilled water coils which cool the warm air. This cooled air is mixed with the supply air before being returned to the space. By supplying minimal air to the space, we reduce the size of ductwork and fan power required significantly.


Materials

- Bamboo generates 35% more oxygen than similar sized trees and is harvested after only 3-5 years of growth.(floors)
- PET Carpet (polyethylene terephthalate) is plastic used in pop bottles and can be recycled into durable carpeting with low VOC's and better indoor air quality than regular carpet. It also takes less energy to manufacture and has a lower impact dye process.
- Walls: Bonded Logic Ultra touch denim insulation. Made of recycled jeans, this fire retardant insulation has a high R value (R-30) and no chemical dangers (no VOC's). Combining this with other insulations, an envelope of R-45 can be achieved.
- Low E Argon-filled Windows.




- The concept of wind power is to harness wind energy and convert it to a usable source of energy i.e. electricity. By using aerodynamic principles to cause a mechanical rotation it is possible to create a direct electrical current, which can be distributed, stored, and/or sold.
- The turbines rotates about a vertical axis supported at the base. The turbines are easily located, aesthetically pleasing with the possibility of creative advertising, not harmful to wildlife, self-starting, operate at low windspeeds, and independent of the wind direction. These advantages combined with the sustainable concept of "free wind" make these turbines ideal for use in an urban environment.
- Approximately 600 turbines can be placed on the west side of the site.






**Packard Foundation
Stevens Library
IDeAS Office
Watsonville Water Resources
U.C. Merced**



**DPR Office (SF)
IBEW-NECA JATC Training
435 Indio Way
West Berkeley Library
SF Exploratorium**



**J. Craig Venter Institute Lab
La Escuelita Education Center
California DMV Field Office
Butte College
LACCD Harbor College Science
Stanford University**

https://www.pge.com/pge_global/common/pdfs/save-energy-money/savings-programs/zero-net-energy-program/ZNE-Case-Study-Buildings-Vol1.pdf
https://www.pge.com/pge_global/common/pdfs/save-energy-money/savings-programs/zero-net-energy-program/ZNE-Case-Study-Buildings-Vol2.pdf
https://www.pge.com/pge_global/common/pdfs/save-energy-money/savings-programs/zero-net-energy-program/ZNE-Case-Study-Buildings-Vol3.pdf

CASE STUDY NO. 12

The J. Craig Venter Institute Laboratory





PHOTO: NICK MERRICK, HALL MERRICK PHOTOGRAPHERS


Practical Examples



PHOTO: NICK MERRICK, HALL MERRICK PHOTOGRAPHERS

13







Images Courtesy Integral Group.




Images Courtesy Integral Group.



© David Wakely


A PV-equipped canopy mounted on the south façade generates electricity for the

ENERGY USE AND PV PRODUCTION (2009)




© David Wakely

Source: Kaneda, D., P. Rumsey, and S. Shell. 2010. Less than Zero. *High Performing Building*.
<http://www.hpbmagazine.org/attachments/article/12143/10F-IDeAs-Z2-Design-Facility-San-Jose-CA.pdf>.
 Photographs © David Wakely. Graphic © EHDD Architecture.



- 1 Private office
- 2 Open office
- 3 Sunshade with building-integrated photovoltaics
- 4 Roof with building-integrated photovoltaics
- 5 Skylight
- 6 Energy-efficient and occupancy sensor controlled light fixtures
- 7 Electrochromic glass
- 8 Radiant heat floor
- 9 Natural ventilation
- 10 High performance glass
- 11 Reduction of outdoor light pollution
- 12 Water-efficient landscaping
- 13 Ground-source heat pump



© EHDD Architecture

Section view of IDeAs building. Integrated Design Associates (IDeAs) transformed a 1960s-era concrete windowless bank building by adding windows, skylights and energy-efficient lighting and HVAC. By maximizing efficiency before sizing the photovoltaic system to cover the remaining loads, costs were kept to a minimum. In 2009, the building used less energy than it produced, achieving the goal of net zero energy and carbon emissions.

Source: Kaneda, D., P. Rumsey, and S. Shell. 2010. Less than Zero. *High Performing Building*.
<http://www.hpbmagazine.org/attachments/article/12143/10F-IDeAs-Z2-Design-Facility-San-Jose-CA.pdf>.
 Photographs © David Wakely. Graphic © EHDD Architecture.




© Jeremy Bitterman



© Jeremy Bitterman

Source: P. Rumsey, E. Soladay, and A. Murphree. 2015. Graceful Inspiration. *High Performing Building*. <http://www.hpbmagazine.org/attachments/article/12152/15W-David-&-Lucile-Packard-Foundation-Headquarters-Los%20Altos-California.pdf>. Photographs © Jeremy Bitterman.




Source: P. Rumsey, E. Soladay, and A. Murphree. 2015. Graceful Inspiration. *High Performing Building*.
<http://www.hpbmagazine.org/attachments/article/12152/15W-David-&-Lucile-Packard-Foundation-Headquarters-Los%20Angeles-California.pdf>.
Photographs © Jeremy Bitterman.

Stevens Library at Sacred Heart Schools, Atherton



<http://www.hpbmagazine.org/Web-Exclusive-Stevens-Library-at-Sacred-Heart-Schools-Atherton-Calif/>



Closing Comments

Growth in ZNE Buildings

Zero Energy Building Growth





Fig 1. The Buildings List includes nearly 500 projects and is on a steep curve upward, having increased over 700% since 2012.


North American ZNE Locations – 2018

2018 Buildings List Project Locations




Sustainability—The Big Picture

- Transportation
- Water
- Materials and products



Wrap-Up



charles@eley.com

Evaluation and Certificate

- ASHRAE values your comments about this course. All course registrants will receive a separate email from ALI-Education (edu@ashrae.org) allowing access to the course survey and certificate of attendance. Once you have completed the survey, you will be redirected to the attendance certificate. Questions concerning this process should be sent to edu@ashrae.org.
- A copy of the course presentation is available at:
<https://www.ashrae.org/2020nov17>
- If you have any questions about ASHRAE Certificates, please contact Kelly Arnold, Coordinator Professional Development at karnold@ashrae.org.
- If you have any questions about ASHRAE courses, please contact Tiffany Cox, Professional Development Course Administrator, at tcx@ashrae.org.



Explore ASHRAE Learning Institute Courses

<https://www.ashrae.org/instructor-led-courses>

Find a Topic that Fits You:

- Commissioning
- Energy Efficiency
- Environmental Quality
- HVAC&R Applications
- Standards and Guidelines

See all the ways to learn and grow with ASHRAE at:

<https://www.ashrae.org/professional-development/learning-portal>

ASHRAE Certification



- ✓ More than **3,000 certifications** earned to-date
- ✓ Elevate your **reputation** among peers, in the workplace and among clients
- ✓ **NEW!** Digital Badging:



- Embedded [metadata](#) uniquely linked to you
- Shareable in electronic media, including LinkedIn and email
- Instant recognition, with real-time, third-part verification

Visit www.ashrae.org/certification to learn more