ADDENDA

ANSI/ASHRAE/IES Addendum bl to
ANSI/ASHRAE/IES Standard 90.1-2013

Energy Standard for Buildings Except Low-Rise Residential Buildings

Approved by the ASHRAE Standards Committee on January 23, 2016; by the ASHRAE Board of Directors on January 27, 2016; by the IES Board of Directors on December 31, 2015; and by the American National Standards Institute on January 28, 2016.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website (www.ashrae.org) or in paper form from the Senior Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2016 ASHRAE ISSN 1041-2336

ASHRAE® IES Illuminating ENGINEERING SOCIETY Approved American National Standard ANSI www.ansi.org

ASHRAE Standing Standard Project Committee 90.1
Cognizant TC: 7.6, Systems Energy Utilization
SPLS Liaison: Roger Hedrick
ASHRAE Staff Liaison: Steven C. Ferguson
IES Liaison: Rita M. Harrold

Drake Erbe*, *Chair*
Thomas Culp*, *Vice-Chair*
Richard, Lord*, *Vice-Chair*
Peter Baselici *
Sean Beilman*
Jeff Boldt*
Ernie Conrad*
Charles Cottrell*
Jay Crandall*
Craig Drumheller*
Jim Garrigus*
Jason Glazer*
Krishnan Gowri*
Pekka Hakkarainen*
Susanna Hanson*
Richard Heinisch*
Ned Heminger*
Dave Herron*
Scott Hintz*
John Hogan*
Jonathan Humble*
Itzhak Maor*
Chris Mathis*
Michael Mehl*
Harry Misuriello*
Frank Morrison*
Frank Myers*
Ron Nickson*
Tim Peglow*
Eric Richman*
Steve Rosenstock*
Bob Ross*
Marty Salzburg*
Leonard Sciarra*
Frank Stanonik*
Wayne Stoppelmoor*
Christian Taber*
William Talbert*
Steven Taylor*
Martha VanGeem*
McHenry Wallace*
Jerry White*
Jeremy Williams*
Karim Amrane
Gary Ash
Joseph Brooks
Don Brundage
Brandon Damas
John Dunlap
Chuck Foster
Sam Francis
Antonio Giacobbe
John Green
Chad Groshart
David Handwork
Stan Harbuck
Richard Hermans
Michael Ivanovich
Hy Kaplan
Neil Leslie
Merle McBride
Benjamin Meyer
Keith Nelson
Amy Schmidt
David Shepherd
Don Surrena
Stephen Szoke
Mike Tillou
Doug Tucker
Richard Watson
Jason Wilen

** Denotes voting member at time of publication.*

© ASHRAE (www.ashrae.org). For personal use only. Additional reproduction, distribution,
or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This addendum clarifies that water economizers may use dry coolers. Any type of heat or mass transfer is allowed whether dry or evaporative.

> ***economizer, water****: a system by which the supply air of a cooling system is cooled indirectly with water that is itself cooled by heat or mass transfer to the environment without the use of mechanical cooling.*

Note: In this addendum, changes to the current standard are indicated in the text by <u>underlining</u> (for additions) and ~~strikethrough~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum bl to 90.1-2013

Modify the standard as follows (IP and SI Units).

6.5.1.2.1 Design Capacity. Water economizer systems shall be capable of ~~cooling supply air by indirect evaporation and~~ providing up to 100% of the expected system cooling load at outdoor air temperatures of 50°F dry bulb/45°F wet bulb and below.

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

ASHRAE · 1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org