

1. Which of the following is the recommended type of supply diffuser for an Operating Room?

- A. non-aspirating ceiling**
- B. sidewall**
- C. window sill grille**
- D. three-way ceiling**

Objective 1B

Task 1

Recall

Answer: A

2. In accordance with FGI/AIA Guidelines, patient room ventilation rates may have fewer than 6 ACH when

- A. the supply air is filtered with HEPA filters.**
- B. supplemental heating and/or cooling systems are used.**
- C. there is only one person in the room.**
- D. there is 100% outside air.**

Objective 2A

Task 2

Application

Answer: B

3. In accordance with FGI/AIA Guidelines, which of the following is the MINIMUM distance that a fresh air intake can be located from contaminated exhaust?

- A. 10 feet (3.0 m)**
- B. 25 feet (7.6 m)**
- C. 35 feet (10.7 m)**
- D. 50 feet (15.2 m)**

Objective 2A

Task 2

Recall

Answer: B