

ERRATA SHEET FOR ANSI/ASHRAE STANDARD 206-2013 (RA 2017)
Method of Testing for Rating of Multipurpose Heat Pump for
Residential Space Conditioning and Water Heating

March 27, 2019

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 206-2013 (RA 2017). The first printing is identified on the outside back cover as “Product code: 86636 6/17” and the second printing is identified as “Product code: 86636 4/18”.

Page Erratum

- 42 11.3.1.1 Cooling – Steady-State.** In the SI version of Equation 11.3.1.1-4 change “1085” to “1859”. See change below.

(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

$$C_{pa} = 1005 + \underline{1859} \del{1085} W_n, \text{ J/kg}\cdot^\circ\text{C} \quad (\text{SI}) \quad (11.3.1.1-4)$$

$$[= 0.24 + 0.444 W_n, \text{ Btu/lb}_m\cdot^\circ\text{F}] \quad (\text{I-P})$$