

Errata to
Advanced Energy Design Guide for Medium to Big Box Retail Buildings

July 21, 2015

Shaded items have been added since the previously published errata sheet dated April 28, 2014.

- Pages 58–79:** In the Quality Assurance section of the Climate Zone Recommendation Tables for Climate Zones 1 through 8, for the Training component change the recommendation from “Facility operator or continuous benchmarking” to “Facility operator **on** continuous benchmarking.”
- Page 60:** In the Doors item of the Envelope section of the Climate Zone Recommendation Table for Climate Zone 2, change the recommendation for swinging doors from “0-0.70” to “**U-0.07.**”
- Page 66:** In the Roofs item of the Envelope section of the Climate Zone Recommendation Table for Climate Zone 4, change the How-To Tips for metal building roofs from “None” to “**EN1, 3, 18–21.**”
- Page 82:** The caption for Figure 5-1 currently reads “(a) Filled Cavity; (b) Liner System, One Layer; (c) Liner System, Two Layers” but should read “(a) Filled Cavity; (b) Liner System, **Two Layers;** (c) Liner System, **Three Layers.**”

For online access to these errata as well as updates to other publications, visit www.ashrae.org/publicationupdates.

Please notify ASHRAE of any other errors you might find by using the Comment on Publications form at www.ashrae.org/resources--publications.

