



ADDENDA

**ANSI/ASHRAE Addendum p to
ANSI/ASHRAE Standard 135.1-2013**

Method of Test for Conformance to BACnet[®]

Approved by ASHRAE on May 31, 2018, and by the American National Standards Institute on June 1, 2018.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE[®] website (www.ashrae.org) or in paper form from the Senior Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2018 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 135
Cognizant TC: 1.4, Control Theory and Application
SPLS Liaison: Roger L. Hedrick

Bernhard Isler*, <i>Chair</i>	David G. Holmberg*	David Robin
Michael Osborne, <i>Vice-Chair</i>	Daniel Kollodge*	Frank Schubert
Coleman L. Brumley, Jr.*, <i>Secretary</i>	Jake Kopocis*	Gregory M. Spiro*
Donald P. Alexander	Thomas Kurowski	David B. Thompson
Clifford H. Copass*	Carl Neilson	Klaus Wagner
Sharon E. Dinges	H. Michael Newman*	Grant N. Wichenko*
Stuart G. Donaldson*	Duffy O'Craven*	Scott Ziegenfus
Seán Giblin	Narasimha Reddy	
Michael P. Graham*	Jonathan Rigsby	

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2017–2018

Steven J. Emmerich, <i>Chair</i>	Roger L. Hedrick	David Robin
Donald M. Brundage, <i>Vice-Chair</i>	Rick M. Heiden	Peter Simmonds
Niels Bidstrup	Jonathan Humble	Dennis A. Stanke
Michael D. Corbat	Srinivas Katipamula	Wayne H. Stoppelmoor, Jr.
Drury B. Crawley	Kwang Woo Kim	Richard T. Swierczynna
Julie M. Ferguson	Larry Kouma	Jack H. Zarour
Michael W. Gallagher	Arsen K. Melikov	Lawrence C. Markel, <i>BOD ExO</i>
Walter T. Grondzik	R. Lee Millies, Jr.	M. Ginger Scoggins, <i>CO</i>
Vinod P. Gupta	Karl L. Peterman	
Susanna S. Hanson	Erick A. Phelps	

Steven C. Ferguson, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

[This foreword and the “rationales” on the following pages are not part of this standard. They are merely informative and do not contain requirements necessary for conformance to the standard.]

FOREWORD

The purpose of this addendum is to present changes to ANSI/ASHRAE 135.1-2013 and Addenda. These modifications are the result of change proposals made pursuant to the ASHRAE continuous maintenance procedures and of deliberations within Standing Standard Project Committee 135. The changes are summarized below.

135.1-2013p-1. Fix the EPICS Consistency Tests, p. 2

135.1-2013p-2. Remove EPICS Database Templates, p. 4

135.1-2013p-3. Add Test for Use of Error Code BUSY with Command Object, p. 5

In the following document, language to be added to existing clauses is indicated through the use of italics, while deletions are indicated by ~~striking through~~. Where entirely new subclauses are added, plain type is used throughout. All other material in this addendum is provided for context only.

The use of placeholders like X, Y, Z, X1, X2, etc., should not be interpreted as literal values of the final standard. These placeholders will be assigned actual numbers/letters only after incorporation of this addendum into the standard for republication.

135.1-2013p-1. Fix the EPICS Consistency Tests.

Rationale

New requirements are added to the EPICS consistency tests:

- verify the Property_List property
- verify the Max_Segments_Accepted value
- verify the declaration of temporarily existent File objects
- verify the declaration of conditionally writable properties

In addition, the naming of the Protocol_Services_Supported and Protocol_Object_Types_Supported properties is fixed.

[Change **Clause 5**, p. 23]

5. EPICS CONSISTENCY TESTS

These tests are static tests of the EPICS and do not involve interrogating the IUT. There are no Test Configuration or Test Step sections with TCSL in these tests because the tests are static tests of the EPICS and not tests of the IUT itself.

Each implementation shall be tested to ensure consistency among interrelated data elements. These tests shall include:

- (a) All object types required by the specified BIBBs shall be indicated as supported in the Standard Object Types Supported section of the EPICS.
...
- (c) The ~~Object_Types_Supported~~ *Protocol_Object_Types_Supported* property of the Device object in the test database shall indicate support for each object type required by the supported BIBBs.
...
- (e) The ~~Application_Services_Supported~~ *Protocol_Services_Supported* property of the Device object in the test database shall indicate support for each application service for which the supported BIBBs requires support for execution of the service.
- (f) The object types listed in the Standard Object Types Supported section of the EPICS shall have a one-to-one correspondence with object types listed in the ~~Object_Types_Supported~~ *Protocol_Object_Types_Supported* property of the Device object contained in the test database. *An object type is supported if it can be made to exist in the IUT's database.*
- (g) For each object type listed in the Standard Object Types Supported section of the EPICS there shall be at least one object of that type in the test database. *It is permissible for there to be no instance of the File object type if File objects are dynamically creatable and come into existence only temporarily during Backup and Restore.*
...
- (i) For each object included in the test database, all required properties for that object as defined in Clause 12 of BACnet shall be present. *Standard properties which are not defined for the implemented Protocol_Revision shall not be present.* In addition, if any of the properties supported for an object require the conditional presence of other properties, their presence shall be verified.
- (j) For each property that is required to be writable, *or conditionally writable*, that property shall be marked as writable, *or conditionally writable*, in the EPICS.

...

- (m) *For each object included in the test database, any properties that are deprecated or removed shall not appear after the Protocol_Revision in which the property was deprecated or removed.*
- (n) *If the Protocol_Revision property is present in the Device object and its value is greater than or equal to 14, for each object included in the test database, the Property_List property shall have one entry for each property present, including non-standard properties, but excluding Object_Type, Object_Identifier, Object_Name, and Property_List.*
- (o) *If the Segmentation_Supported property in the Device object is SEGMENTED_BOTH or SEGMENTED_RECEIVE, then the value of the Max_Segments_Accepted property of the Device object shall be greater than 1.*

135.1-2013p-2. Remove EPICS Database Templates.

Rationale

Remove EPICS database templates to reduce maintenance issues.

[Modify **Clause 4.5.10**, p. 9]

...

Properties in the test database that are conditionally writable shall have a "C" following the property value, as shown in the example below. It is recommended that the governing mechanism be identified in a comment:

```
{
  object-identifier: (analog-input, 6)
  object-name: "□"
  object-type: analog-input
  present-value: 12.3 C    -- Writable when Out_Of_Service is TRUE
  other properties...
}
```

~~The following sections show templates for each of the standard object types. To improve readability, the carriage return/linefeed pairs are not explicitly shown in the examples.~~

[Delete all **Clauses 4.5.10.1 thru 4.5.10.28**, p. 9]

135.1-2013p-3. Add Test for Use of Error Code BUSY with Command Object.

Rationale

Add a test to ensure writes to the Present_Value of a Command object results in an error consisting of an error class of OBJECT and an error code of BUSY. This requirement was added with Addendum 135-2008h, Section 1 (i.e., protocol revision 10).

[Change **Clause 7.3.2.9.7**, p. 71]

7.3.2.9.7 Write While In_Process is TRUE Test

Dependencies: WriteProperty Service Execution Tests, 9.22.

BACnet Reference Clauses: 12.10.8 and 12.10.9.

Purpose: To verify that an action list continues to completion if a second action list is commanded while In_Process is TRUE and that the second action list is not executed.

Test Concept: The IUT is configured with two action lists that include a sequence of externally visible outputs with post delays for each action. The TD triggers the first action list. The external outputs are observed in order to trigger the second action list during the post delay of the first list. The TD triggers the second action list. The external outputs are observed to verify that the second action list is not executed. If the IUT does not support Post Delay, then this test shall be omitted. If the IUT does not support action list configuration, then this test shall be omitted.

Configuration Requirements: The IUT shall be configured with a Command object O having two distinct action lists, X and Y, that include writing to a sequence of externally visible outputs. There shall be a post delay between writes to the externally visible outputs that is long enough for the tester to observe the delay (This ensures In_Process remains TRUE long enough to command the second action list).

Test Steps:

1. WRITE Present_Value = X
- ~~2. RECEIVE Simple ACK PDU~~
- ~~3. WRITE Present_Value = Y~~
2. TRANSMIT WriteProperty-Request,
 'Object Identifier' = O,
 'Property Identifier' = Present_Value,
 'Property Value' = Y
- 4 3. IF (Protocol_Revision is present and Protocol_Revision ≥ 10) THEN
 RECEIVE BACnet-Error-PDU,
 Error Class = OBJECT,
 Error Code = BUSY
 ELSE
 (RECEIVE BACnet-Error-PDU,
 Error Class = OBJECT,
 Error Code = BUSY) |
 (RECEIVE BACnet-Error-PDU,
 Error Class = SERVICES,
 Error Code = SERVICE_REQUEST_DENIED | OTHER)
- ~~5 4. CHECK (that the externally visible actions of X took take place)~~
- ~~6 5. CHECK (that the externally visible actions of Y did do not take place)~~
- 7 6. VERIFY In_Process = FALSE,
- 8 7. VERIFY All_Writes_Successful = TRUE

[Add to **HISTORY OF REVISIONS**, p. 662]

HISTORY OF REVISIONS

<i>Summary of Changes to the Standard</i>
...
ANSI/ASHRAE Standard 135.1-2013 A consolidated version of the standard that incorporates Addenda <i>j, k, l, m and n</i> to ANSI/ASHRAE 135.1-2011 and all of the known errata.
Addendum <i>p</i> to ANSI/ASHRAE 135.1-2013 Approved by ASHRAE on May 31, 2018, and by the American National Standards Institute on June 1, 2018. <ol style="list-style-type: none">1. Fix the EPICS Consistency Tests2. Remove EPICS Database Templates3. Add Test for Use of Error Code BUSY with Command Object

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

About ASHRAE

ASHRAE, founded in 1894, is a global society advancing human well-being through sustainable technology for the built environment. The Society and its members focus on building systems, energy efficiency, indoor air quality, refrigeration, and sustainability. Through research, Standards writing, publishing, certification and continuing education, ASHRAE shapes tomorrow's built environment today.

For more information or to become a member of ASHRAE, visit www.ashrae.org.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, on CD-ROM, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.