

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1 ab –Publication Draft. Proposed changes clarify that the additional power allowances apply to any lighted area that meets the criteria for additional lighting power allowance. This change does not change the intent or practical stringency of the section.

Addendum 90.1 ab

9.3 Prescriptive Path

Additional Interior Lighting Power. When using the Space-by-Space Method, aAn increase in the *interior lighting power allowance* is allowed ~~when using the Space-by-Space Method for specific space-lighting functions as noted in Table 9.3.1.2. In all such spaces in which an additional lighting power allowance is taken, the a~~Additional power shall be allowed only if the specified lighting is installed. ~~Additional power,~~ shall be used only for the specified *luminaires*, and shall not be used for any other purpose or in any other space.

An increase in the *interior lighting power allowance* ~~for space types noted in Table 9.3.1.2 as eligible for additional interior lighting power allowance~~ is permitted in the following cases:

AND

In all of Table 9.3.1.2 delete the last column (checkmarks) with the heading “Additional Power Allowance (see 9.3.1.2)”.