

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1 ac –Publication Draft. The standard does not direct the designer as to how to determine the load of the system. The additional wording provides the designer with more flexibility in determining the load of the system.

Addendum 90.1 ac

7.2.1 Load Calculations~~Sizing of Systems~~. Service water heating *system* design loads for the purpose of sizing *systems* and *equipment* shall be determined in accordance with the manufacturers' published sizing guidelines or generally accepted engineering standards and handbooks acceptable to the adopting authority (e.g., ASHRAE Handbook – HVAC Applications).