

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1g – Publication Draft. The F-factor and R-values for heated slabs-on-grade were correct in the Public Review Draft #2. During the drafting process of the Independent Substantive Change and Draft Final Standard some of the numbers changed. This addendum will place the correct values into the criteria tables for the tables noted.

Addendum 90.1g

Appendix B: Revise the heated slab-on-grade floor values in Tables 19 through 26 as follows:

TABLE NO. (UNITS)	OPAQUE ELEMENTS	NONRESIDENTIAL	RESIDENTIAL
19 (I-P)	<u>Slab-on-grade Floors</u> Heated		F 0.540 R-10 <u>for 48 in</u> <u>F 0.780</u>
20 (I-P)	<u>Slab-on-grade Floors</u> Heated		F 0.540 R-10 <u>for 48 in</u> <u>F 0.780</u>
21 (I-P)	<u>Slab-on-grade Floors</u> Heated		F 0.540 R-10 <u>for 48 in</u> <u>F 0.780</u>
22 (I-P)	<u>Slab-on-grade Floors</u> Heated		F 0.540 R-10 <u>for 48 in</u> <u>F 0.780</u>
23 (I-P)	<u>Slab-on-grade Floors</u> Heated	F 0.550 R-10 <u>F 0.780</u> R-10 <u>for 48 in</u>	F 0.440 R-15 <u>F 0.780</u> R-10 <u>for 48 in</u>
24 (I-P)	<u>Slab-on-grade Floors</u> Heated	F 0.550 R-10 <u>F 0.780</u> R-10 <u>for 48 in</u>	F 0.440 R-15 <u>F 0.780</u> R-10 <u>for 48 in</u>
25 (I-P)	<u>Slab-on-grade Floors</u> Heated	F 0.440 R-15 <u>F 0.780</u> R-10 <u>for 48 in</u>	F 0.440 R-15 <u>F 0.780</u> R-10 <u>for 48 in</u>
26 (I-P)	<u>Slab-on-grade Floors</u> Heated	F 0.440 R-15 <u>F 0.780</u> R-10 <u>for 48 in</u>	F 0.373 R-20 <u>F 0.780</u> R-10 <u>for 48 in</u>
19 (SI)	<u>Slab-on-grade Floors</u> Heated		F 0.95 R-1.8 <u>for 122 cm</u> <u>F 1.35</u>
20 (SI)	<u>Slab-on-grade Floors</u> Heated		F 0.95 R-1.8 <u>for 122 cm</u> <u>F 1.35</u>
21 (SI)	<u>Slab-on-grade Floors</u> Heated		F 0.950 R-1.8 <u>for 122 cm</u> <u>F 1.35</u>
22 (SI)	<u>Slab-on-grade Floors</u> Heated		F 0.95 R-1.8 <u>for 122 cm</u> <u>F 1.35</u>
23 (SI)	<u>Slab-on-grade Floors</u> Heated	F 0.95 R-1.8 <u>for 122 cm</u> <u>F 1.35</u>	F 0.76 R-2.6 <u>F 1.35</u> R-1.8 <u>for 122 cm</u>
24 (SI)	<u>Slab-on-grade Floors</u> Heated	F 0.95 R-1.8 <u>for 122 cm</u> <u>F 1.35</u>	F 0.76 R-2.6 <u>F 1.35</u> R-1.8 <u>for 122 cm</u>
25 (SI)	<u>Slab-on-grade Floors</u> Heated	F 0.76 R-2.6 <u>F 1.35</u> R-1.8 <u>for 122 cm</u>	F 0.76 R-2.6 <u>F 1.35</u> R-1.8 <u>for 122 cm</u>
26 (SI)	<u>Slab-on-grade Floors</u> Heated	F 0.76 R-2.6 <u>F 1.35</u> R-1.8 <u>for 122 cm</u>	F 0.65 R-3.5 <u>F 1.35</u> R-1.8 <u>for 122 cm</u>