

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1v – Publication Draft. In the first public review, the modification of 9.2.1.1 c) in the addendum provided additional detail on the intent of the original standard phrase: “an unscheduled basis by occupant intervention”. The additional inclusion of 9.2.1.1 “d) by occupant override.” was an oversight since occupant override for automatic controls is already covered in 9.2.1.2 of the standard.

ADDENDUM 90.1V (I-P AND SI EDITIONS)

9.2 Mandatory Provisions

9.2.1 Lighting Control

9.2.1.1. Automatic Lighting Shutoff. Interior lighting in *buildings* larger than 5000 ft² (465 m²) shall be controlled with an *automatic control device* to shut off *building* lighting in all spaces. This *automatic control device* shall function on either:

- a) a scheduled basis using a time-of-day operated control device that turns lighting off at specific programmed times. An independent program schedule shall be provided for areas of no more than 25,000 ft² (2,323 m²) but not more than one floor; or
- b) an occupant sensor that shall turn lighting off within 30 minutes of an occupant leaving a space; or
- c) a signal from another control or alarm system that indicates the area is unoccupied.