

**INTERPRETATION IC 62.2-2007-5 OF  
ANSI/ASHRAE STANDARD 62.2-2007  
Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings**

Approved July 11, 2009

**Request from:** Bruce Wilcox ([bwilcox@lmi.net](mailto:bwilcox@lmi.net)), 1110 Monterey Ave, Berkeley, CA 94707.

**Reference:** This request for interpretation refers to the requirements presented in ANSI/ASHRAE Standard 62.2-2007, Table 7.1 Prescriptive Duct Sizing.

**Background:** Builders and code authorities using Standard 62.2-7007 are unsure how to use Table 7.1.

**Interpretation:** Interpolation and extrapolation in Table 7.1 is not allowed. For air flow values not listed, use the next higher value. Table 7.1 is not applicable for systems with air flow greater than 125 cfm @ 0.25 in. w.g. (65 L/s @ 62.5 Pa).

**Question:** Is this Interpretation correct?

**Answer:** Yes

**Comment:** None.