

**INTERPRETATION IC 62-2001-11 OF
ANSI/ASHRAE STANDARD 62-2001
VENTILATION FOR ACCEPTABLE INDOOR AIR QUALITY**

TRANSFER TO 62-2001 APPROVED: January 12, 2002

Originally issued as interpretation of Standard 62-1989 (IC 62-1989-1) on January 29, 1995, but transferred to Standard 62-1999 (IC 62-1999-9) on August 14, 2000, and subsequently to Standard 62-2001. Since no changes were made to the relevant sections of Standard 62-2001, no revisions were made to the interpretation as part of this transfer.

Request from: Eugene M. Moreau, P.E., Manager, Indoor Air Program, Division of Health Engineering, State of Maine, Department of Human Services, Augusta, ME 04333.

References. This request refers to the requirements for ventilation of public restrooms given in ASHRAE Standard 62-2001, Table 2.1, and in paragraphs 6.1.3.1, 6.1.3.2 and 6.1.3.4.

Question 1. Is intermittent exhaust permissible in restrooms?

Answer. Yes. Restroom ventilation may be interrupted under the procedure of subsection 6.1.3.4, "Intermittent or Variable Occupancy."

Question 2. Are the remarks in Table 2.1 mandatory or advisory?

Answer. Advisory (should, or recommended), unless stated as mandatory (shall).