


ANSI/ASHRAE Addendum a to
ANSI/ASHRAE Standard 135-2004



ASHRAE STANDARD

BACnet[®]—A Data Communication Protocol for Building Automation and Control Networks

Approved by the ASHRAE Standards Committee on October 3, 2004; by the ASHRAE Board of Directors on February 10, 2005; and by the American National Standards Institute on February 10, 2005.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site, <http://www.ashrae.org>, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in U.S. and Canada).

© Copyright 2005 ASHRAE, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

www.ashrae.org

ASHRAE Standing Standard Project Committee 135
Cognizant TC: TC 1.4, Control Theory and Application
SPLS Liaison: Frank E. Jakob

Steven T. Bushby, *Chair**
William O. Swan, III, *Vice-Chair*
Carl Neilson, *Secretary*
Barry B. Bridges*
James F. Bulter*
A.J. Capowski*
Troy Cowan*
Thomas S. Ertsgaard*

Craig P. Gemmill*
Robert L. Johnson
Stephen T. Karg*
J. Damian Ljungquist*
David Robin
Daniel A. Traill*
J. Michael Whitcomb*
David P. White

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2004-2005

Dean S. Borges, *Chair*
Richard D. Hermans, *Vice-Chair*
Donald B. Bivens
Paul W. Cabot
Hugh F. Crowther
Brian P. Dougherty
Hakim Elmahdy
Matt R. Hargan
Roger L. Hedrick
John F. Hogan
Frank E. Jakob
Stephen D. Kennedy

David E. Knebel
Merle F. McBride
Mark P. Modera
Cyrus H. Nasser
Davor Novosel
George Reeves
John Sabelli
Stephen V. Santoro
Gideon Shavit
David R. Tree
James E. Woods
Michael F. Beda, *BOD ExO*
William A. Harrison, *CO*

Claire B. Ramspeck, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard.)

FOREWORD

The purpose of this addendum is to add a number of independent substantive changes to the BACnet standard. These modifications are the result of change proposals made pursuant to the continuous maintenance procedures contained in the *Manual for Processing ASHRAE Standards* and *PC Guidance* and of deliberations within Standing Standard Project Committee 135. The changes are summarized below.

135a-1. Revise Life Safety Point and Life Safety Zone object types to modify their behavior when placed out of service, p. 1.

In the following document, language to be added to existing clauses of ANSI/ASHRAE 135-2004 and Addenda is indicated through the use of *italics*, while deletions are indicated by ~~strike through~~. Where entirely new subclauses are proposed to be added, plain type is used throughout.

135-2004a-1. Revise Life Safety Point and Life Safety Zone object types for out-of-service operation.

Addendum 135-2004a-1

[Change **Table 12-18**, p. 194]

Table 12-18. Properties of the Life Safety Point Object Type

Property Identifier	Property Datatype	Conformance Code
...
Present_Value	BACnetLifeSafetyState	\mathbb{R}^+R
Tracking_Value	BACnetLifeSafetyState	$\Theta R'$
...

[Change **12.15.4**, p. 195]

12.15.4 Present_Value

This property, of type BACnetLifeSafetyState, reflects the state of the Life Safety Point object. The means of deriving the Present_Value shall be a local matter. Present_Value may latch non-NORMAL state values until reset. ~~The Present_Value property shall be writable when Out_Of_Service is TRUE.~~

[Change **12.15.5**, p. 195]

12.15.5 Tracking_Value

This ~~optional~~ property, of type BACnetLifeSafetyState, reflects the non-latched state of the Life Safety Point object. The means of deriving the state shall be a local matter. Unlike Present_Value, which may latch non-NORMAL state values until reset, Tracking_Value shall continuously track changes in the state. *The Tracking_Value property shall be writable when Out_Of_Service is TRUE.*

[Change **12.15.11**, p. 196]

12.15.11 Out_Of_Service

The Out_Of_Service property, of type BOOLEAN, is an indication whether (TRUE) or not (FALSE) the input(s) or process the object represents is not in service. This means that changes to the ~~Present_Value Tracking_Value~~ property are decoupled from the input(s) or process when the value of Out_Of_Service is TRUE. In addition, the Reliability property and the corresponding state of the FAULT flag of the Status_Flags property shall be decoupled when Out_Of_Service is TRUE. While the Out_Of_Service property is TRUE, the ~~Present_Value Tracking_Value~~ and Reliability properties may be changed to any value as a means of simulating specific fixed conditions or for testing purposes. Other functions that depend on the state of the ~~Present_Value Tracking_Value~~ or Reliability properties shall respond to changes made to these properties while Out_Of_Service is TRUE, as if those changes had occurred to the input(s) or process.

[Change **Table 12-19**, p. 200]

Table 12-19. Properties of the Life Safety Zone Object Type

Property Identifier	Property Datatype	Conformance Code
...
Present_Value	BACnetLifeSafetyState	\mathbb{R}^+R
Tracking_Value	BACnetLifeSafetyState	$\Theta R'$
...

[Change 12.16.4, p. 201]

12.16.4 Present_Value

This property, of type BACnetLifeSafetyState, reflects the state of the Life Safety Zone object. The means of deriving the Present_Value shall be a local matter. Present_Value may latch non-NORMAL state values until reset. ~~The Present_Value property shall be writable when Out_Of_Service is TRUE.~~

[Change 12.16.5, p. 201]

12.16.5 Tracking_Value

This ~~optional~~ property, of type BACnetLifeSafetyState, reflects the non-latched state of the Life Safety Zone object. The means of deriving the state shall be a local matter. Unlike Present_Value, which may latch non-NORMAL state values until reset, Tracking_Value shall continuously track changes in the state. *The Tracking_Value property shall be writable when Out_Of_Service is TRUE.*

[Change 12.16.11, p. 202]

12.16.11 Out_Of_Service

The Out_Of_Service property, of type BOOLEAN, is an indication whether (TRUE) or not (FALSE) the input(s) or process the object represents is not in service. This means that changes to the ~~Present_Value~~ Tracking_Value property are decoupled from the input(s) or process when the value of Out_Of_Service is TRUE. In addition, the Reliability property and the corresponding state of the FAULT flag of the Status_Flags property shall be decoupled when Out_Of_Service is TRUE. While the Out_Of_Service property is TRUE, the ~~Present_Value~~ Tracking_Value and Reliability properties may be changed to any value as a means of simulating specific fixed conditions or for testing purposes. Other functions that depend on the state of the ~~Present_Value~~ Tracking_Value or Reliability properties shall respond to changes made to these properties while Out_Of_Service is TRUE, as if those changes had occurred to the input(s) or process.

[Change Annex C, p.459]

```

LIFE-SAFETY-POINT ::= SEQUENCE {
    ...
    present-value          [85]   BACnetLifeSafetyState,
    tracking-value         [164]  BACnetLifeSafetyState OPTIONAL,
    description            [28]   CharacterString OPTIONAL,
    ...
}

```

[Change Annex C, p.460]

```

LIFE-SAFETY-ZONE ::= SEQUENCE {
    ...
    present-value          [85]   BACnetLifeSafetyState,
    tracking-value         [164]  BACnetLifeSafetyState OPTIONAL,
    description            [28]   CharacterString OPTIONAL,
    ...
}

```

[Add a new entry to **History of Revisions**, p.598]

(This History of Revisions is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard)

HISTORY OF REVISIONS

<i>Protocol</i>		<i>Summary of Changes to the Standard</i>
<i>Version</i>	<i>Revision</i>	
...
1	5	Addendum a to ANSI/ASHRAE 135-2004 Approved by the ASHRAE Standards Committee October 3, 2004; by the ASHRAE Board of Directors February 10, 2005; and by the American National Standards Institute February 10, 2005. 1. Revise Life Safety Point and Life Safety Zone object types to modify their behavior when placed out of service.

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.