



ADDENDA

**ANSI/ASHRAE Addendum g to
ANSI/ASHRAE Standard 15-2013**

Safety Standard for Refrigeration Systems

Approved by the ASHRAE Standards Committee on June 29, 2016; by the ASHRAE Technology Council on June 29, 2016; and by the American National Standards Institute on June 30, 2016.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website (www.ashrae.org) or in paper form from the Senior Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2016 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 15
Cognizant TCs: 101, Custom Engineered Refrigeration Systems,
and 9.1, Large Building Air-Conditioning Systems
SPLS Liaison: Roger Hedrick

Dennis Dorman*, <i>Chair</i>	Douglas T. Reindl*	Tim Halsor
Martin Timm, <i>Vice-Chair</i>	Brian J. Rodgers*	Alexander Hillbrand
Gregory A. Scrivener*, <i>Secretary</i>	Jeffrey M. Shapiro*	Glenn C. Hourahan
Wayne K. Borrowman*	Eric M. Smith*	Hung M. Pham
Els Baert	Russell C. Tharp*	Douglas K. Tucker
Jim Caylor*	John I. Vucci*	James T. Vershaw
Danny Halel*	Larry D. Burns	Wei Wang
Scott MacBain*	Rakesh Goel	

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2016–2017

Rita M. Harrold, <i>Chair</i>	Julie M. Ferguson	Cyrus H. Nasser
Steven J. Emmerich, <i>Vice-Chair</i>	Michael W. Gallagher	David Robin
James D. Aswegan	Walter T. Grondzik	Peter Simmonds
Niels Bidstrup	Vinod P. Gupta	Dennis A. Stanke
Donald M. Brundage	Susanna S. Hanson	Wayne H. Stoppelmoor, Jr.
Waller S. Clements	Roger L. Hedrick	Jack H. Zarour
Drury B. Crawley	Rick M. Heiden	William F. Walter, <i>BOD ExO</i>
John F. Dunlap,	Srinivas Katipamula	Patricia Graef, <i>CO</i>
James W. Earley, Jr.	Arsen K. Melikov	
Keith I. Emerson	R. Lee Millies, Jr.	

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum g makes a number of important changes to ASHRAE Standard 15-2013. The first change to Section 9.2.1 clarifies the metric unit gage pressure when designing for vacuum. The changes to Section 9.9 give new requirements for the use of pressure limiting devices. The changes to Section 9.11 clarify that ASME Section VIII, "Pressure Vessel Design," is not required for the water side of heat exchangers, provided certain other design requirements are met. The changes to Section 9.13 stipulate that other types of compression devices that are not specifically listed in the section may be used for the connection of copper tubing providing they are agency listed for the refrigeration use. There is also the addition of Section 9.7.8.6. And finally, the changes to the Normative References in Appendix B remove the notes pertaining to References 6 and 8, making these references required for all users.

Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~strikethrough~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum g to Standard 15-2013

Modify Section 9 as shown. NOTE: Changes to Section 9.7.8 in this addendum reflect previous changes made by addendum a to this standard. Addenda to Standard 15 may be downloaded at the ASHRAE website:

<https://www.ashrae.org/standards-research--technology/standards-addenda>

9.2.1 Design pressures shall not be less than pressure arising under maximum operating, standby, or shipping conditions. When selecting the design pressure, allowance shall be provided for setting pressure-limiting devices and pressure-relief devices to avoid nuisance shutdowns and loss of refrigerant. The *ASME Boiler and Pressure Vessel Code*, Section VIII, Division I, Appendix M, contains information on the appropriate allowances for design pressure.

Refrigerating equipment shall be designed for a vacuum of 29.0 in. Hg (32°F) (3.12 kPa) (737 mm Hg [0°C]). Design pressure for lithium bromide absorption systems shall not be less than 5-psig gage pressure 5.00 psi (34.5 kPa 34.7 kPa gage). Design pressure for mechanical refrigeration systems shall not be less than gage pressure 15.0 psi ±5-psig (103 kPa 103.4 kPa gage) and, except as noted in Sections 9.2.2, 9.2.3, 9.2.4, 9.2.5, and 9.2.6, shall not be less than the saturation pressure (gage) corresponding to the following temperatures:

[. . .]

9.7.8 Discharge from Pressure-Relief Devices. Pressure-relief systems designed for vapor shall comply with Section 9.7.8. Pressure-relief systems designed for liquid shall comply with Section 9.4.3.

Different refrigerants shall not be vented into a common relief piping system unless the refrigerants are included in a blend that is recognized by ASHRAE Standard 34¹.

9.9.1 When Required. Pressure-limiting devices complying with Section 9.9 shall be provided for compressors on systems operating above atmospheric pressure, ~~except that a pressure-limiting device is not required on any factory-sealed system containing less than 22 lb (10 kg) of Group A1 refrigerant that has been listed by an approved, nationally recognized testing laboratory and is so identified.~~

Exception: Pressure-limiting devices are not required for listed-factory-sealed systems containing less than 22 lb (10 kg) of Group A1 refrigerant.

9.9.2 Setting. ~~When required by Section 9.9.1, the maximum setting to which a pressure-limiting device is capable of being readily set by use of the adjusting means provided shall not exceed the design pressure of the highside of a system that is not protected by a pressure-relief device or 90% of the setting of the pressure-relief device installed on the highside of a system. The pressure-limiting device shall stop the action of the pressure-imposing element at a pressure no higher than this maximum setting.~~

9.9.2 Setting. Pressure-limiting devices shall be set in accordance with one the following:

- a. For positive-displacement compressors:
 1. When systems are protected by a high-side pressure relief device, the compressor's pressure-limiting device shall be set at or below 90% of the operating pressure for the high-side pressure relief device.
 2. When systems are not protected by a high-side pressure relief device, the compressor's pressure-limiting device shall be set at or below the system's high-side design pressure.
- b. For nonpositive-displacement compressors:
 1. When systems are protected by a high-side pressure relief device, the compressor's pressure-limiting device shall be set at or below 90% of the operating pressure for the high-side pressure relief device
 2. When systems are protected by a low-side pressure relief device that is only subject to lowside pressure and is provided with a permanent relief path between the systems' highside and lowside, without intervening valves, the compressor's pressure-limiting device shall be set at or below the system's high-side design pressure.

9.9.3 Connection. ~~Pressure-limiting devices shall be connected between the pressure-imposing element and any stop valve on the discharge side. There shall be no intervening stop valves in the line leading to the pressure-limiting device.~~

9.9.3 Location. Stop valves shall not be installed between the pressure-imposing element and pressure-limiting devices serving compressors.

9.9.4 Emergency Stop. Activation of a pressure-limiting device shall stop the action of the pressure-imposing element.

[. . .]

9.11.1 [Unchanged]

Exception: Water-side components designed to operate at a temperature not exceeding 210°F (99°C) shall be exempted from the rules of Section VIII of the *ASME Boiler and Pressure Vessel Code*⁶ and shall be designed, constructed, and assembled to have an ultimate strength sufficient to withstand 150 psig (1034 kPa) or two times the design pressure for which it is rated, whichever is greater.

[. . .]

9.13.1 The following are requirements for unprotected refrigerant-containing copper pipe or tubing

[. . .]

b. Copper tube shall be connected by brazed joints, soldered joints, or compression fittings or fittings listed for refrigeration use.

Modify Normative Appendix B as follows.

NORMATIVE APPENDIX B NORMATIVE REFERENCES

This appendix contains full citations for normative references. Full citations for references that are solely informative are included in Informative Appendix A. Note that in some locations within the standard, normative references are also used as informative references. References in this standard are numbered in the order in which they appear in the document,

so the numbers for the informative references are shown for the convenience of the user.

1. *ANSI/ASHRAE Standard 34-2001, Designation and Safety Classification of Refrigerants*, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., Atlanta, GA 30329.
2. Not a normative reference.
3. *ARI 700-1999, Specifications for Fluorocarbon Refrigerants* and *ARI Standard 700c-1999, Appendix C to ARI Standard 700—Analytical Procedures for ARI Standard 700-99*, Air-Conditioning and Refrigeration Institute, 4100 North Fairfax Drive, Arlington, VA 22203.
4. *UL 1995-1995 Heating and Cooling Equipment*, Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.
5. *NFPA 70-2002, National Electrical Code*⁷, National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02269-9101.
6. *ANSI/ASME Boiler and Pressure Vessel Code*, Section VIII, Rules for Construction of Pressure Vessels, Division 1, 2001, American Society of Mechanical Engineers (ASME), 3 Park Avenue, New York, NY 10016-5990.

~~**Note:** Reference 6 is mandatory for designers, manufacturers, and producers of refrigeration equipment. For all other users, this reference is informative.~~

7. Not a normative reference.
8. *ANSI/ASME B31.5-2001, Refrigeration Piping and Heat Transfer Components*, American Society of Mechanical Engineers (ASME), 3 Park Avenue, New York, NY 10016.

~~**Note:** Reference 8 is mandatory for designers, manufacturers, and producers of refrigeration equipment. For all other users, this reference is informative.~~

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

About ASHRAE

ASHRAE, founded in 1894, is a global society advancing human well-being through sustainable technology for the built environment. The Society and its members focus on building systems, energy efficiency, indoor air quality, refrigeration, and sustainability. Through research, Standards writing, publishing, certification and continuing education, ASHRAE shapes tomorrow's built environment today.

For more information or to become a member of ASHRAE, visit www.ashrae.org.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, on CD-ROM, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.