


ANSI/ASHRAE Addenda v and w to
ANSI/ASHRAE Standard 34-2004



ASHRAE STANDARD

Designation and Safety Classification of Refrigerants

Approved by the ASHRAE Standards Committee on January 27, 2007; by the ASHRAE Board of Directors on March 2, 2007; and by the American National Standards Institute on March 27, 2007.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site, <http://www.ashrae.org>, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2007 ASHRAE, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

www.ashrae.org

ASHRAE Standing Standard Project Committee 34
Cognizant TC: TC 3.1, Refrigerants and Secondary Coolants
SPLS Liaison: Roger L. Hedrick
Staff Liaison: Douglas K. Tucker

Robert G. Doerr, <i>Chair*</i>	Jay A. Kohler	Vikas Patnaik
James M. Calm, <i>Vice-Chair*</i>	Stephen Kujak	Robert G. Richard
Sean Cunningham	Andrew Kusmierz*	George M. Rusch
David A. Didion*	Thomas J. Leck	John Senediak*
Paul H. Dugard*	Mark O. McLinden*	Gansesan "Sonny" Sundaresan*
H. Michael Hughes*	Nandini C. Mouli	Eugene F. Troy
Gary W. Jepson*	Sandra R. Murphy	William Walter
Debra H. Kennoy*	Sunil Nanjundaram	David Wilson*

* Denotes members of voting status when the document was approved for publication.

ASHRAE STANDARDS COMMITTEE 2006–2007

David E. Knebel, <i>Chair</i>	James D. Lutz
Stephen D. Kennedy, <i>Vice-Chair</i>	Carol E. Marriott
Michael F. Beda	Merle F. McBride
Donald L. Brandt	Mark P. Modera
Steven T. Bushby	Ross D. Montgomery
Paul W. Cabot	H. Michael Newman
Hugh F. Crowther	Stephen V. Santoro
Samuel D. Cummings, Jr.	Lawrence J. Schoen
Robert G. Doerr	Stephen V. Skalko
Roger L. Hedrick	Bodh R. Subherwal
John F. Hogan	Jerry W. White, Jr.
Eli P. Howard, III	James E. Woods
Frank E. Jakob	Richard D. Hermans, <i>BOD ExO</i>
Jay A. Kohler	Hugh D. McMillan, III, <i>CO</i>

Claire B. Ramspeck, *Assistant Director of Technology for Standards and Special Projects*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This addendum updates the Addendum 34u-2004 text and tables based on an increased ODL from 69,100 ppm to 140,000 ppm; increased cardiac sensitization default from 0 to 1000 ppm; new toxicity information for R-22, 32, and 227ea; new LFL values; and the addition of new refrigerants.

Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and strikethrough (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum v to 34-2004

7. REFRIGERANT CONCENTRATION LIMIT (RCL)

7.1 Single-Compound Refrigerants. The RCL for each refrigerant shall be the lowest of the quantities calculated in accordance with 7.1.1, 7.1.2, and 7.1.3, using data as indicated in 7.3 and adjusted in accordance with 7.4. Determination shall assume full vaporization; no removal by ventilation, dissolution, reaction, or decomposition; and complete mixing of the refrigerant in the space to which it is released.

7.1.1 Acute-Toxicity Exposure Limit (ATEL). The ATEL shall be the lowest of items (a)-(d) as follows:

- a. **Mortality:** 28.3% of the 4-hour LC₅₀ for rats. If not determined, 28.3% of the 4-hour ALC for rats. If neither has been determined, 0 ppm. The following equations shall be used to adjust LC₅₀ or ALC values that were

determined with 15-minute to 8-hour tests, for refrigerants for which 4-hour test data are not available:

$$LC_{50 \text{ for } T} = LC_{50 \text{ for } t} \cdot (t/T)^{1/2}$$

or

$$ALC_T = ALC_t \cdot (t/T)^{1/2}$$

where

T = 4 hours and

t = the test duration expressed in hours, 0.25–8

- b. **Cardiac Sensitization:** 100% of the NOEL for cardiac sensitization in unanesthetized dogs. If not determined, 80% of the LOEL for cardiac sensitization in dogs. If neither has been determined, ~~0~~1000 ppm. The cardiac sensitization term is omitted from ATEL determination if the LC₅₀ or ALC in (a) is less than 10,000 ppm by volume or if the refrigerant is found, by toxicological review, to not cause cardiac sensitization.
- c. **Anesthetic or Central Nervous System Effects:** 50% of the 10-minute EC₅₀ in mice or rats for loss of righting ability in a rotating apparatus. If not determined, 50% of the LOEL for signs of any anesthetic or CNS effect in rats during acute toxicity studies. If neither has been determined, 80% of the NOEL for signs of any anesthetic or CNS effect in rats during an acute, subchronic, or chronic toxicity study in which clinical signs are documented.
- d. **Other Escape-Impairing Effects and Permanent Injury:** 80% of the lowest concentration, for human exposures of 30 minutes, that is likely to impair ability to escape or to cause irreversible health effects.

7.1.2 Oxygen Deprivation Limit (ODL). The ODL shall be ~~69,100~~140,000 ppm by volume for locations with altitudes at and below 1000 meters (3300 feet) above sea level. At locations with altitudes greater than 1000 meters (3300 feet) above sea level, the ODL shall be 69,100 ppm.

7.1.3 Flammable Concentration Limit (FCL). The FCL shall be calculated as 25% of the LFL determined in accordance with 6.1.3.

TABLE 1 Refrigerant Data and Safety Classifications

Refrigerant Number	Chemical Name ^{a,b}	Chemical Formula ^a	Safety Group	RCL ^c		
				(ppm v/v)	(g/m ³)	(lb/Mcf)
Methane Series						
11	trichlorofluoromethane	CCl ₃ F	A1	1100	6.2	0.39
12	dichlorodifluoromethane	CCl ₂ F ₂	A1	18000	90	5.6
12B1	bromochlorodifluoromethane	CBrClF ₂				
13	chlorotrifluoromethane	CClF ₃	A1			
13B1	bromotrifluoromethane	CBrF ₃	A1			
14 ^{d,e}	tetrafluoromethane (carbon tetrafluoride)	CF ₄	A1	69000 110000	250 400	16 25
21	dichlorofluoromethane	CHCl ₂ F	B1			

TABLE 1 Refrigerant Data and Safety Classifications (Continued)

Refrigerant Number	Chemical Name ^{a,b}	Chemical Formula ^a	Safety Group	RCL ^c		
				(ppm v/v)	(g/m ³)	(lb/Mcf)
22	chlorodifluoromethane	CHClF ₂	A1	25000 <u>59000</u>	89 <u>210</u>	5.5 <u>13</u>
23	trifluoromethane	CHF ₃	A1	41000	120	7.3
30	dichloromethane (methylene chloride)	CH ₂ Cl ₂	B2			
31	chlorofluoromethane	CH ₂ ClF				
32	difluoromethane (methylene fluoride)	CH ₂ F ₂	A2	32000 <u>36000</u>	68 <u>77</u>	4.2 <u>4.8</u>
40	chloromethane (methyl chloride)	CH ₃ Cl	B2			
41	fluoromethane (methyl fluoride)	CH ₃ F				
50	methane	CH ₄	A3			
Ethane Series						
113	1,1,2-trichloro-1,1,2,2-trifluoroethane	CCl₂FC <u>CCl₂FC</u> ClF₂CClF₂ <u>ClF₂CClF₂</u>	A1	2,600	20	1.2
114	1,2-dichloro-1,1,2,2-tetrafluoroethane	CClF₂CClF₂ CClF₂CClF₂	A1	20000	140	8.7
115 ^{d,e}	chloropentafluoroethane	CClF₂CF₃ CClF₂CF₃	A1	69000 <u>120000</u>	440 <u>760</u>	27 <u>47</u>
116 ^e	hexafluoroethane	CF ₃ CF ₃	A1	69000 <u>97000</u>	390 <u>550</u>	24 <u>34</u>
123	2,2-dichloro-1,1,1-trifluoroethane	CHCl₂CF₃ CHCl₂CF₃	B1	9100	57	3.5
124	2-chloro-1,1,1,2-tetrafluoroethane	CHClFCF₃ CHClFCF₃	A1	10000	56	3.5
125 ^e	pentafluoroethane	CHF ₂ CF ₃	A1	69000 <u>75000</u>	340 <u>370</u>	21 <u>23</u>
134a	1,1,1,2-tetrafluoroethane	CH₂FCF₃* CH₂FCF₃	A1	50000	210	13
141b	1,1-dichloro-1-fluoroethane	CH₃CCl₂F* CH₃CCl₂F		2600	12	0.78
142b	1-chloro-1,1-difluoroethane	CH₃CClF₂* CH₃CClF₂	A2	15000 <u>20000</u>	62 <u>83</u>	3.9 <u>5.1</u>
143a	1,1,1-trifluoroethane	CH₃CF₃* CH₃CF₃	A2	18000 <u>21000</u>	60 <u>70</u>	3.8 <u>4.5</u>
152a	1,1-difluoroethane	CH₃CHF₂* CH₃CHF₂	A2	9300 <u>12000</u>	25 <u>32</u>	1.6 <u>2.0</u>
Ethers						
170 ^d	ethane	CH ₃ CH ₃	A3	7000	8.7	0.54
E170	dimethyl ether	CH ₃ OCH ₃	A3	8500	16	1.0
Propane Series						
218 ^e	octafluoropropane	CF ₃ CF ₂ CF ₃	A1	69000 <u>90000</u>	530 <u>690</u>	33 <u>43</u>
<u>227ea^e</u>	<u>1,1,1,2,3,3,3-heptafluoropropane</u>	<u>CF₃CHFCE₃</u>	<u>A1</u>	<u>84000</u>	<u>580</u>	<u>36</u>
236fa	1,1,1,3,3,3-hexafluoropropane	CF ₃ CH ₂ CF ₃	A1	55000	340	21
245fa	1,1,1,3,3-pentafluoropropane	CF₃CH₂CHF₂ CHF₂CH₂CF₃	B1 ^{e,d}	34000	190	12
290	propane	CH ₃ CH ₂ CH ₃	A3	5000 <u>5300</u>	9.0 <u>9.5</u>	0.56

TABLE 1 Refrigerant Data and Safety Classifications (Continued)

Refrigerant Number	Chemical Name ^{a,b}	Chemical Formula ^a	Safety Group	RCL ^c		
				(ppm v/v)	(g/m ³)	(lb/Mcf)
Cyclic Organic Compounds						
C318 ^d	octafluorocyclobutane	(CF₂)₄ * -(CF₂)₄-		69000	570	35
Miscellaneous Organic Compounds						
<i>Hydrocarbons</i>						
600	butane	CH ₃ CH ₂ CH ₂ CH ₃	A3	1000	2.4	0.1
600a	isobutane	CH(CH₃)₂CH₃ * CH(CH ₃) ₂ CH ₃	A3	2500 <u>4000</u>	6.0 <u>9.6</u>	0.37 <u>0.6</u>
<u>601</u>	<u>Pentane</u>	<u>CH₃CH₂CH₂CH₂CH₃</u>				
<u>601a</u>	<u>Isopentane</u>	<u>CH(CH₃)₂CH₂CH₃</u>	<u>A3</u>	<u>1000</u>	<u>2.9</u>	<u>0.2</u>
<i>Oxygen Compounds</i>						
610	ethyl ether	CH₃CH₂OCH₂CH₃ * CH ₃ CH ₂ OCH ₂ CH ₃				
611	methyl formate	HCOOCH ₃	B2			
<i>Sulfur Compounds</i>						
620	(Reserved for future assignment)					
Nitrogen Compounds						
630	methyl amine	CH ₃ NH ₂				
631	ethyl amine	CH₃CH₂(NH₂) * CH ₃ CH ₂ (NH ₂)				
Inorganic Compounds						
702	hydrogen	H ₂	A3			
704	helium	He	A1			
717	ammonia	NH ₃	B2	320	0.22	0.014
718	water	H ₂ O	A1			
720	neon	Ne	A1			
728	nitrogen	N ₂	A1			
732	oxygen	O ₂				
740	argon	Ar	A1			
744	carbon dioxide	CO ₂	A1	40000	72	4.5
744A	nitrous oxide	N ₂ O				
764	sulfur dioxide	SO ₂	B1			
Unsaturated Organic Compounds						
1150	ethene (ethylene)	CH ₂ =CH ₂	A3			
1270 ^d	propene (propylene)	CH ₃ CH=CH ₂	A3	<u>1000</u>	<u>1.7</u>	<u>0.1</u>

^a The chemical name and chemical formula are not part of this standard.

^b The preferred chemical name is followed by the popular name in parentheses.

^c Data taken from J.M. Calm, "ARTI Refrigerant Database," Air- Conditioning and Refrigeration Technology Institute (ARTI), Arlington, VA, July 2001; J.M. Calm, "Toxicity Data to Determine Refrigerant Concentration Limits," Report DE/CE 23810-110, Air- Conditioning and Refrigeration Technology Institute (ARTI), Arlington, VA, September 2000; J.M. Calm, "The Toxicity of Refrigerants," *Proceedings of the 1996 International Refrigeration Conference*, Purdue University, West Lafayette, IN, pp. 157-62, 1996; D.P. Wilson and R.G. Richard, "Determination of Refrigerant Lower Flammability Limits (LFLs) in Compliance with Proposed Addendum p to ANSI/ASHRAE Standard 34-1992 (1073-RP)," *ASHRAE Transactions* 2002, 108(2); D.W. Coombs, "HFC-32 Assessment of Anesthetic Potency in Mice by Inhalation," Huntingdon Life Sciences Ltd., Huntingdon, Cambridgeshire, England, February 2004 and amendment February 2006; D.W. Coombs, "HFC-22 An Inhalation Study to Investigate the Cardiac Sensitization Potential in the Beagle Dog," Huntingdon Life Sciences Ltd., Huntingdon, Cambridgeshire, England, August 2005; and other toxicity studies.

^d The RCL values for these refrigerants are provisional based on data found in searches for other refrigerants, but not fully examined.

^e At locations with altitudes greater than 1000 meters (3300 feet) above sea level, the ODL and RCL shall be 69,100 ppm.

TABLE 2 Data and Safety Classifications for Refrigerant Blends

Zeotropes					
Refrigerant Number	Composition (Mass %)	Safety Group	RCL ^a		
			(ppm v/v)	(g/m ³)	(lb/Mcf)
400	R-12/114 (must be specified)	A1			
	(50.0/50.0)	A1	28000	160	10
	(60.0/40.0)	A1	26000 <u>30000</u>	150 <u>170</u>	9.3 <u>11</u>
401A	R-22/152a/124 (53.0/13.0/34.0) ^e	A1	20000	77	4.8
			<u>27000</u>	<u>110</u>	<u>6.6</u>
401B	R-22/152a/124 (61.0/11.0/28.0) ^e	A1	21000	79	4.9
			<u>30000</u>	<u>120</u>	<u>7.2</u>
401C	R-22/152a/124 (33.0/15.0/52.0) ^e	A1	17000	71	4.4
			<u>20000</u>	<u>84</u>	<u>5.2</u>
402A	R-125/290/22 (60.0/2.0/38.0) ^f	A1	39000	160	10
			<u>33000</u>	<u>140</u>	<u>8.5</u>
402B	R-125/290/22 (38.0/2.0/60.0) ^f	A1	32000	120	7.8
			<u>63000</u>	<u>240</u>	<u>15</u>
403A	R-290/22/218 (5.0/75.0/20.0) ^g	A1	29000	110	6.9
			<u>33000</u>	<u>120</u>	<u>7.6</u>
403B ^v	R-290/22/218 (5.0/56.0/39.0) ^g	A1	34000	140	8.9
			<u>70000</u>	<u>290</u>	<u>18</u>
404A ^v	R-125/143a/134a (44.0/52.0/4.0) ^f	A1	69000	280	17
			<u>130000</u>	<u>500</u>	<u>31</u>
405A ^t	R-22/152a/142b/C318 (45.0/7.0/5.5/42.5) ^h		32000	150	9.2
			<u>57000</u>	<u>260</u>	<u>16</u>
406A	R-22/600a/142b (55.0/4.0/41.0) ⁱ	A2	25000	92	5.7
			<u>21000</u>	<u>25</u>	<u>4.7</u>
407A ^v	R-32/125/134a (20.0/40.0/40.0) ^o	A1	69000	260	16
			<u>78000</u>	<u>290</u>	<u>18</u>
407B ^v	R-32/125/134a (10.0/70.0/20.0) ^o	A1	69000	290	18
			<u>77000</u>	<u>320</u>	<u>20</u>
407C ^v	R-32/125/134a (23.0/25.0/52.0) ^o	A1	69000	240	15
			<u>76000</u>	<u>270</u>	<u>17</u>
407D	R-32/125/134a (15.0/15.0/70.0) ^o	A1	65000	240	15
407E ^v	R-32/125/134a (25.0/15.0/60.0) ^f	A1	69000	240	15
			<u>75000</u>	<u>260</u>	<u>16</u>
408A ^v	R-125/143a/22 (7.0/46.0/47.0) ^f	A1	47000	170	10
			<u>95000</u>	<u>340</u>	<u>21</u>
409A	R-22/124/142b (60.0/25.0/15.0) ^k	A1	20000	79	4.9
			<u>29000</u>	<u>110</u>	<u>7.1</u>
409B	R-22/124/142b (65.0/25.0/10.0) ^k	A1	20000	78	4.9
			<u>30000</u>	<u>120</u>	<u>7.3</u>
410A ^v	R-32/125 (50.0/50.0) ^l	A1	55000	160	10
			<u>130000</u>	<u>390</u>	<u>25</u>
410B ^v	R-32/125 (45.0/55.0) ⁿ	A1	58000	180	11
			<u>130000</u>	<u>390</u>	<u>24</u>
411A ^u	R-1270/22/152a (1.5/87.5/11.0) ^m	A2	26000	86	5.4
			<u>14000</u>	<u>46</u>	<u>2.9</u>

TABLE 2 Data and Safety Classifications for Refrigerant Blends (Continued)

Refrigerant Number	Composition (Mass %)	Safety Group	RCL ^a		
			(ppm v/v)	(g/m ³)	(lb/Mcf)
411B ^u	R-1270/22/152a (3.0/94.0/3.0) ^m	A2	23000 13000	80 45	5.0 2.8
412A	R-22/218/143b (70.0/5.0/25.0) ^k	A2	26000 22000	97 82	6.0 5.1
413A	R-218/134a/600a (9.0/88.0/3.0) ^q	A2	49000 22000	210 94	13 5.8
414A	R-22/124/600a/142b (51.0/28.5/4.0/16.5) ^s	A1	19000 26000	76 100	4.8 6.4
414B	R-22/124/600a/142b (50.0/39.0/1.5/9.5) ^s	A1	18000 23000	73 95	4.5 6.0
<u>415A</u>	<u>R-22/152a (82.0/18.0)</u>	<u>A2</u>	<u>57000</u>	<u>190</u>	<u>12</u>
<u>415B</u>	<u>R-22/152a (25.0/75.0)</u>	<u>A2</u>	<u>52000</u>	<u>120</u>	<u>9.3</u>
416A ^{tu}	R-134a/124/600 (59.0/39.5/1.5)	A1	21000 14000	96 62	6.0 3.9
417A ^{tu}	R-125/134a/600 (46.6/50.0/3.4)	A1	45000 13000	200 56	12 3.5
<u>418A</u>	<u>R-290/22/152a (1.5/96.0/2.5)</u>	<u>A2</u>	<u>59000</u>	<u>200</u>	<u>13</u>
<u>419A^v</u>	<u>R-125/134a/E170 (77.0/19.0/4.0)</u>	<u>A2</u>	<u>70000</u>	<u>310</u>	<u>19</u>
<u>420A</u>	<u>R-134a/142b (88.0/12.0)</u>	<u>A1</u>	<u>45000</u>	<u>190</u>	<u>12</u>
<u>421A</u>	<u>R-125/134a (58.0/42.0)</u>	<u>A1</u>	<u>61000</u>	<u>280</u>	<u>17</u>
<u>421B</u>	<u>R-125/134a (85.0/15.0)</u>	<u>A1</u>	<u>69000</u>	<u>330</u>	<u>21</u>
<u>422A</u>	<u>R-125/134a/600a (85.1/11.5/3.4)</u>	<u>A1</u>	<u>63000</u>	<u>290</u>	<u>18</u>
<u>422B</u>	<u>R-125/134a/600a (55.0/42.0/3.0)</u>	<u>A1</u>	<u>56000</u>	<u>250</u>	<u>16</u>
<u>422C</u>	<u>R-125/134a/600a (82.0/15.0/3.0)</u>	<u>A1</u>	<u>62000</u>	<u>290</u>	<u>18</u>
<u>422D</u>	<u>R-125/134a/600a (65.1/31.5/3.4)</u>	<u>A1</u>	<u>58000</u>	<u>260</u>	<u>16</u>
<u>423A</u>	<u>134a/227ea (52.5/47.5)</u>	<u>A1</u>	<u>59000</u>	<u>310</u>	<u>19</u>
<u>424A^{tu}</u>	<u>R-125/134a/600a/600/601a (50.5/47.0/0.9/1.0/0.6)</u>	<u>A1</u>	<u>23000</u>	<u>100</u>	<u>6.2</u>
<u>425A</u>	<u>R-32/134a/227ea (18.5/69.5/12)</u>	<u>A1</u>	<u>67000</u>	<u>250</u>	<u>16</u>
<u>426A^{tu}</u>	<u>R-125/134a/600/601a (5.1/93.0/1.3/0.6)</u>	<u>A1</u>	<u>20000</u>	<u>83</u>	<u>5.2</u>

Azeotropes^b

Refrigerant Number	Composition (Mass %)	Safety Group	RCL ^a		
			(ppm v/v)	(g/m ³)	(lb/Mcf)
500	R-12/152a (73.8/26.2)	A1	29000 30000	120	7.4 7.6
501	R-22/12 (75.0/25.0) ^c	A1	27000 54000	100 210	6.4 13
502	R-22/115 (48.8/51.2)	A1	35000 73000	160 330	10 21
503	R-23/13 (40.1/59.9)				
504 ^{iv}	R-32/115 (48.2/51.8)		41000 140000	130 460	8.4 29
505	R-12/31 (78.0/22.0) ^c				
506	R-31/114 (55.1/44.9)				

TABLE 2 Data and Safety Classifications for Refrigerant Blends (Continued)

Refrigerant Number	Composition (Mass %)	Safety Group	RCL ^a		
			(ppm v/v)	(g/m ³)	(lb/Mcf)
507A ^y	R-125/143a (50.0/50.0)	A1	69000	280	17
			130000	520	32
508A	R-23/116 (39.0/61.0)	A1	55000	220	14
508B	R-23/116 (46.0/54.0)	A1	52000	200	13
509A ^y	R-22/218 (44.0/56.0)	A1	38000	190	12
			75000	390	24

^a Data taken from J.M. Calm, "ARTI Refrigerant Database," Air-Conditioning and Refrigeration Technology Institute (ARTI), Arlington, VA, July 2001; J.M. Calm, "Toxicity Data to Determine Refrigerant Concentration Limits," Report DE/CE 23810-110, Air-Conditioning and Refrigeration Technology Institute (ARTI), Arlington, VA, September 2000; J.M. Calm, "The Toxicity of Refrigerants," *Proceedings of the 1996 International Refrigeration Conference*, Purdue University, West Lafayette, IN, pp. 157-62, 1996; D.P. Wilson and R.G. Richard, "Determination of Refrigerant Lower Flammability Limits (LFLs) in Compliance with Proposed Addendum p to ANSI/ASHRAE Standard 34-1992 (1073-RP)," *ASHRAE Transactions* 2002, 108(2); D.W. Coombs, "HFC-32 Assessment of Anesthetic Potency in Mice by Inhalation," Huntingdon Life Sciences Ltd., Huntingdon, Cambridgeshire, England, February 2004 and amendment February 2006; D.W. Coombs, "HFC-22 An Inhalation Study to Investigate the Cardiac Sensitization Potential in the Beagle Dog," Huntingdon Life Sciences Ltd., Huntingdon, Cambridgeshire, England, August 2005; and other toxicity studies.

^b Azeotropic refrigerants exhibit some segregation of components at conditions of temperature and pressure other than those at which they were formulated. The extent of segregation depends on the particular azeotrope and hardware system configuration.

^c The exact composition of this azeotrope is in question, and additional experimental studies are needed.

^e Composition tolerances are (±2.0/+0.5, -1.5/±1.0).

^f Composition tolerances are (±2.0/±1.0/±2.0).

^g Composition tolerances are (+0.2, -2.0/±2.0/±2.0).

^h Composition tolerances for the individual components are (±2.0/±1.0/±1.0/±2.0) and for the sum of R-152a and R-142b are (+0.0, -2.0).

ⁱ Composition tolerances are (±2.0/±1.0/±1.0).

^k Composition tolerances are (±2.0/±2.0/±1.0).

^l Composition tolerances are (+0.5, -1.5/+1.5, -0.5).

^m Composition tolerances are (+0.0, -1.0/+2.0, -0.0/+0.0, -1.0).

ⁿ Composition tolerances are (±1.0/±1.0).

^o Composition tolerances are (±2.0/±2.0/±2.0).

^q Composition tolerances are (±1.0/±2.0/+0.0,-1.0).

^r Composition tolerances are (±2.0, ±2.0, ±2.0).

^s Composition tolerances are (±2.0, ±2.0, ±0.5/+0.5, -1.0).

^t The RCL values for these refrigerants are provisional based on data found in searches for other refrigerants, but not fully examined.

^u The RCL values for these refrigerant blends are approximated in the absence of adequate data for a component comprising less than 4% m/m of the blend and expected to have only a small influence in an acute, accidental release.

^y At locations with altitudes greater than 1000 meters (3300 feet) above sea level, the ODL and RCL shall be 69,100 ppm.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This addendum adds an informative appendix containing toxicity values for single-compound refrigerants.

Addendum w to 34-2004

8. REFRIGERANT CLASSIFICATIONS

Refrigerants are assigned the classifications indicated in Tables 1 and 2. Toxicity and flammability data used to determine RCL values are summarized in Appendix E.

TABLE E1 Toxicity Table for Standard 34—ATEL, ODL, FCL and RCL Values Single-Compound Refrigerants^a (ppm v/v)

Refrigerant R-	Chemical Name	Cardiac Sensitization				Anesthesia		Other ⁱ	ATEL	ODL	FCL	RCL	LFL	ATEL Source	RCL Source
		LC ₅₀ ^{c,d}	LOEL ^e	NOEL ^e	EC ₅₀ ^f	LOEL ^g	NOEL ^h								
11	trichlorofluoromethane	26,200	4,800	1,100	35,000	ND	12,500	ND	1,100	140,000	NA	1,100	—	100% Cardiac NOEL	ATEL
12	dichlorodifluoromethane	>800,000	50,000	40,000	250,000	ND	200,000	22,700	22,000	140,000	NA	22,000	—	Other	ATEL
14	tetrafluoromethane	>390,000	ND	200,000	ND	ND	226,000	ND	110,000	140,000	NA	110,000	—	28.8% LC ₅₀	ATEL
22	chlorodifluoromethane	220,000	50,000	59,300 ^k	140,000	ND	ND	ND	59,000	140,000	NA	59,000	—	100% Cardiac NOEL	ATEL
23	trifluoromethane	>663,000	ND	800,000	ND	ND	51,000	ND	41,000	140,000	NA	41,000	—	80% Anesthesia NOEL	ATEL
32	difluoromethane (methylene fluoride)	>760,000	250,000	200,000	ND	ND	250,000	ND	200,000	140,000	36,000	36,000	144,000	80% Anesthesia NOEL	25% LFL
113	1,1,2-trichloro-1,2,2-trifluoroethane	52,500	4,850	2,600	28,000	ND	25,000	ND	2,600	140,000	NA	2,600	—	100% Cardiac NOEL	ATEL
114	1,2-dichloro-1,1,2,2-tetrafluoroethane	255,000 ^j	25,000	ND	250,000	ND	100,000	ND	20,000	140,000	NA	20,000	—	80% Cardiac LOEL	ATEL
115	chloropentafluoroethane	>800,000	150,000	ND	ND	ND	800,000	ND	120,000	140,000	NA	120,000	—	80% Cardiac LOEL	ATEL
116	hexafluoroethane	>800,000	ND	200,000	ND	ND	121,000	ND	97,000	140,000	NA	97,000	—	80% Anesthesia NOEL	ATEL
123	2,2-dichloro-1,1,1-trifluoroethane	32,000	ND	10,300	27,000	ND	2,500	ND	9,100	140,000	NA	9,100	—	28.8% LC ₅₀	ATEL
124	2-chloro-1,1,1,2-tetrafluoroethane	263,000	25,000	10,100	150,000	ND	48,000	ND	10,000	140,000	NA	10,000	—	100% Cardiac NOEL	ATEL
125	pentafluoroethane	>769,000	100,000	75,000	ND	ND	709,000	ND	75,000	140,000	NA	75,000	—	100% Cardiac NOEL	ODL
134a	1,1,1,2-tetrafluoroethane	>359,000 ^l	75,200	49,800	270,000	ND	81,000	ND	50,000	140,000	NA	50,000	—	100% Cardiac NOEL	ATEL
141b	1,1-dichloro-1-fluoroethane	61,600	5,200	2,600	25,000	29,000	20,000	ND	2,600	140,000	15,000	2,600	60,000	100% Cardiac NOEL	ATEL
142b	1-chloro-1,1-difluoroethane	106,000 ^d	50,000	25,000	250,000	ND	591,000	ND	25,000	140,000	20,000	20,000	80,000	100% Cardiac NOEL	25% LFL
143a	1,1,1-trifluoroethane	>591,000	300,000	250,000	500,000	ND	24,800	ND	170,000	140,000	21,000	21,000	82,000	28.3% LC ₅₀	25% LFL
152a	1,1-difluoroethane	400,000 ^d	150,000	50,000	ND	ND	100,000	500,000	50,000	140,000	12,000	12,000	48,000	100% Cardiac NOEL	25% LFL
170	ethane	>24,800	100,000	ND	ND	ND	ND	ND	7,000	140,000	7,700	7,000	31,000	28.3% LC ₅₀	ATEL
E170	Dimethyl ether	164,000	200,000	100,000	ND	84,000	ND	ND	42,000	140,000	8,500	8,500	34,000	50% Anesthesia LOEL	25% LFL

TABLE E1 Toxicity Table for Standard 34—ATEL, ODL, FCL and RCL Values Single-Compound Refrigerants^a (ppm v/v)

Refrigerant R-	Chemical Name	Cardiac Sensitization			Anesthesia		Other ^j	ATEL	ODL	FCL	RCL	LFL	ATEL Source	RCL Source
		LC ₅₀ ^{c, d}	LOEL ^e	NOEL ^e	EC ₅₀ ^f	LOEL ^g								
218	octafluoropropane	>400,000 ^{d, m}	400,000	300,000	ND	ND	113,000	ND	140,000	NA	90,000	—	80% Anesthesia NOEL	ATEL
227ea	1,1,1,2,3,3,3-heptafluoropropane	>788,696	105,000	90,000	ND	ND	105,000	ND	140,000	NA	84,000	—	80% Anesthesia NOEL	ATEL
236fa	1,1,1,3,3,3-hexafluoropropane	>457,000	150,000	100,000	110,000	ND	20,000	ND	140,000	NA	55,000	—	80% Anesthesia EC ₅₀	ODL
245fa	1,1,1,3,3-pentafluoropropane	>203,000	44,000	34,100	ND	ND	50,600	ND	140,000	NA	34,000	—	100% Cardiac NOEL	ATEL
290	propane	>200,000 ⁿ	100,000	50,000	280,000	ND	ND	ND	140,000	5,300	5,300	21,000	100% Cardiac NOEL	25% LFL
C318	octafluorocyclobutane	>800,000	100,000	ND	>800,000	ND	800,000	ND	140,000	NA	80,000	—	80% Cardiac LOEL	ATEL
600	butane	272,000	ND	ND	ND	ND	ND	100,000	140,000	5,000	1,000	20,000	Sect 7.1.1 (b)	ATEL
600a	isobutane	143,000 ^o	50,000	25,000	200,000	10,000	ND	ND	140,000	4,000	4,000	16,000	100% Cardiac NOEL	25% LFL
601a	isopentane	434,000	ND	ND	ND	120,000	ND	ND	140,000	3300	3300	13,000	Sect 7.1.1 (b)	ATEL
717	ammonia	3,300 ^d	ND	-p-	ND	-p-	38,900	400	140,000	42,000	320	167,000	Other	ATEL
744	carbon dioxide	-s-	ND	-p-	ND	-p-	ND	50,000 ^r	140,000	NA	40,000	—	NIOSH IDLH	ATEL
1270	propene (propylene)	>490,000 ^t	ND	ND	ND	ND	10,000	7,200	140,000	6,700	1,000	27,000	Sect 7.1.1 (b)	ATEL

ND: None Determined or Not Adequately Defined according to criteria of this standard.

NA: Not Applicable.

Note: The data shown in this table are rounded to three significant digits to avoid suggestion of artificial precision, but actual calculations used the data as published or converted to avoid propagation of errors in calculations, especially for blends. The ATEL and RCL concentrations are rounded to two significant figures.

^a Data taken from J.M. Calm, "ARTI Refrigerant Database," Air- Conditioning and Refrigeration Technology Institute (ARTI), Arlington, VA, July 2001; J.M. Calm, "Toxicity Data to Determine Refrigerant Concentration Limits," Report DE/CE 23810-110, Air- Conditioning and Refrigeration Technology Institute (ARTI), Arlington, VA, September 2000; J.M. Calm, "The Toxicity of Refrigerants," *Proceedings of the 1996 International Refrigeration Conference*, Purdue University, West Lafayette, IN, pp. 157-62, 1996; D.P. Wilson and R.G. Richard, "Determination of Refrigerant Lower Flammability Limits (LFLs) in Compliance with Proposed Addendum p to ANSI/ASHRAE Standard 34-1992 (1073-RP)," *ASHRAE Transactions* 2002, 108(2); D.W. Coombs, "HFC-32 Assessment of Anesthetic Potency in Mice by Inhalation," Huntingdon Life Sciences Ltd., Huntingdon, Cambridgeshire, England, February 2004 and amendment February 2006; D.W. Coombs, "HFC-22 An Inhalation Study to Investigate the Cardiac Sensitization Potential in the Beagle Dog," Huntingdon Life Sciences Ltd., Huntingdon, Cambridgeshire, England, August 2005; and other toxicity studies.

^b From ANSI/ASHRAE Standard 34-2004 and subsequent published addenda.

^c 4-hr LC₅₀ rat used for mortality indicator; some federal and fire code toxicity classifications are based on a 1-hr LC₅₀ rat.

^d 4-hr approximate lethal concentration (ALC) rat used for mortality indicator; LC₅₀ not determined.

^e Dog with epinephrine injection.

^f 10-min EC₅₀, mouse or rat.

^g Lowest anesthetic/CNS LOEL rat during ALC, LC₅₀, or other acute toxicity study.

^h Highest anesthetic/CNS NOEL rat in any toxicity study not exceeding an acute LOEL.

ⁱ Other escape-impairing or permanently injuring effects, including severe sensory irritation, for short exposures.

^j R-114 30-min LC₅₀ rat - 720,000 ppm v/v, 2-hr LC₅₀ rat > 600,000 ppm v/v.

^k Not used.

^l R-134a LC₀ substituted for ALC; > 50% of animals died at ALC of 566,700 ppm v/v.

^m R-218 1-hr ALC rat > 800,000 ppm v/v.

ⁿ R-290 15-min LC₅₀ rat > 800,000 ppm v/v.

^o R-600a 15-min LC₅₀ rat = 570,000 ppm v/v; anesthetic/CNS value is a 17-min EC₅₀ mouse.

^p No data, but believed to exceed LC₅₀ and ALC.

^q Published LC₅₀ values - 6,586-19,671 ppm v/v for 1 hr and 2,000-4,067 for 4 hr; conversion of the lowest 1-hr LC₅₀ rat to 4-hr yields 3,300, approximately the midpoint of the 4-hr values.

^r See NIOSH IDLH documentation for other effect.

^s R-744 treated as simple asphyxiant; 5-min LC_{Lo} human = 90,000 ppm v/v.

^t R-1270 6-hr ALC > 400,000 ppm v/v; cardiac sensitization in 2 of 2 dogs at 100,000 ppm; respiratory rate decrease in half of tested animals at 7,200 ppm v/v.

**POLICY STATEMENT DEFINING ASHRAE'S CONCERN
FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.