



ADDENDA

**ANSI/ASHRAE Addendum c to
ANSI/ASHRAE Standard 52.2-2012**

Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size

Approved by ASHRAE on July 1, 2015, and by the American National Standards Institute on July 28, 2015.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website (www.ashrae.org) or in paper form from the Senior Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2015 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 52.2
Cognizant TC: 2.4, Particulate Air Contaminants and Particulate Removal Equipment
SPLS Liaison: Patricia T. Graef

Michale D. Corbat,* <i>Chair</i>	Zied Driss*	Bruce N. McDonald*
Kathleen Owen,* <i>Vice-Chair</i>	Chris Fischer*	Stephen W. Nicholas*
Todd A. McGrath,* <i>Secretary</i>	Thomas A. Justice*	John S. Robertson*
Richard K. Chesson, Jr.*	Carolyn M. L. Kerr*	Christine Q. Sun*
Kyung-Ju Choi*	David Matier*	Paolo M. Tronville*
David B. Christopher*	Phil Maybee*	Alan C. Veeck*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2014–2015

Richard L. Hall, <i>Chair</i>	James W. Earley, Jr.	Mark P. Modera
Douglass T. Reindl, <i>Vice-Chair</i>	Steven J. Emmerich	Cyrus H. Nasser
Joseph R. Anderson	Patricia T. Graef	Heather L. Platt
James Dale Aswegan	Rita M. Harrold	Peter Simmonds
Charles S. Barnaby	Adam W. Hinge	Wayne H. Stoppelmoor, Jr.
Donald M. Brundage	Srinivas Katipamula	Jack H. Zarour
John A. Clark	Debra H. Kennoy	Julia A. Keen, <i>BOD ExO</i>
Waller S. Clements	Malcolm D. Knight	Bjarne Wilkens Olesen, <i>CO</i>
David R. Conover	Rick A. Larson	
John F. Dunlap	Arsen K. Melkov	

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE RP-1287 presented several recommendations related to particle counter specifications, and SSPC 52.2 reviewed the findings and incorporated a number of those recommendations into this addendum. In addition, input from several particle counter manufacturers was obtained to help ensure that the proposed recommendations are achievable and practical. These changes are to improve the reproducibility of the test. For that reason, the particle counter is limited to one class of counters, specifically light-scattering optical particle counters, which are currently in wide use. Additionally, stringent requirements on the particle counter's sizing resolution, calibration, sampling rate, and other performance factors are specified. This addendum intends to make the specifications sufficiently (but not excessively) stringent and comprehensive in order to provide significantly improved reproducibility.

Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striking through~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum c to Standard 52.2-2012

Add the following new definition to Section 3.1.

3.1 Definitions

aerosol particle counter (OPC): an instrument that samples, counts, and sizes aerosol particles. While several different technologies exist for aerosol particle counters (e.g., optical, aerodynamic, electrostatic mobility), only optical aerosol particle counters based on light scattering are used in this standard. Optical aerosol particle counters are often referred to as "OPCs" and, when the particles are sized into a number of sizing channels, are also sometimes referred to as "aerosol spectrometers."

Modify Section 4.6 as shown.

4.6 Particle Counter(s). The particle counter specifications consist of the following:

4.6.1 ~~Permissible particle counters are optical particle counters (OPCs) with wide angle collection optics or other counters demonstrating good correlation in measuring particle size efficiencies, such as aerodynamic particle counters (APCs).¹⁰ An APC shall first be tested with KCl to establish~~

10. An OPC determines particle size based on the intensity of the particle's scattered light. An APC determines particle size by measuring the time of flight of the particle.

~~the relationship between the aerodynamic particle size and the light-scattering particle size determined by an OPC. Calibrate the APC with PSL and use the relationship to express results as equivalent light-scattering size of KCl.~~

- a. Measurement technology
- b. Size range
- c. Counting efficiency
- d. Resolution of particle size measurement
- e. Number of sizing channels and their boundaries
- f. Degree of monotonic response required
- g. Calibration methods
- h. Sampling flow rate stability
- i. Zero-count specification
- j. Requirements when dual counters are used
- k. Sample flow rate measurement and recording

4.6.1 The aerosol particle counter shall be based on optical particle sizing and counting (i.e., light scattering). These instruments are commonly known as "optical particle counters" and also as "optical aerosol spectrometers."

4.6.2 ~~The particle counter(s) shall be capable of counting-count and sizing size individual KCl aerosol particles in the 0.30 to 10 μm diameter size range.~~

4.6.3 The counting efficiency shall be at least 50% for 0.3 μm NIST-traceable polystyrene latex (PSL) particles.

4.6.4 The sizing resolution of the particle counter shall be $\leq 10\%$ (standard deviation/mean) and shall be measured in accordance with ISO 21501-1, ISO 21501-4, IEST-RP-CC014.1, or equivalent. The resolution shall be measured at a particle size in the range of 0.5 to 0.7 μm .

4.6.5 ~~The particle counter(s) shall measure the test aerosol group measured particles and then group them into 12 size ranges. The range boundaries (based on the physical size of the KCl aerosol/PSL calibration) shall conform to Table 4-1.~~

4.6.6 The particle counter's correlation of measured response^{11,10} to physical particle size shall be monotonic for PSL particles from 0.30 to 10 μm , such that only one size range shall be indicated for any measured response (i.e., any lack on monotonic response must be such that the associated ambiguity in particle size is contained within one channel of the particle counter).

4.6.7 Particle counter calibration shall conform to the following:

- a. The OPC shall be calibrated in accordance with ISO 21501-4.
- b. The calibration shall be performed with monodisperse NIST-traceable PSL.
- c. The calibration shall include at least one particle diameter in each of the ranges of 0.3 to 0.4 μm , 9 to 11 μm , and 4 other sizes in between.
- d. The size calibration of the particle counter shall be to report the actual physical size of the PSL particles, and it shall be performed performed at least annually.

11,10. Voltage, for example.

4.6.5 At least 90% of all observed counts shall register in size ranges 4 and 5 of Table 4-1 when the particle counter is challenged with monodisperse 1.0 µm diameter PSL particles.

4.6.8 The particle counter shall have less than 10% coincidence loss at a particle counting rate of 300,000 particles per minute¹² and shall have a minimum inlet volume flow rate of 47.2 cm³/s (0.100 cfm). ~~This~~The inlet volume flow rate shall not change more than 2% with a 1000 Pa (4.0 in. ~~of water~~ wc) change in the pressure of the sampled air.

4.6.9 The total measured particle concentration count rate shall be ~~no more~~less than 20010 particles/m³ (5.66 particles/ft³) per minute when the particle counter is sampling air with a HEPA or ULPA high-efficiency filter on its intake.

4.6.10 Dual particle counters, if used, shall be identical models such that they are closely matched in design and sampling flow rate.

4.6.11 The viewed sample flow rate of the particle counter shall be recorded for each data sample.

Informative Note: Some particle counters incorporate measurement of the viewed sample flow rate within the instrument and provide that measurement as part of the data stream associated with each sample. If the particle counter does not provide this output, provisions need to be made to capture this information for each sample (such as adding a mass flowmeter on the outlet stream from the particle counter's sensor). For some particle counters, viewed sample flow rate can be significantly affected by duct pressure, which can change with flow rate; the resistance of the test filter (clean and with dust loading); and test duct setup (such as the diameter of the ASME flow nozzle and pressure drop of the outlet HEPA filter bank). Changes in flow rate through the particle counter sensor will directly change the particle count rate and lead to errors when computing the particle filtration efficiency values. Changes in flow rate may also influence the particle counter calibration.

In some cases, the influence of duct pressure can be significantly reduced by routing the exhaust of the particle counter back to the duct to equalize (or reduce) the differential pressure across the particle counter, by using a mass flow controller downstream of the particle counter's sensor, or by adding a controlled restriction in the exhaust line of the particle counter.

The viewed sample flow rate is that part of the sample stream that passes through the particle counter's sensor. In many particle counters, 100% of the sample flow flows through the sensor; in some counters and/or sampling systems, the viewed sample flow is a fraction of the total sampled flow (to allow isokinetic sampling, reduced residence time in sample line, etc.).

Add new qualifications to Section 5.1 as shown.

5. APPARATUS QUALIFICATION TESTING

12. The particle counting rate is the product of the particle concentration and the viewed volume flow. Example: 100 particles/mL · 3000 mL/min = 300,000 particles/min.

5.1 Apparatus qualification tests shall verify quantitatively that the test rig and sampling procedures are capable of providing reliable particle size efficiency measurements. The tests shall be performed in accordance with Table 5-1.

Qualification tests shall be performed for:

- Air velocity uniformity in the test duct
- Aerosol uniformity in the test duct
- Downstream mixing of aerosol
- Overload tests of the particle counter
- 100% efficiency test
- Correlation ratio test
- Aerosol generator response time
- Duct leakage test
- Particle counter zero
- Particle counter sizing accuracy
- Radioactivity of the aerosol neutralizer
- Dust feeder airflow rate
- Final filter efficiency
- OPC documentation
- OPC flow-rate stability test

Insert the following sections between current Sections 5.14 and 5.15.

5.15 OPC Documentation. Secure documentation from the particle counter manufacturer (or other source) that verifies that each specific particle counter requirement of Section 4.6 is being met.

5.16 OPC Flow Rate Stability Check

5.16.1 Install a flow restriction (such as an air filter or flow nozzle) in the test section of the test duct that will provide at least a 1000 Pa (4 in. wc) duct pressure difference between the upstream OPC sampling location and the downstream OPC sampling location when the duct is operated at a flow rate between 500 and 2000 cfm.

5.16.2 Operate the test duct at a flow rate that yields a 1000 Pa ± 10% (4.0 in. wc ± 10%) pressure differential between the upstream and downstream OPC sample locations.

5.16.3 Measure the sampled flow rate of the OPC when sampling upstream and when sampling downstream. If dual counters are used, measure the flow rate of each OPC.

5.16.4 The particle counter's viewed sample flow rate must be the instrument's specified flow rate ± 5%.

5.16.5 The difference between the upstream and downstream viewed sample flow rates must not exceed 2%.

Informative Note to Sections 5.16.4 and 5.16.5: Corrective action, if needed, may be to route the exhaust of the particle counter back to the duct to equalize the differential pressure across the particle counter; use of a mass flow controller downstream of the particle counter's sensor; or adding a controlled restriction in the exhaust line of the particle counter.

Modify Section 10.6.2 by adding the following.

10.6.2.5 Viewed Sample Volume. The particle counter's viewed sample flow rate must be the instrument's specified flow rate ± 5%.

Modify Section 10.6.4 as follows.

10.6.4.1 Viewed Sample Flowrate Consistency. The difference between the upstream and downstream viewed sample flow rates must not exceed 2%.

10.6.4.12

10.6.4.23

10.6.4.34

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

About ASHRAE

ASHRAE, founded in 1894, is a global society advancing human well-being through sustainable technology for the built environment. The Society and its members focus on building systems, energy efficiency, indoor air quality, refrigeration, and sustainability. Through research, Standards writing, publishing, certification and continuing education, ASHRAE shapes tomorrow's built environment today.

For more information or to become a member of ASHRAE, visit www.ashrae.org.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, on CD-ROM, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.