



ADDENDA

**ANSI/ASHRAE Addendum c to
ANSI/ASHRAE Standard 55-2010**

Thermal Environmental Conditions for Human Occupancy

Approved by the ASHRAE Standards Committee on January 21, 2012; by the ASHRAE Board of Directors on January 25, 2012; and by the American National Standards Institute on January 26, 2012.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site (www.ashrae.org) or in paper form from the Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE Web site (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2012 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 55
Cognizant TC: 2.1, Physiology and Human Environment
SPLS Liaison: Steven F. Bruning

Gwelen Paliaga, <i>Chair*</i>	Josh Eddy	Brian M. Lynch*
John L. Stoops, <i>Vice Chair*</i>	Yanzheng Guan*	Michael P. O'Rourke*
Sahar Abbaszadeh Fard, <i>Secretary*</i>	Thomas B. Hartman*	Abhijeet Pande*
Peter F. Alspach*	Daniel Int-Hout, III*	Julian Rimmer*
Edward A. Arens*	Michael A. Humphreys	Stefano Schiavon
Richard M. Aynsley*	Essam Eldin Khalil*	Lawrence J. Schoen*
Robert Bean*		Peter Simmonds*
Richard de Dear		Stephen C. Turner*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2011–2012

Carol E. Marriott, <i>Chair</i>	Krishnan Gowri	Janice C. Peterson
Kenneth W. Cooper, <i>Vice-Chair</i>	Maureen Grasso	Douglas T. Reindl
Douglass S. Abramson	Cecily M. Grzywacz	Boggarm S. Setty
Karim Amrane	Richard L. Hall	James R. Tauby
Charles S. Barnaby	Rita M. Harrold	James K. Vallort
Hoy R. Bohanon, Jr.	Adam W. Hinge	William F. Walter
Steven F. Bruning	Debra H. Kennoy	Michael W. Woodford
David R. Conover	Jay A. Kohler	Craig P. Wray
Steven J. Emmerich	Frank Myers	Eckhard A. Groll, <i>BOD ExO</i>
Allan B. Fraser		Ross D. Montgomery, <i>CO</i>

Stephanie C. Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This addendum represents an evolution of the description and definition of the average outdoor temperature to be used in the adaptive comfort model. The original term – monthly average – did not fully capture the methodology used in defining the adaptive approach nor was it clear in describing how to apply it. The change to prevailing mean as well as the addition of the daily outdoor temperature definition provides much clearer direction on the application of the adaptive comfort model. This addendum allows a range of options for calculating the prevailing mean outdoor air temperature to accommodate different sources of outdoor weather data and different comfort applications.

Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striking through~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum c to 55-2010

[Modify the following definition in Section 3:]

[The line added above $\overline{t_{a(out)}}$ was corrected in the latest published errata sheet for Standard 55-2010 available for free download from the ASHRAE website at <http://www.ashrae.org/technology/page/120>.]

temperature, prevailing mean ~~monthly~~ outdoor air ($t_{pma(out)}$): when used as input variable in Figure 5.3 for the adaptive model, this temperature is based on the arithmetic average of the ~~mean daily minimum and mean daily maximum outdoor (dry-bulb) temperatures for the month in question. over some period of days as permitted in Section 5.3.~~

[Add the following new definition to Section 3:]

temperature, mean daily outdoor air ($\overline{t_{mda(out)}}$): any arithmetic mean for a 24-hour period permitted in Section 5.3 of the standard. Mean daily outdoor air temperature is used to calculate prevailing mean outdoor air temperature.

[Modify the Section 5.3 as follows:]

[Proposed changes to Section 5.3 below include those changes from published Addendum a to Standard 55-2010 available for free download from the ASHRAE website at <http://www.ashrae.org/technology/page/132>.]

5.3 Optional Method for Determining Acceptable Thermal Conditions in Naturally Conditioned Spaces. For the purposes of this standard, occupant-controlled naturally conditioned spaces are those spaces where the thermal conditions of the space are regulated primarily by the occupants through

opening and closing of windows. Field experiments have shown that occupants' thermal responses in such spaces depend in part on the outdoor climate and may differ from thermal responses in buildings with centralized HVAC systems primarily because of the different thermal experiences, changes in clothing, availability of control, and shifts in occupant expectations. This optional method is intended for such spaces.

5.3.1 In order for this optional method to apply, the space in question must be equipped with operable windows that open to the outdoors and can be readily opened and adjusted by the occupants of the space. There must be no mechanical cooling system for the space (e.g., refrigerated air conditioning, radiant cooling, or desiccant cooling). It is permissible to use mechanical ventilation with unconditioned air, but opening and closing of windows must be the primary means of regulating the thermal conditions in the space. It is permissible for the space to be provided with a heating system, but this optional method does not apply when the heating system is in operation. It applies only to spaces where the occupants are engaged in near-sedentary physical activities, with metabolic rates ranging from 1.0 to 1.3 met. See Normative Appendix A for estimation of metabolic rates. This optional method applies only to spaces where the occupants are free to adapt their clothing to the indoor and/or outdoor thermal conditions.

5.3.2 For spaces that meet these criteria, ~~it is acceptable to~~ determine the allowable indoor operative temperatures from Figure 5.3 for any day in question using the prevailing mean outdoor air temperature determined in accordance with all of the following.

5.3.2.1 It shall be based on no fewer than 7 and no more than 30 sequential days prior to the day in question.

5.3.2.2 It shall be a simple arithmetic mean of all of the mean daily outdoor air temperatures of all the sequential days in Section 5.3.2.1.

Exception to 5.3.2.2: Weighting methods are permitted provided that the weighting curve continually decreases toward the more distant days such that the weight applied to a day is between 0.6 and 0.9 of that applied to the subsequent day. For this option, the upper limit on the number of days in the sequence does not apply.

5.3.2.3 Mean daily outdoor air temperature for each of the sequential days in Section 5.3.2.1 shall be the simple arithmetic mean of all the outdoor dry-bulb temperature observations for the 24-hour day. The quantity of measurements shall be no less than two and, in that case, shall be the minimum and maximum for the day. When using three or more measurements, the time periods shall be evenly spaced.

5.3.2.4 Observations in Section 5.3.2 shall be from the nearest approved meteorological station, public or private, or TMY (Typical Meteorological Year) weather file.

Exception to 5.3.2.1, 5.3.2.2, 5.3.2.3: When weather data to calculate the prevailing mean outdoor air temperature are not available, it is permitted to use as the prevailing mean the published meteorological monthly means for each calendar month. It is permitted to interpolate between monthly means.

5.3.3 This figure includes two sets of operative temperature limits—one for 80% acceptability and one for 90% acceptability. The 80% acceptability limits are for typical applications and shall be used when other information is not available. It is acceptable to use the 90% acceptability limits when a higher standard of thermal comfort is desired. Figure 5.3 is based on an adaptive model of thermal comfort that is derived from a global database of 21,000 measurements taken primarily in office buildings.

The equations corresponding to the acceptable operative temperature ranges in Figure 5.3 are:

$$\text{Upper 80\% acceptability limit (°C)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 21.3$$

$$\text{Upper 80\% acceptability limit (°F)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 60.5$$

$$\text{Upper 90\% acceptability limit (°C)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 20.3$$

$$\text{Upper 90\% acceptability limit (°F)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 58.7$$

$$\text{Lower 80\% acceptability limit (°C)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 14.3$$

$$\text{Lower 80\% acceptability limit (°F)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 47.9$$

$$\text{Lower 90\% acceptability limit (°C)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 15.3$$

$$\text{Lower 90\% acceptability limit (°F)} = 0.31 (\textit{prevailing mean outdoor-monthly-air temperature}) + 49.7$$

5.3.4 The allowable operative temperature limits in Figure 5.3 may not be extrapolated to outdoor temperatures above and below the end points of the curves in this figure. If the *prevailing mean monthly outdoor air temperature* is less than 10°C (50°F) or greater than 33.5°C (92.3°F), this option may not be used, and no specific guidance for naturally conditioned spaces is included in this standard.

Figure 5.3 accounts for local thermal discomfort effects in typical buildings, so it is not necessary to address these factors when using this option. If there is reason to believe that local thermal comfort is a problem, it is acceptable to apply the criteria in Section 5.2.4.

Figure 5.3 also accounts for people's clothing adaptation in naturally conditioned spaces by relating the acceptable range of indoor temperatures to the outdoor climate, so it is not necessary to estimate the clothing values for the space.


No humidity or air-speed limits are required when this option is used.

Figure 5.3 includes the effects of people's indoor air speed adaptation in warm climates, up to 0.3 m/s (59 fpm) in operative temperatures warmer than 25°C (77°F). In naturally conditioned spaces where air speeds within the occupied zone exceed 0.3 m/s (59 fpm), the upper acceptability temperature limits in Figure 5.3 are increased by the corresponding Δt_0 in Table 5.3, which is based on equal SET values as illustrated in Section 5.2.3.2. For example, increasing air speed within the occupied zone from 0.3 m/s (59 fpm) to 0.6 m/s (118 fpm) increases the upper acceptable temperature limits in Figure 5.3 by a Δt_0 of 1.2°C (2.2°F). These adjustments to the upper acceptability temperature limits apply only at $t_0 > 25^\circ\text{C}$ (77°F) in which the occupants are engaged in near-sedentary physical activity (with metabolic rates between 1.0 met and 1.3 met).

TABLE 5.3 Increases in Acceptable Operative Temperature Limits (Δt_0) in the Adaptive Comfort Standard (Figure 5.3) Resulting from Increasing Air Speed above 0.3 m/s (59 fpm)

Air Speed 0.6 m/s (118 fpm)	Air Speed 0.9 m/s (177 fpm)	Air Speed 1.2 m/s (236 fpm)
1.2°C (2.2°F)	1.8°C (3.2°F)	2.2°C (4.0°F)

[Change the horizontal axis of Figure 5.3 as follows:]



[Delete the following text from Section 5.4. The remainder of the text in Section 5.4 remains unchanged.]

~~**Mean monthly outdoor temperature** is the arithmetic average of the mean daily minimum and mean daily maximum outdoor (dry-bulb) temperature for the month in question.~~

**POLICY STATEMENT DEFINING ASHRAE'S CONCERN
FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

