



# ADDENDA

**ANSI/ASHRAE Addendum c to  
ANSI/ASHRAE Standard 62.1-2016**

# Ventilation for Acceptable Indoor Air Quality

Approved by the ASHRAE Standards Committee on June 23, 2018; by the ASHRAE Board of Directors on June 27, 2018; and by the American National Standards Institute on July 25, 2018.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or in paper form from the Senior Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2018 ASHRAE

ISSN 1041-2336



**ASHRAE Standing Standard Project Committee 62.1**  
**Cognizant TC: 4.3, Ventilation Requirements and Infiltration**  
**SPLS Liaison: Karl L. Peterman**

Hoy R. Bohanon, Jr.* <i>Chair</i>	Enrica Galasso	Daniel C. Pettway*
Jennifer A. Isenbeck* <i>Co-Vice-Chair</i>	Elliott Gall	Stephen Ray*
Wayne R. Thomann* <i>Co-Vice-Chair</i>	Enrique T. Gonzalez*	Chandra Sekhar*
Nick H. Agopian	Gregg Gress*	Charles J. Seyffer
Charlene W. Bayer	Brian J. Hafendorfer*	Jeffrey K. Smith*
Lance R. Brown*	Nathan L. Ho*	Dennis A. Stanke*
Robin M. Bristol	Elliott Horner*	Erica Stewart*
Tina M. Brueckner*	Eli P. Howard, III*	Drayton P. Stott
Mark P. Buttner*	Paul J. Kitchens	Richard Taft
Jordan D. Clark	Stephany I. Mason	Dean T. Tompkins
Leonard A. Damiano*	Maria A. Menchaca Brandan	David Vigue
Abdel K. Darwich*	Christopher O. Muller*	Donald Weekes, Jr.
James E. Dennison	John Nelson, Jr.*	Josiah Wiley*
Paul L. Doppel*	Lisa C. Ng	Runming Yao
Henry W. Ernst, Jr.	Laura G. Petrillo-Groh*	Marwa Zaatari*

\* Denotes members of voting status when the document was approved for publication

---

**ASHRAE STANDARDS COMMITTEE 2017–2018**

Steven J. Emmerich, <i>Chair</i>	Roger L. Hedrick	David Robin
Donald M. Brundage, <i>Vice-Chair</i>	Rick M. Heiden	Peter Simmonds
Niels Bidstrup	Jonathan Humble	Dennis A. Stanke
Michael D. Corbat	Srinivas Katipamula	Wayne H. Stoppelmoor, Jr.
Drury B. Crawley	Kwang Woo Kim	Richard T. Swierczyna
Julie M. Ferguson	Larry Kouma	Jack H. Zarour
Michael W. Gallagher	Arsen K. Melikov	Lawrence C. Markel, <i>BOD ExO</i>
Walter T. Grondzik	R. Lee Millies, Jr.	M. Ginger Scoggins, <i>CO</i>
Vinod P. Gupta	Karl L. Peterman	
Susanna S. Hanson	Erick A. Phelps	

Steven C. Ferguson, *Senior Manager of Standards*

---

**SPECIAL NOTE**

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

**(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)**

## FOREWORD

*Addendum c deletes Informative Appendix C, "Summary of Selected Air Quality Guidelines," from Standard 62.1. Appendix C first appeared in Standard 62-1989. Since that time there have been many additions and modifications. Its purpose is to assist with the IAQ procedure. The committee is aware of misuse and confusion caused by the information in its present form. The committee prefers to delete this misused appendix now. The committee may add back relevant informative guidance that assists with implementation of the IAQ procedure in the next version of the standard.*

**Note:** In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

### Addendum c to Standard 62.1-2016

#### Revise Section 6.3.1 as shown.

**6.3.1 Contaminant Sources.** Each contaminant of concern, for purposes of the design, shall be identified. For each contaminant of concern, indoor sources and outdoor sources shall be identified, and the emission rate for each contaminant of concern from each source shall be determined. Where two or more contaminants of concern target the same organ system, these contaminants shall be considered to be a contaminant mixture.

**Informative Note:** ~~Informative Appendix C provides information for some potential contaminants of concern, including the organs they affect.~~

#### Revise Section 6.3.2 as shown.

**6.3.2 Contaminant Concentration.** For each contaminant of concern, a concentration limit and its corresponding exposure period and an appropriate reference to a cognizant authority shall be specified. For each contaminant mixture of concern, the ratio of the concentration of each contaminant to

its concentration limit shall be determined, and the sum of these ratios shall be not greater than one.

**Exception:** Consideration of odors in determining concentration limits shall not be required.

#### Informative Notes:

- 1- Odors are addressed in Section 6.3.4.2.
- 2- ~~Informative Appendix C includes concentration guidelines for some potential contaminants of concern.~~

#### Revise Section 6.3.4.2 as shown.

**6.3.4.2 Subjective Evaluation.** Using a subjective occupant evaluation conducted in the completed building, the minimum outdoor airflow rates required to achieve the level of acceptability specified in Section 6.3.3 shall be determined within each zone served by the system.

**Informative Notes:** Level of acceptability often increases in response to increased outdoor airflow rates, increased level of indoor or outdoor air cleaning, or decreased indoor or outdoor contaminant emission rate.

- 1- ~~Informative Appendix C presents one approach to subjective occupant evaluation.~~
- 2- ~~Level of acceptability often increases in response to increased outdoor airflow rates, increased level of indoor or outdoor air cleaning, or decreased indoor or outdoor contaminant emission rate.~~

#### Revise Section 6.5.2.1 as shown.

**6.5.2.1 Contaminant Sources.** Contaminants or mixtures of concern for purposes of the design shall be identified. For each contaminant or mixture of concern, indoor sources (occupants, materials, activities, and processes) and outdoor sources shall be identified, and the emission rate for each contaminant of concern from each source shall be determined.

**Informative Note:** ~~Informative Appendix C provides information for some potential contaminants of concern.~~

#### Revise Section 6.5.2.2 as shown.

**6.5.2.2 Contaminant Concentration.** For each contaminant of concern, a concentration limit and its corresponding exposure period and an appropriate reference to a cognizant authority shall be specified.

**Informative Note:** ~~Informative Appendix C includes concentration guidelines for some potential contaminants of concern.~~

#### Delete Informative Appendix C in its entirety.

~~(This appendix is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)~~

## ~~INFORMATIVE APPENDIX C SUMMARY OF SELECTED AIR QUALITY GUIDELINES~~

~~If particular contaminants are of concern, or if the IAQ Procedure is to be used, acceptable indoor concentrations and exposures are needed for the particular contaminants. When using this procedure, these concentration and exposure values need to be documented and justified by reference to a cognizant authority as defined in the standard. Such guidelines or other limiting values can also be useful for diagnostic purposes. At present, no single organization develops acceptable concentrations or exposures for all indoor air contaminants, nor are values available for all contaminants of potential concern. A number of organizations offer guideline values for selected indoor air contaminants. These values have been developed primarily for ambient air, occupational settings, and, in some cases, for residential settings. They should be applied with an understanding of their basis and applicability to the indoor environment of concern. If an acceptable concentration or exposure has not been published for a contaminant of concern, a value may be derived through review of the toxicological and epidemiological evidence using appropriate consultation. However, the evidence with respect to health effects is likely to be insufficient for many contaminants. At present, there is no quantitative definition of acceptable IAQ that can necessarily be met by measuring one or more contaminants.~~

~~Table C-1 presents selected standards and guidelines used in Canada, Germany, Europe, and the United States for acceptable concentrations of substances in ambient air, indoor air, and industrial workplace environments. These values are issued by cognizant authorities and have not been developed or endorsed by ASHRAE. The table is presented only as background information when using the IAQ Procedure. Specialized expertise should be sought before selecting a value for use in estimating outdoor airflow rates using the IAQ Procedure or for building design or diagnostics purposes. Meeting one, some, or all of the listed values does not ensure that acceptable IAQ (as defined in this standard) will be achieved.~~

~~Tables C-2 and C-3 list concentration values of interest for selected contaminants as general guidance for building design, diagnostics, and ventilation system design using the IAQ Procedure. The values in the table are based on cognizant authorities and studies reported in peer-reviewed scientific publications; ASHRAE does not recommend their adoption as regulatory values, standards, or guidelines. The tables are presented as further background when using the IAQ Procedure. Consultation should be sought before selecting a particular value for use in calculating ventilation using the IAQ Procedure. Meeting one, some, or all of the listed values does not ensure that acceptable IAQ will be achieved.~~

Selection of a specific target concentration and exposure is best made by a team with wide experience in toxicology, industrial hygiene, and exposure assessment. As they review the specific concentrations listed in Tables C-1, C-2, and C-3, or others taken from other sources, designers should be mindful of the following:

- ~~Standards and guidelines are developed for different purposes and should be interpreted with reference to the setting and purpose for which they were developed compared to that to which they are being applied.~~
- ~~Not all standards and guideline values recognize the presence of susceptible groups or address typical populations found in occupancies listed in this standard.~~
- ~~Most standards and guidelines do not consider interactions between and among various contaminants of concern.~~
- ~~The assumptions and conditions set forth by the standard or guideline may not be met in the space or for the occupants being considered (such as an 8-hour day, 40-hour work week).~~

~~When many chemicals are present in the air, as they almost always are in indoor air, then some way of addressing potential additive effects is warranted. The ACGIH guidance on the subject instructs that when two or more substances acting on the "...same organ system are present, their combined effect, rather than that of either individually, should be given primary consideration." <sup>C-1</sup> Information on affected organs is readily available on the websites of the cited references for ACGIH, OEHHA, and ATSDR. If no contradictory information is available, the effects of the different substances "should be considered as additive." A formula is given wherein the ratios of the concentrations of each substance with the same health-related endpoint to the threshold limit value for each substance are added. If the sum of all these ratios exceeds unity, then it is considered that the concentration value has been exceeded.~~

$$\frac{C_1}{T_1} + \frac{C_2}{T_2} + \dots + \frac{C_n}{T_n}$$

~~where~~

~~$C_i$  = airborne concentration of the substance~~

~~$T_i$  = threshold limit value of that substance~~

## ~~C1. GUIDELINE VALUES FOR INDUSTRIAL ENVIRONMENTS~~

~~ACGIH threshold limit values, or TLVs<sup>®</sup>, have been applied to industrial workplace air contaminants <sup>C-1</sup> (Reference C-2 is the German counterpart). The ACGIH TLVs represent the maximum acceptable 8-hour, time-weighted average (TWA); 15-minute short-term exposure limit (STEL); and instantaneous (ceiling) case limits. It is a source of concentration limits for many chemical substances and physical agents for industrial use. In light of the constantly changing state of knowledge, the document is updated annually. It cautions the user, "The values listed in this book are intended for use in the practice of industrial hygiene as guidelines or recommenda-~~

tions to assist in the control of potential health hazards and for no other use.”

Caution must be used in directly extending the ACGIH TLVs or other workplace guidelines to spaces covered by this standard and to population groups other than workers. Industrial health practice attempts to limit worker exposure to injurious substances at levels that do not interfere with the industrial work process and do not risk the workers' health and safety. There is not an intention to eliminate all effects, such as unpleasant smells or mild irritation. Further, the health criteria are not uniformly derived for all contaminants. Irritation, narcosis, and nuisance or other forms of stress are not uniformly considered as the basis for the concentration limits. This is because different organizations use different end points and different contaminants have more or less information available on diverse end points of interest. The target population is also different from the occupants found in the spaces covered by this standard. Healthy industrial workers tend to change jobs or occupations if an exposure becomes intolerable. In contrast, workers in commercial environments such as offices often do not expect elevated concentrations of potentially harmful substances in their work environments. Also, monitoring programs are unlikely to be in place, as may be the case with industrial workplaces. In addition, the general population may have less choice about where they spend most of their time and includes those who may be more sensitive, such as children, asthmatics, allergic individuals, the sick, and the elderly.

## **C2. GUIDELINES FOR SUBSTANCES IN OUTDOOR AIR**

Guidelines have been developed for outdoor air for a number of chemicals and metals, as shown in many of the references. These values, including some for metals, may be appropriate for some indoor environments, but they should be applied only after appropriate consultation. These guidelines also provide guidance concerning the quality of outdoor air if there is suspicion that outdoor air may be contaminated with specific substances or if there is a known source of contamination nearby.<sup>C-3</sup>

## **C3. REGULATION OF OCCUPATIONAL EXPOSURE TO AIRBORNE CONTAMINANTS**

Regulations of occupational exposure to workplace hazards are based on the results of accumulated experience with worker health and toxicological research and carefully evaluated by groups of experts. Effects are examined in relation to exposure to the injurious substance. Exposure is defined as the mathematical product of the concentration of the contaminant and the time during which a person is exposed to this concentration. Because concentration may vary with time, exposure is typically calculated across the appropriate averaging time, expressed as a TWA concentration, STEL, or ceiling limit. Regulations of the U.S. Occupational Safety and Health Administration (OSHA) are TWAs in most cases.

Industrial exposures are regulated on the basis of a 40-hour workweek with 8- to 10-hour days. During the remainder of the time, exposure is anticipated to be substantially lower for the contaminants of concern. Application of indus-

trial exposure limits would not necessarily be appropriate for other indoor settings, occupancies, and exposure scenarios. However, for certain contaminants that lack exposure limits for a specific nonindustrial target population, substantial downward adjustments to occupational limits have sometimes been used.

## **C4. SUBSTANCES LACKING GUIDELINES AND STANDARDS**

For indoor contaminants for which an acceptable concentration and exposure value has not been established by a cognizant authority, one approach has been to assume that some fraction of TLV is applicable and would not lead to adverse health effects or complaints in general populations. This approach should not be used without first assessing its suitability for the contaminant of concern. In any event, if appropriate standards or guidelines do not exist, expertise must be sought or research needs to be conducted to determine contaminant concentrations and exposures that are acceptable.

## **C5. SUBJECTIVE EVALUATION**

Indoor air often contains complex mixtures of contaminants of concern, such as environmental tobacco smoke<sup>C-30,C-31</sup>, infectious and allergenic biological aerosols<sup>C-32</sup>, and emissions of chemicals from commercial and consumer products. Precise quantitative treatment of these contaminants can be difficult or impossible in most cases. Chemical composition alone may not always be adequate to reliably predict the reaction of building occupants exposed to most common mixtures of substances found in indoor air. There are many toxicological endpoints used in assessing the effects from exposure to air contaminants.

Irritation of mucosal tissue, such as that found in the human nose, eyes, and the upper airways, is one of the endpoints often used in assessing short-term exposure to air contaminants. These irritation responses can occur after the irritant receptor is exposed to nonreactive compounds, to reactive compounds with a different pattern of dose-response relationships, and through allergic and other immunologic effects for which dose-response relationships have not been well defined. Susceptible populations—i.e., individuals with atopy (“allergies”)—may report irritation at lower levels of exposures than individuals without allergies. Other susceptible populations, such as the elderly and the young, may differ from healthy adults in their response to irritating and odorous substances.

To some degree, adequacy of control may rest upon subjective evaluation. Panels of observers have been used to perform subjective evaluation of IAQ in buildings. Many contaminants have odors or are irritants that may be detected by human occupants or visitors to a space. Generally, the air can be considered acceptably free of annoying contaminants if 80% of a panel consisting of a group of untrained subjects exposed to known concentrations of contaminants under representative controlled conditions of use and occupancy deems the air not to be objectionable.

When performing a subjective evaluation, an observer should enter the space in the manner of a normal visitor and should render a judgment of acceptability within 15 seconds.

Each observer should make the evaluation independently of other observers and without influence from a panel leader. Users of subjective evaluation methods are cautioned that they only test odor and sensory responses. Some harmful contaminants will not be detected by such tests. Carbon monoxide and radon are two examples of odorless contaminants that pose significant health risks. To evaluate the acceptability of adapted persons (occupants), an observer should spend at least six minutes in the space before rendering a judgment of acceptability<sup>C-29</sup>.

## REFERENCES

- C-1. ACGIH. 2005. *Threshold Limit Values for Chemical Substances and Physical Agents and Biological Exposure Indices*. American Conference of Governmental Industrial Hygienists, 1330 Kemper Meadow Drive, Cincinnati, OH 45240-1634. www.acgih.org.
- C-2. *Maximum Concentrations at the Workplace and Biological Tolerance Values for Working Materials 2000*, Commission for the Investigation of Health Hazards of Chemical Compounds in the Work Area, Federal Republic of Germany.
- C-3. Martin, W., and A.C. Stern. 1974. *The World's Air Quality Standards*, Vol. II. *The Air Quality Management Standards of the United States*, Table 17, pp. 11-38. October 1974 (available from NTIS PB 241-876; National Technical Information Service, 4285 Port Royal Road, Springfield, VA 22161).
- C-4. U.S. Environmental Protection Agency. 2008. *Code of Federal Regulations*, Title 40, Part 50. National Ambient Air Quality Standards. www.epa.gov/air/criteria.html.
- C-5. U.S. Department of Labor, Occupational Safety and Health Administration. *Code of Federal Regulations*, Title 29, Part 1910.1000-1910.1450. www.osha.gov.
- C-6. U.S. Food and Drug Administration. 2004. *Code of Federal Regulations*, Title 21, Part 801.415 (maximum acceptable levels of ozone), April 1. www.gpo-access.gov/cfr/index.html.
- C-7. U.S. Environmental Protection Agency. 1992. *A Citizen's Guide to Radon and Technical Support Document for the Citizen's Guide to Radon*.
- C-8. Health Canada. 1995. *Exposure Guidelines for Residential Indoor Air Quality: A Report of the Federal Provincial Advisory Committee on Environmental and Occupational Health*. Ottawa: Health Canada. www.hc-sc.gc.ca/heccesc/air\_quality/pdf/tr-156.pdf.
- C-9. U.S. Environmental Protection Agency. 1990. *Compendium of Methods for Determination of Air Pollutants in Indoor Air*. Document No. PB 90-200-288/AS, available from NTIS, Springfield, VA 22161.
- C-10. American Society of Testing and Materials. *Annual Book of ASTM Standards*, Section 11, Vol. 11.03 *Atmospheric Analysis; Occupational Health and Safety*. ASTM, West Conshohocken, PA.
- C-11. World Health Organization. 2000. *Air Quality Guidelines for Europe, 2nd Edition*. World Health Organization Regional Publications, European Series No. 91. World Health Organization, Regional Office for Europe, Copenhagen, www.euro.who.int/document/e71922.pdf.
- C-12. Commission of the European Communities. 1992. *Report No. 11: Guidelines for Ventilation Requirements in Buildings*. Joint Research Centre, Ispra (Varese), Italy.
- C-13. NIOSH. 2004. *NIOSH Pocket Guide to Chemical Hazards (NPG)*. National Institute for Occupational Safety and Health, February. www.cdc.gov/niosh/npg/npg.html.
- C-14. Shields, H.C., D.M. Fleischer, and C.J. Weschler. 1996. Comparisons among VOCs measured at three types of U.S. commercial buildings with different occupant densities. *Indoor Air* 6(1):2-17.
- C-15. Devos, M. F. Patte, J. Rouault, P. Laffort, and L.J. Van Gemert. 1990. *Standardized Human Olfactory Thresholds*. Oxford University Press, Oxford.
- C-16. California Air Resources Board. 2004. *Indoor Air Quality Guideline No. 1, Formaldehyde in the Home*. August. Sacramento, CA. http://www.arb.ca.gov/research/indoor/formaldGL08-04.pdf.
- C-17. American Society of Testing and Materials. 2004. *Standard Practice for Conversion Units and Factors Relating to Sampling and Analysis of Atmospheres*, D 1914-95(2004)e1. In *Annual Book of ASTM Standards*, 2004; Section Eleven, Water and Environmental Technology, Vol. 11.03. 100 Barr Harbor Drive, West Conshohocken, PA, 19428, www.astm.org.
- C-18. U.S. Environmental Protection Agency. *The Plain English Guide To The Clean Air Act*. EPA Office of Air Quality Planning and Standards. www.epa.gov/oar/oaqps/peg-cao/pegeaa11.html.
- C-19. U.S. Environmental Protection Agency. 1988. *Health and Environmental Effects Profile for Formaldehyde*. EPA/600/x-85/362. Environmental Criteria and Assessment Office, Office of Health and Environmental Assessment, Office of Research and Development, Cincinnati, OH.
- C-20. U.S. Environmental Protection Agency. *Formaldehyde: Hazard Summary*. Technology Transfer Network, Air Toxics Web site, Office of Air Quality Planning and Standards. www.epa.gov/ttnatw01/hlthef/formalde.html.
- C-21. Hodgson, A.T. 1995. A review and a limited comparison of methods for measuring total volatile organic compounds in indoor air. In *Indoor Air*, Vol. 5, No. 4.
- C-22. Brown, S., M.R. Sim, M.J. Abramson, and C.N. Gray. 1994. Concentrations of volatile organic compounds in indoor air—A review, p. 123-34. In *Indoor Air*, Vol. 4.
- C-23. Daisey, J.M., A.T. Hodgson, W.J. Fisk, M.J. Mendell, and J. Ten Brinks. 1994. Volatile organic compounds in twelve California office buildings: Classes, concentrations, and sources, p. 3557-62. In *Atmospheric Environment*, Vol. 28, No. 22.
- C-24. Nielsen et al. 1998. In H. Levin (Ed.), *Indoor Air Guideline Values for Organic Acids, Phenols, and*

- Glycol Ethers*. Indoor Air Supplement 5/1998. Munksgaard, Copenhagen.
- C-25. Anonymous. 1999. *Jane's Chem-Bio Handbook*. Jane's Information Group. Alexandria, Virginia.
- C-26. Anderson, K., J.V. Bakke, O. Bjørseth, C.-G. Bornehag, G. Clausen, J.K. Hongslo, M. Kjellman, S. Kjærgaard, F. Levy, L. Mølhave, S. Skerfving and J. Sundell. 1997. *TVOC and Health in Non-Industrial Indoor Environments*. Report from a Nordic Scientific Consensus Meeting at Långholmen in Stockholm, 1996. In *Indoor Air*, Vol. 7:78-91.
- C-27. European Collaborative Action. *Total Volatile Organic Compounds (TVOC) in Indoor Air Quality Investigations*, Report No. 19 (EUR 17675 EN). Joint Research Centre, Environment Institute, European Commission. Ispra, Italy.
- C-28. Wolkoff, P., P.A. Clausen, B. Jensen, G.D. Nielsen and C.K. Wilkins. 1997. Are we measuring the relevant indoor pollutants?, pp. 92-106. In *Indoor Air*, Vol. 7.
- C-29. Gunnarsen, L. and P.O. Fanger. 1992. Adaptation to indoor air pollution, pp. 43-54. In *Environment International*, Vol. 18.
- C-30. National Institutes of Safety and Health (NIOSH). 1991. *Environmental Tobacco Smoke in the Workplace*.
- C-31. California Environmental Protection Agency (CalEPA). 1997. *Health Effects of Exposure to Environmental Tobacco Smoke*, Sept. Available at: [www.oehha.ca.gov/air/environmental\\_tobacco/finalets.html](http://www.oehha.ca.gov/air/environmental_tobacco/finalets.html).
- C-32. ACGIH. 1999. *Bioaerosols: Assessment and Control*. American Conference of Governmental Industrial Hygienists. Cincinnati.
- C-33. Roach, S.A and S.M. Rappoport. 1990. But they are not thresholds: A critical analysis, the documentation of threshold limit values, pp. 727-53. In *American Journal of Industrial Medicine*, Vol. 17.
- C-34. Castleman, B.I and G.E. Ziem. 1988. Corporate influence on threshold limit values, pp. 531-59. In *Am. J. Ind. Med.* Vol. 13.
- C-35. Bluysen et al. 1996. European indoor air quality audit project in 56 office buildings. In *Indoor Air*. Vol. 6.
- C-36. California Environmental Protection Agency, Office of Environmental Health Hazard Assessment. December 18, 2008. *Air Toxics Hot Spots Program Risk Assessment Guidelines. Technical Support Document for the Derivation of Noncancer Reference Exposure Levels*. OEHHA, Sacramento, CA. Available at <http://www.oehha.org/air/allrels.html>.
- C-37. Womble S.E., E.L. Ronea, J.R. Girman, and H.S. Brightman. 1996. Developing baseline information on buildings and indoor air quality (BASE '95), pp. 109-17. In *Proceedings of IAQ 96/Paths to Better Building Environments/Health Symptoms in Building Occupants*, Atlanta, Georgia.
- C-38. Hadwen, G.E., J.F. McCarthy, S.E. Womble, J.R. Girman, and H.S. Brightman, 1997. Volatile organic compound concentrations in 41 office buildings in the continental United States, pp. 465-70. In J.E. Woods, D.T. Grimsrud, and N. Boschi, (Eds.), *Proceedings: Healthy Buildings/LAQ'97*. Washington, DC: Vol. 2.
- C-39. Apte, M.G. and J.M. Daisey. 1999. VOCs and "sick building syndrome": Application of a new statistical approach for SBS research to US EPA BASE study data, pp. 117-22. In *Proceedings of Indoor Air 99: The 8th International Conference on Indoor Air Quality and Climate, Edinburgh, Scotland, 8-13 August*. Vol. 1.
- C-40. International Agency for Research on Cancer (IARC). 2004. *Monographs on the Evaluation of Carcinogenic Risks to Humans: Formaldehyde, 2-Butoxyethanol and 1-tert-Butoxy-2-propanol* 88:2-9 (June). [www.iarc.fr/htdocs/announcements/vol88.html](http://www.iarc.fr/htdocs/announcements/vol88.html).
- C-41. California Air Resources Board. 2005. *California Ambient Air Quality Standards*. Sacramento, CA. <http://www.arb.ca.gov/research/aaqs/caaqs/caaqs.htm>.
- C-42. Hodgson, A.T., and H. Levin. 2003. Volatile Organic Compounds in Indoor Air: A Review of Concentrations Measured in North America Since 1990. LBL Report 51715, April 2003. <http://eetd.lbl.gov/ied/pdf/LBNL-51715.pdf>.
- C-43. Hodgson, A.T., and H. Levin. 2003. Classification of Measured Indoor Volatile Organic Compounds Based on Noncancer Health and Comfort Considerations. LBL Report 53308. Lawrence Berkeley National Laboratory, September 2003. <http://eetd.lbl.gov/ied/pdf/LBNL-53308.pdf>.
- C-44. European Commission. 2004. *Critical Appraisal of the Setting and Implementation of Indoor Exposure Limits in the EU (THE INDEX Project): Summary of Recommendations and Management Options*. December 2004. Joint Research Centre, Institute for Health and Consumer Protection, Physical and Chemical Exposure Unit, Ispra, Italy. Available at [http://ec.europa.eu/health/index\\_en.htm](http://ec.europa.eu/health/index_en.htm).
- C-45. Levin, H. and A. T. Hodgson. 2006. VOC Concentrations of Interest in North American Offices and Homes. *Proceedings Healthy Buildings 2006*, Lisbon, Portugal, 4-8 June, 2006, Vol. I, pp. 233-238.
- C-46. U.S. Department of Health and Human Services, Agency for Toxic Substances and Disease Registry (ATSDR), Jan. 14, 2009. *Minimal Risk Levels (MRLs)*. Accessible at <http://www.atsdr.edc.gov/mrls/>
- C-47. California Air Resources Board. 2008. *Airborne Toxic Control Measure to Reduce Formaldehyde Emissions from Composite Wood Products*. California Code of Regulations, Title 17, Sections 93120-93120.12. Also available at <http://www.arb.ca.gov/toxics/compwood/compwood.htm>.
- C-48. FEMA Procurement Specification, Release Number HQ-08-056, April 11, 2008. Available at: <http://www.fema.gov/news/newsrelease.fema?id=43180>.

## Guide for Using TABLE C-1

The substances listed in Table C-1 are common air contaminants in industrial and nonindustrial environments. The values summarized in this table are from various sources with diverse procedures and criteria for establishing the values. Some are for industrial environments (OSHA, MAK, NIOSH, ACGIH), some are for outdoor environments (NAAQS), and others are general (WHO) or indoor residential environment related (Canadian) values. The following explanations are intended to assist the reader by providing a brief description of the criteria each agency used in adopting its guideline values.

- **NAAQS:** Outdoor air standards developed by the U.S. EPA under the Clean Air Act. By law, the values listed in these regulations must be reviewed every five years. These concentrations are selected to protect not only the general population but also the most sensitive individuals.
- **OSHA:** Enforceable maximum exposures for industrial environments developed by OSHA (U.S. Department of Labor) through a formal rule-making process. Once an exposure limit has been set, levels can be changed only through reopening the rule-making process. These permissible exposure limits (PELs) are not selected to protect the most sensitive individuals.
- **MAK:** Recommended maximum exposures for industrial environments developed by the Deutsche Forschungs Gemeinschaft, a German institution similar to the U.S. National Institutes of Health and NIOSH. Levels are set on a regular basis, with annual reviews and periodic republication of criteria levels. These levels are enforceable in Germany and are not selected to protect the most sensitive individuals.
- **Canadian:** Recommended maximum exposures for residences developed in 1987 and reaffirmed in 1995 by a committee of provincial members convened by the federal government to establish consensus guideline type levels. A revised version is being considered. These are not intended to be enforced.
- **WHO/Europe:** Environmental (nonindustrial) guidelines developed in 1987 and updated in 1999 by the WHO Office for Europe (Denmark). Intended for application both to indoor and outdoor exposure.
- **NIOSH:** Recommended maximum exposure guidelines for industrial environments are developed by NIOSH (Centers for Disease Control) and published in a series of criteria documents. NIOSH criteria documents contain both a review of the literature and a recommended exposure limit (REL) guideline. These are not enforceable, are not reviewed regularly, and are not selected to protect the most sensitive individuals. In some cases, they are set at levels above those deemed protective of health because commonly available industrial hygiene practice does not reliably detect the substances at lower levels. (Note that methods used in nonindustrial settings are often more sensitive than NIOSH methods for industrial hygiene measurements.)
- **ACGIH:** Recommended maximum exposures for industrial environments developed by ACGIH's Threshold Limit Values (TLVs) Committee. The committee reviews the scientific literature and recommends exposure guidelines. The assumptions are for usual industrial working conditions, 40-hour weeks, and single exposures. Surveillance practices for both exposures and biological responses are often in place in the work environments where these levels are used. These levels are not selected to protect the most sensitive individuals. About half of the TLVs are intended to protect against irritation. Published studies have shown that many of the TLVs intended to protect against irritation actually represent levels where some or all of the study subjects did report irritation<sup>C-33, C-34</sup>.

The table is not inclusive of all contaminants in indoor air, and achieving the listed indoor concentrations for all of the listed substances does not ensure odor acceptability, avoidance of sensory irritation, or all adverse health effects for all occupants. In addition to indoor contaminant levels, the acceptability of indoor air also involves thermal conditions, indoor moisture levels as they impact microbial growth, and other indoor environmental factors. ASHRAE is not selecting or recommending default concentrations.

Users of this table should recognize that unlisted noxious contaminants can also cause unacceptable IAQ with regard to comfort (sensory irritation), odors, and health. When such contaminants are known or might reasonably be expected to be present, selection of an acceptable concentration and exposure may require reference to other guidelines or a review and evaluation of relevant toxicological and epidemiological literature.

**TABLE C-1 Comparison of Regulations and Guidelines Pertinent to Indoor Environments<sup>a</sup>**  
(The user of any value in this table should take into account the purpose for which it was adopted and the means by which it was developed.)

	Enforceable and/or Regulatory Levels				Nonenforced Guidelines and Reference Levels			
	NAAQS/EPA (Ref. C-4)	OSHA (Ref. C-5)	MAK (Ref. C-2)	Canadian (Ref. C-8)	WHO/Europe (Ref. C-11)	NIOSH (Ref. C-13)	ACGIH (Ref. C-1)	
Carbon dioxide	5000 ppm		5000 ppm 10,000 ppm [1-h]	3500 ppm [1-]		5000 ppm 30,000 ppm [1.5-min]	5000 ppm 30,000 ppm [1.5-min]	
Carbon monoxide <sup>e</sup>	9 ppm <sup>g</sup> 35 ppm [1-h] <sup>g</sup>	50 ppm	30 ppm 60 ppm [30 min]	11 ppm [8-h] 25 ppm [1-h]	90 ppm [1.5-min] 50 ppm [30 min] 25 ppm [1-h] 10 ppm [8-h]	35 ppm 200 ppm [C]	25 ppm	
Formaldehyde <sup>h</sup>		0.75 ppm 2 ppm [1.5-min]	0.3 ppm 1 ppm <sup>i</sup>	0.1 ppm [1-] 0.05 ppm [1-] <sup>b</sup>	0.1 mg/m <sup>3</sup> (0.081 ppm) [30-min] <sup>p</sup>	0.016 ppm 0.1 ppm [1.5-min]	0.3 ppm [C]	
Lead	1.5 µg/m <sup>3</sup> [3-months]	0.05 mg/m <sup>3</sup>	0.1 mg/m <sup>3</sup> 1 mg/m <sup>3</sup> [30 min]	Minimize exposure	0.5 µg/m <sup>3</sup> [1-yr]	0.050 mg/m <sup>3</sup>	0.05 mg/m <sup>3</sup>	
Nitrogen dioxide	0.05 ppm [1-yr]	5 ppm [C]	5 ppm 10 ppm [5-min]	0.05 ppm 0.25 ppm [1-h]	0.1 ppm [1-h] 0.02 ppm [1-yr]	1 ppm [1.5-min]	3 ppm 5 ppm [1.5-min]	
Ozone	0.12 ppm [1-h] <sup>g</sup> 0.08 ppm	0.1 ppm	j	0.12 ppm [1-h]	0.064 ppm (120 µg/m <sup>3</sup> ) [8-h]	0.1 ppm [C]	0.05 ppm <sup>k</sup> 0.08 ppm <sup>l</sup> 0.1 ppm <sup>m</sup> 0.2 ppm <sup>n</sup>	
Particles <sup>e</sup> <2.5 µm-MMAD <sup>d</sup>	15 µg/m <sup>3</sup> [1-yr] <sup>o</sup> 35 µg/m <sup>3</sup> [24 h] <sup>o</sup>	5 mg/m <sup>3</sup>	1.5 mg/m <sup>3</sup> for <4 µm 4 mg/m <sup>3</sup>	0.1 mg/m <sup>3</sup> [1-h] 0.040 mg/m <sup>3</sup> [1-]			3 mg/m <sup>3</sup> [C]	
Particles <sup>e</sup> <10 µm-MMAD <sup>d</sup>	150 µg/m <sup>3</sup> [24 h] <sup>o</sup>						10 mg/m <sup>3</sup> [C]	
Radon				800 Bq/m <sup>3</sup> [1-yr]				
Sulfur dioxide	0.03 ppm [1-yr] <sup>g</sup> 0.14 ppm [24 h] <sup>g</sup>	5 ppm	0.5 ppm 1 ppm <sup>i</sup>	0.38 ppm [5-min] 0.019 ppm	0.048 ppm [24-h] 0.042 ppm [1-yr]	2 ppm 5 ppm [1.5-min]	2 ppm 5 ppm [1.5-min]	
Total particles <sup>e</sup>		15 mg/m <sup>3</sup>						

a. Numbers in brackets [ ] refer to either a ceiling or to averaging times: of less than or greater than eight hours; (min = minutes; h = hours; y = year; C = ceiling; 1 = long-term). Where no time is specified, the averaging time is eight hours.  
b. Target level is 0.05 ppm because of its potential carcinogenic effects. Total aldehydes limited to 1 ppm. Although the epidemiological studies conducted to date provide little convincing evidence that formaldehyde is carcinogenic in human populations, because of this potential, indoor levels should be reduced as much as possible.  
c. As one example regarding the use of values in this table, readers should consider the applicability of carbon monoxide concentrations. The concentrations considered acceptable for nonindustrial, as opposed to industrial, exposure are substantially lower. These lower concentrations (in other words, the ambient air quality standards, which are required to consider populations at highest risk) are set to protect the most sensitive subpopulation, individuals with pre-existing heart conditions.  
d. MMAD = mass median aerodynamic diameter in microns (micrometers). Less than 3.0 µm is considered respirable; less than 10 µm is considered inhalable.  
e. Nuisance particles not otherwise classified (PNOC), not known to contain significant amounts of asbestos, lead, crystalline silica, known carcinogens, or other particles known to cause significant adverse health effects.  
f. See Table C-2 for the U.S. EPA guideline.  
g. Not to be exceeded more than once per year.  
h. The U.S. Department of Housing and Urban Development adopted regulations concerning formaldehyde emissions from plywood and particleboard intended to limit the airborne concentration of formaldehyde in manufactured homes to 0.4 ppm. (24 CFR Part 3280, HUD Manufactured Home Construction and Safety Standards). In addition, California Air Resources Board Regulation 93120, entitled "Airborne Toxic Control Measure to Reduce Formaldehyde Emissions from Composite Wood Products," has specific chamber-based requirements for composite wood products sold in California C-47.  
i. Never to be exceeded  
j. Carcinogen, no maximum values established  
k. TLV for heavy work  
l. TLV for moderate work  
m. TLV for light work  
n. TLV for heavy, moderate, or light workloads (less than or equal to two hours)  
o. 62 FR 38652-38760, July 16, 1997  
p. Epidemiological studies suggest a causal relationship between exposure to formaldehyde and nasopharyngeal cancer, although the conclusion is tempered by the small numbers of observed and expected cases. There are also epidemiological observations of an association between relatively high occupational exposures to formaldehyde and sinonasal cancer.

## Guide for Using TABLE C-2

The substances listed in Table C-2 are common air contaminants of concern in nonindustrial environments. The target concentrations that have been set or proposed by various national or international organizations concerned with health and comfort effects of outdoor and indoor air are listed for reference only. The table is not inclusive of all contaminants in indoor air, and achieving the target indoor concentrations for all of the listed substances does not ensure freedom from sensory irritation or from all adverse health effects for all occupants. In addition to indoor contaminant levels, the acceptability of indoor air also involves thermal conditions, indoor moisture levels as they impact microbial growth, and other indoor environmental factors. ASHRAE is not selecting or recommending default concentrations.

Health or comfort effects and exposure periods that are the basis for the guideline levels are listed in the “comments” column. For design, the goal should be to meet the guideline levels continuously during occupancy because people spend the great majority of their time indoors.

Users of this table should recognize that unlisted noxious contaminants can also cause unacceptable IAQ with regard to comfort (sensory irritation), odors, and health. When such contaminants are known or might reasonably be expected to be present, selection of an acceptable concentration and exposure may require reference to other guidelines or a review and evaluation of relevant toxicological and epidemiological literature. (Table C-2 summarizes some of this literature.)

**TABLE C-2 Concentration of Interest for Selected Contaminants**

(Note: References numbers that are followed by [c] and [m] list the concentrations of interest [c] and measurement methods [m]. The user of any value in this table should take into account the purpose for which it was adopted and the means by which it was developed.)

Contaminant	Sources	Concentrations of Interest	Comments	References
Carbon Monoxide (CO)	Leaking-vented combustion appliances Unvented combustion appliances Parking garages Outdoor air	9 ppm (8 h)	Based on effects on persons with coronary artery disease, average exposure for eight hours. Sustained indoor concentrations exceeding outdoor concentrations may merit further investigation. Many carbon monoxide measuring instruments have limited accuracy at low levels. Sources—burning of gasoline, natural gas, coal, oil, etc. (Note: CO is unlikely to be the only contaminant of concern in parking garages or other spaces where vehicles operate.) Health effects—reduces ability of blood to bring oxygen to body cells and tissues; cells and tissues need oxygen to work. Carbon monoxide may be particularly hazardous to people who have heart or circulatory problems and people who have damaged lungs or breathing passages.	C-4 [c] C-9 [m]
Formaldehyde (HCHO)	Pressed-wood products Furniture and furnishings	0.1 mg/m <sup>3</sup> (0.081 ppm) (30 min)  27 ppb (8 h)	Based on irritation of sensitive people, 30-minute exposure (WHO)  Established as a never-to-exceed guideline to avoid irritant effects in sensitive individuals. Does not protect against formaldehyde's potential carcinogenicity (California Air Resources Board).	C-11 [c] C-9, 26 [m]  C-16
		45 ppb (55 µg/m <sup>3</sup> ) (1 h) 7.3 ppb (9 µg/m <sup>3</sup> ) (8 h)	Acute and 8-hour noncancer Reference Exposure Levels (RELEs) developed based on current scientific database (Cal-EPA, OEHHA).  Health effects—Acute and chronic inhalation exposure to formaldehyde in humans can result in eye, nose, and throat irritation, respiratory symptoms, exacerbation of asthma, and sensitization. Human studies have reported an association between formaldehyde exposure and lung and nasopharyngeal cancer. In 2004, the International Agency for Research on Cancer (IARC) concluded that “formaldehyde is carcinogenic to humans (Group 1), on the basis of sufficient evidence in humans and sufficient evidence in experimental animals.”	C-36  C-19, 20, 36, 40
		16 ppb	FEMA Procurement Specification for Mobile Homes	C-48

a. USEPA has promulgated a guideline value of 4 pCi/L indoor concentration. This is not a regulatory value but an action level where mitigation is recommended if the value is exceeded in long-term tests.

### Conversion Factors C-17

Parts per million and mass per unit volume:

Measurements of indoor airborne concentrations of substances are generally converted to standard conditions of 77°F (25°C) and 29.92 in-Hg (101.325 kPa) pressure. Vapors or gases are often expressed in parts per million (ppm) by volume or in mass per unit volume. Concentrations in ppm by volume can be converted to mass per unit volume values as follows:

$$\text{ppm} \times \text{molecular weight} / 24.450 = \text{mg/L}$$

$$\text{ppm} \times \text{molecular weight} / 0.02445 = \mu\text{g/m}^3$$

$$\text{ppm} \times \text{molecular weight} / 24.45 = \text{mg/m}^3$$

$$\text{ppm} \times \text{molecular weight} \times 28.3224 / 450 = \text{mg/ft}^3$$





### Guide for Using Table C-3

Table C-3 provides information that may be beneficial for designers who choose to comply with the Indoor Air Quality Procedure of this Standard. The VOCs included in the table were reported in published, peer-reviewed surveys conducted in office buildings and in new and existing residences in North America during the period 1990–2000 (C-42, C-43, C-45). Only those VOCs for which exposure guidelines for the general population have been developed by cognizant authorities are listed in Table C-3.

Reference Exposure Levels (RELs) are guidelines for acute, 8-hour and chronic inhalation exposures developed by California Office of Health Hazard Assessment (OEHHA). Minimal Risk Levels (MRLs) for hazardous substances are guidelines for acute, intermediate and chronic inhalation exposures developed by the Agency for Toxic Substances and Disease Registry (ATSDR). Factors for  $\mu\text{g}/\text{m}^3$  to ppb concentration conversions are shown.

The table does not purport to represent (a) all possible chemicals found in nonindustrial indoor environments and (b) all concentration guidelines, standards, and regulatory limits. Published, peer-reviewed surveys conducted in office buildings and in new and existing residences in North America since 2000 may identify several more compounds, for some of which guidelines may be available from the cognizant authorities described above.

**TABLE C-3 Concentrations of Interest for Selected Volatile Organic Compounds**

Compound	CAS Number	Chemical Class <sup>a</sup>	Conversion Factor: $\mu\text{g}/\text{m}^3$ to ppb <sup>b</sup>	CA-OEHHA REL <sup>c-36</sup>			ATSDR MRL <sup>c-46</sup>		
				Acute <sup>e</sup> ( $\mu\text{g}/\text{m}^3$ )	8-hr <sup>d</sup> ( $\mu\text{g}/\text{m}^3$ )	Chronic <sup>g</sup> ( $\mu\text{g}/\text{m}^3$ )	Acute <sup>f</sup> (ppb)	Intermediate <sup>g</sup> (ppb)	Chronic <sup>h</sup> (ppb)
Acetaldehyde	75-07-0	Ald	0.554	470	300	140			
Acrolein	107-02-8	Ald	0.436	2.5	0.7	0.35	3	0.4	
Acrylonitrile	107-13-1	Misc	0.460						
Benzene	71-43-2	Arom	0.313	1300		5	9	6	3
Bromomethane (Methyl bromide)	74-83-9	Halo	0.258				50	50	5
1,3-Butadiene	106-99-0	Alke	0.452			20			
2-Butanone	78-93-3	Ket	0.339	13,000					
2-Butoxyethanol	111-76-2	Gly	0.207				6000	3000	200
t-Butyl methyl ether (Methyl-t-butyl ether)	1634-04-4	Ethr	0.277				2000	700	700
Carbon disulfide	75-115-0	Misc	0.321	6200		800			300
Carbon tetrachloride	56-23-5	Halo	0.159	1900		40		30	30
Chlorobenzene	108-90-7	ClAro	0.217			1000			
Chloroform	67-66-3	Halo	0.205	150		300	100	50	20
1,4-Dichlorobenzene	106-46-7	ClAro	0.166			800	2000	200	10

a. Alc = alcohol; Ethr = ether; Gly = glycol ether; Ket = ketone; Ald = aldehyde; Est = acetates and other esters; Acid = carboxylic acid; Alka = alkane HC; Alke = alkene HC; Cyel = cyclic HC; Terp = terpene HC; Arom = aromatic HC; ClAro = chlorinated aromatic HC; Halo = halogenated aliphatic HC; Misc = miscellaneous category

b. Conversion factors from  $\mu\text{g}/\text{m}^3$  to ppb

c. Exposure averaging time is 1 hour

d. Exposure averaging time is 8 hours and which may be repeated

e. Designed to address continuous exposures for up to a lifetime; the exposure metric used is the annual average exposure

f. Exposure to a chemical for a duration of 14 days or less, as specified in the toxicological profiles

g. Exposure to a chemical for a duration of 15–364 days, as specified in the toxicological profiles

h. Exposure to a chemical for 365 days or more, as specified in the toxicological profiles

i. See also Tables C-1 and C-2 for additional guidance on formaldehyde.

TABLE C-3 Concentrations of Interest for Selected Volatile Organic Compounds (Continued)

Compound	CAS Number	Chemical Class <sup>a</sup>	Conversion Factor: $\mu\text{g}/\text{m}^3$ -to-ppb <sup>b</sup>	CA-OEHHA REL <sup>c,36</sup>			ATSDR MRL <sup>c,46</sup>		
				Acute <sup>e</sup> ( $\mu\text{g}/\text{m}^3$ )	8-h <sup>d</sup> ( $\mu\text{g}/\text{m}^3$ )	Chronic <sup>e</sup> ( $\mu\text{g}/\text{m}^3$ )	Acute <sup>f</sup> (ppb)	Intermediate <sup>g</sup> (ppb)	Chronic <sup>h</sup> (ppb)
1,2-Dichloroethane (Ethylene dichloride)	107-06-2	Halo	0.247						600
Dichloromethane (Methylene chloride)	75-09-2	Halo	0.288	14,000		400	600	300	300
1,4-Dioxane	123-91-1	Ethr	0.278	3000		3000	2000	1000	1000
Ethylbenzene	100-41-4	Arom	0.230			2000	10,000	700	300
Ethylene glycol	107-21-1	Gly	0.394			400	788		
Formaldehyde <sup>i</sup>	50-00-0	Ald	0.815	55	9	9	40	30	8
n-Hexane	110-54-3	Alka	0.284			7000	600		
Naphthalene	91-20-3	Arom	0.191			9			0.7
Phenol	108-95-2	Alc	0.260	5800		200			
2-Propanol (Isopropanol)	67-63-0	Alc	0.407	3200		7000			
2-Propanone (Acetone)	67-64-1	Ket	0.421				26,000	13,000	13,000
Styrene	100-42-5	Arom	0.235	21,000		900	2000		200
Tetrachloroethene (Tetrachloroethylene, Perchloroethylene)	127-18-4	Halo	0.147	20,000		35	200		40
Toluene	108-88-3	Arom	0.265	37,000		300	1000		80
1,1,1-Trichloroethane (Methyl chloroform)	71-55-6	Halo	0.183	68,000		1000	2000	700	
Trichloroethene (Trichloroethylene)	79-01-6	Halo	0.186			600	2000	100	
Vinyl chloride	75-01-4	Halo	0.391	180,000			500	30	
Xylene isomers	1330-20-7	Arom	0.230	22,000		700	2000	600	50

a. Alc = alcohol; Ethr = ether; Gly = glycol; ether; Ket = ketone; Ald = aldehyde; Est = acetates and other esters; Acid = carboxylic acid; Alka = alkane; HC = alkene; HC = alkene; Cyel = cyclic; HC = aromatic; HC; Arom = aromatic; HC; Terp = terpene; HC; Arom = aromatic; HC; ClAro = chlorinated aromatic; HC; Halo = halogenated aliphatic; HC; Misc = miscellaneous category  
b. Conversion factors from  $\mu\text{g}/\text{m}^3$ -to-ppb  
c. Exposure averaging time is 1 hour  
d. Exposure averaging time is 8 hours and which may be repeated  
e. Designed to address continuous exposures for up to a lifetime; the exposure metric used is the annual average exposure  
f. Exposure to a chemical for a duration of 14 days or less, as specified in the toxicological profiles  
g. Exposure to a chemical for a duration of 15-364 days, as specified in the toxicological profiles  
h. Exposure to a chemical for 365 days or more, as specified in the toxicological profiles  
i. See also Tables C-1 and C-2 for additional guidance on formaldehyde.

## **POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

### **About ASHRAE**

ASHRAE, founded in 1894, is a global society advancing human well-being through sustainable technology for the built environment. The Society and its members focus on building systems, energy efficiency, indoor air quality, refrigeration, and sustainability. Through research, Standards writing, publishing, certification and continuing education, ASHRAE shapes tomorrow's built environment today.

For more information or to become a member of ASHRAE, visit [www.ashrae.org](http://www.ashrae.org).

To stay current with this and other ASHRAE Standards and Guidelines, visit [www.ashrae.org/standards](http://www.ashrae.org/standards).

### **Visit the ASHRAE Bookstore**

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, on CD-ROM, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at [www.ashrae.org/bookstore](http://www.ashrae.org/bookstore).

### **IMPORTANT NOTICES ABOUT THIS STANDARD**

**To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit [www.ashrae.org/standards](http://www.ashrae.org/standards) to download them free of charge.**

**Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.**