

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1f – 1st Public Review Draft. Based on a review of the economic justification of unheated slab-on-grade insulation requirements, the Project Committee determined that the requirements should be modified. This addendum raises the boundary for such insulation applications from 7200 HDD65 (4000 HDD18) to above 9000 HDD65 (5000 HDD18).

Addendum 90.1f

APPENDIX B: Revise the unheated slab-on-grade floor criteria for residential spaces as follows:

Table B-19 (I-P): ~~F-0.540, R-10.0 for 24 in.~~ F-0.730, NR
Table B-20 (I-P): ~~F-0.540, R-10.0 for 24 in.~~ F-0.730, NR
Table B-19 (SI): ~~F-0.930, R-1.8 for 61 cm~~ F-1.260, NR
Table B-20 (SI): ~~F-0.930, R-1.8 for 61 cm~~ F-1.260, NR