

**ANSI/ASHRAE Addendum i to
ANSI/ASHRAE Standard 15-2007**



ASHRAE STANDARD

Safety Standard for Refrigeration Systems

Approved by the ASHRAE Standards Committee on June 24, 2009; by the ASHRAE Board of Directors on June 24, 2009; and by the American National Standards Institute on July 22, 2009.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site, <http://www.ashrae.org>, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**
1791 Tullie Circle NE, Atlanta, GA 30329
www.ashrae.org

ASHRAE Standing Standard Project Committee 15
Cognizant TCs: TC 10.1, Custom Engineered Refrigeration Systems, and
TC 9.1, Large Building Air-Conditioning Systems
SPLS Liaison: Byron W. Jones

Phillip A. Johnson, *Chair**

Stephen W. Duda, *Secretary**

Wayne K. Borrowman

Jim Caylor

Ajay R. Chatlani*

Danny M. Halel*

Jay A. Kohler*

Brian J. Rodgers

Jeffery M. Shapiro*

Daryl K. Showalter

Martin L. Timm*

Ronald P. Vallort

John I. Vucci*

Claude E. Wilkinson

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2008–2009

Hugh F. Crowther, *Chair*

Steven T. Bushby, *Vice-Chair*

Robert G. Baker

Michael F. Beda

Donald L. Brandt

Paul W. Cabot

Kenneth W. Cooper

Samuel D. Cummings, Jr

K. William Dean

Martin Dierycxk

Robert G. Doerr

Allan B. Fraser

Nadar R. Jayaraman

Byron W. Jones

Jay A. Kohler

Carol E. Marriott

Merle F. McBride

Frank Myers

H. Michael Newman

Janice C. Peterson

Douglas T. Reindl

Lawrence J. Schoen

Boggarm S. Setty

Bodh R. Subherwal

William F. Walter

Michael W. Woodford

David E. Knebel, *BOD ExO*

Andrew K. Persily, *CO*

Stephanie Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

There has been an increasing global trend in the use of flammable refrigerants in refrigeration systems where such use is appropriately controlled to limit safety risks. Standards for safety are evolving to define the allowable uses of flammable refrigerants (for example, in refrigerator and freezer applications, see Underwriters Laboratories standard UL 60335-2-24, International Standard IEC 60335-2-24 and IEC 60335-2-89). In these standards, the use of small amounts of flammable refrigerants is permitted, but only in conjunction with product testing for safety conducted by a recognized and approved testing laboratory or inspection agency, and the maintenance of listed product status with such organizations.

ASHRAE Standard 15-2007, Section 7.5.3, allows the use of Group A3 refrigerants where approved by the authority having jurisdiction (AHJ). Small portable cooling appliances and/or self-contained refrigeration systems are generally not regulated by the model codes that form the basis for most local

regulation (see the 2006 International Mechanical Code, Section 106.2). Requiring specific local approvals from the AHJ for systems using small amounts of flammable refrigerant charge would be impractical, and inconsistent with national code practice. This addendum allows the use of such systems through an exception to Section 7.5.3.

Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and strikethrough (for deletions).

Addendum i to Standard 15-2007

Add an additional exception, Exception "c," to Section 7.5.3 as shown below.

7.5.3 Higher Flammability Refrigerants. Group A3 and B3 refrigerants shall not be used except where approved by the authority having jurisdiction.

Exceptions:

- a. This restriction does not apply to laboratories with more than 100 ft² (9.3 m²) of space per person.
- b. This restriction does not apply to industrial occupancies.
- c. This restriction does not apply to listed portable-unit systems containing no more than 0.331 lb (150 g) of Group A3 refrigerant, provided that the equipment is installed in accordance with the listing and the manufacturer's installation instructions.

**POLICY STATEMENT DEFINING ASHRAE'S CONCERN
FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.