

**ERRATA SHEET FOR FIRST PRINTING AND REPRINT 2/02**  
**ANSI/ASHRAE/IESNA STANDARD 90.1-2001 (I-P edition)**  
**Energy Standard for Buildings Except Low-Rise Residential Buildings**

**May 21, 2002**

The corrections listed in this errata sheet apply to the first printing and reprint of ANSI/ASHRAE/IESNA Standard 90.1-2001, I-P edition. The outside back cover marking identifying the reprint is “86245 PC 2/02” and is blank for the first printing.

**NOTICE:** ASHRAE now has a list server for Standing Standards Project Committee 90.1 (SSPC 90.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard and the User’s Manual is available. To sign up for the list server please visit **Standards List Servers** on the Standards and Codes section of the ASHRAE website at <http://www.ashrae.org/STANDARDS/listservers.htm>.

**Page    Erratum**

- Inside Cover    **ASHRAE/IESNA Standard Project Committee 90.1-2001.** Correct the spelling of “Larry Spielvogel, *Chair*”.
- 51    **Table 7.2.2, Performance Requirements for Water Heating Equipment.** In the third column titled **Subcategory or Rating Condition**, add “≥20 gal” for electric resistance water heaters so that it reads “Resistance ≥20 gal”.
- 95    **Normative Appendix B.** At the end of the existing paragraph, add the following: “The following definitions apply: ci = continuous insulation (see Section 3.2), NR = no (insulation) requirements.”
- 127    **Normative Appendix C, Section C6.8.2, Cooling Factor.** In Equation C-14, in the equation for CLG, change “G<sub>2</sub>” to “G<sup>2</sup>”.