

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2019,  
Safety Standard for Refrigeration Systems**

**June 11, 2019**

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15-2019. The outside back cover marking identifying the first printing is “Product code: 86015 5/19”.

**Page    Erratum**

**14**    **Table 8-2 Level 1 Ventilation Rate for Class 2L Refrigerants.** In Column two of Table 8-1 change item a as shown below.  
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

a. 0.5 ft<sup>3</sup>/min per ft<sup>2</sup> ~~ft<sup>3</sup>~~ (2.54 L/s per m<sup>3</sup>) of *machinery room* area or