

**ERRATA SHEET FOR  
ANSI/ASHRAE/ICC/USGBC/IES STANDARD 189.1-2017  
Standard for the Design of High-Performance Green Buildings  
Except Low-Rise Residential Buildings**

**July 25, 2019**

The corrections listed in this errata sheet apply to all printings of ANSI/ASHRAE/ICC/USGBC/IES Standard 189.1-2017. Shaded items have been added since the previously published errata sheet dated March 22, 2019 was distributed.

**NOTICE:** ASHRAE now has a list server for Standing Standard Project Committee 189.1 (SSPC 189.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard is available. To sign up for the list server please visit **Project Committee List Servers for Standard** on the Technology / Standards section of the ASHRAE website at <https://www.ashrae.org/technical-resources/standards-and-guidelines/project-committee-list-servers>.

**Page(s)   Erratum**

- 27**    **7.4.3.4 Economizers.** Revise Section 7.4.3.4, Exception (a), as shown below.  
*(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~)*

**7.4.3.4 Economizers.**

[...]

- a. Where the alternate ~~reduced~~ renewables approach defined in Section 7.4.1.1.2<sup>1</sup> is used, ANSI/ASHRAE/IES Standard 90.1, Section 6.5.1, Exception (910), shall be permitted to eliminate the economizer requirement, provided the requirements in ANSI/ASHRAE/IES Standard 90.1, Table 6.5.1-23, are applied to the efficiency requirements required by Section 7.4.1.1.2. If the standard renewable approach is chosen as defined in Section 7.4.1.1.1 then the requirements in ANSI/ASHRAE/IES Standard 90.1, Table 6.5.1-23, shall be applied to the efficiency requirements in ANSI/ASHRAE/IES Standard 90.1, Tables 6.8.1-1 through 6.8.1-11.

- 29**    **7.4.3.10.4 Ventilation Control.** In the last sentence in Section 7.4.3.10.4 change the reference to “Section 8.3.1.6” to “Section 8.3.1.9” so it reads as shown below.

In conjunction with the *automatic* ventilation shutoff, and *automatic* preoccupancy purge cycle shall provide *outdoor air* ventilation as specified in Section 8.3.1.9.

- 29**    **7.4.4.1 Equipment efficiency for the Alternate Renewables Approach.** In Section 7.4.4.1 change “Table B-9” to “Table B-8”.

- 40**    **8.3.1.9 Guest Room Preoccupancy Outdoor Air Purge Cycle.** In Section 8.3.1.9 change “Section 7.4.3.9.4” to “Section 7.4.3.10.4”.

- 41**    **8.3.3.2.4 Interior Background Noise – Testing.** In Section 8.3.3.2.4 change the reference to Section 10.3.1.1.5 to Section 10.3.1.1.2.

- 42     **8.3.3.3.3 Interior Sound Transmission – Testing.** In Section 8.3.3.3.3 change the reference to Section 10.3.1.1.5 to Section 10.3.1.1.2.
- 42     **8.3.3.5.2 Property Line Sound Levels – Testing.** In Section 8.3.3.5.2 change the reference to Section 10.3.1.1.5.1.3 to Section 10.3.1.1.2.1.3.
- 46     **8.4.1.2 Minimum Sidelighting Effective Aperture for Office Spaces and Classrooms.**  
Revise the title of Section 8.4.1.2 as shown below.  
(Note: Deletions are shown in ~~strikethrough~~.)
- 8.4.1.2 Minimum Sidelighting Effective Aperture for Office Spaces and Classrooms.**
- 134    **H4.4.1 Equipment Efficiency for the Alternate Renewables Approach.** In Section H4.4.1 change “Table B-9” to “Table B-8”.