

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 29-2015
Method of Testing Automatic Ice Makers**

June 30, 2016

The corrections listed in this errata sheet apply to the first printing of ANSI/ASHRAE Standard 29-2015 identified on the outside back cover as “Product code: 86115 5/159”.

Page	Erratum
-------------	----------------

- | | |
|----------|--|
| 7 | TABLE A-2 Net Cooling Effect for Ice Sample. Change the equation in item 16 to read as follows. The “+ (10)” in the equation should be changed to “- (10)”. |
|----------|--|

16. Average temperature difference between room and water during ice melt period =
 $[(9) + (5) - (6) - (10)]/2$