

ERRATA SHEET FOR ANSI/ASHRAE STANDARD 41.6-1994 (RA 2006)
Standard Method for Measurement of Moist Air Properties

September 6, 2011

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 41.6-1994 (RA 2006). The first printing is identified on the outside back cover as “86104 2/06” and the second printing is identified as “Product Code: 86104 8/09”.

Page Erratum

13 **7.2.6 Enthalpy.** Replace the equation in Section 7.2.6 with the following:

$$h \approx 1.005t + W(2500.9 + 1.805t), \text{ kJ/kg of dry air.}$$