

**INTERPRETATION IC 90.1-2001-6 OF
ANSI/ASHRAE/IESNA STANDARD 90.1-2001
Energy Standard for Buildings Except Low-Rise Residential Buildings**

Revision Approved: April 22, 2002

Originally issued as interpretation of Standard 90.1-1999 on June 25, 2001 (IC 90.1-1999-7), but revised based on the publication of 90.1-2001. Revisions made to all Background, Question and Answer statements to reflect Standard 90.1-2001 language.

Request from: Jay Enck, CH2M HILL, 115 Perimeter Center Place, NE, Suite 700, Atlanta, GA 30346 (E-mail: <mailto:jenck@ch2m.com>)

Reference: This request for interpretation refers to the requirements presented in ANSI/ASHRAE/IESNA Standard 90.1-2001, Section 5.5.3.4, Vestibules.

Background: Section 5.5.3.4 requires enclosed vestibules for doors that separate conditioned space from the exterior. Several exceptions to Section 5.5.3.4 are given. Exception C states that “Doors not intended to be used as a building entrance door” are not required to have a vestibule.

Interpretation: A door that is not a main public entrance to the building is not required to have a vestibule. A controlled access door that opens to a patio which does not have egress from the building’s exterior would not be considered a building entrance door and therefore would not require a vestibule.

Question: Is this interpretation correct?

Answer: Yes.

Comments: None.