



CARBON BUSTERS

ASHRAE LowDown Showdown

2021 Building Performance Analysis Conference

Building Type: Residential Care Center

Total Floor Area: 75,000 ft2

Location: Puerto Rico

Total Site Energy Usage

2,340,000 kBtu

Site EUI

31 kBtu/ft2

Source EUI

-26 kBtu/ft2

Total Operational Carbon

- kgCO2e/ft2

Total Energy Storage Capacity

500,000 kBtu

Annual Water Usage

- Gallons

Annual Energy Costs

- \$/ft2

Annual Water Costs

- \$/ft2

Total Annual Costs


- \$/ft2

Total Energy Generation

4,300,000 kBtu

Team

Energy Modeling/Engineering Abbott Price	Architect Brian Ugartechea
Energy Modeling/Engineering Anthony Thompson	Architect James Paxson
Energy Modeling/Engineering Joaquin Font	Architect Renso Valerio
Energy Modeling/Engineering Laura Wu	





Design Description


The project is situated on the northern coast of Vieques, a small island located east of mainland Puerto Rico. Our site sits in the Quebrada Cofi Valley located about a half mile west of the dense city center of the Isabell II Barrio. Puerto Rico is an island that is no stranger to natural disasters and Vieques, located further east of the mainland, receives the brunt of damages when it comes to hurricanes and tropical storms. In our site selection, we wanted to directly respond to the under-resourced and more vulnerable part of Puerto Rico. The site aims to serve as an additional hub between the mainland and Vieques’ smaller local communities who need refuge or passage in times of emergency.

Energy Savings Strategies

This building is to be powered solely by renewable energy: PV, tidal, and offshore wind. The renewable energy generation is designed with enough capacity to power the building in an isolated manner during emergencies for 3 months, while also still exporting surplus renewable energy to the local community! Based on 2-axis tracking in this region, the average annual AC energy density is approximately 334 kWh/m^2, yielding an average annual energy production of 1,250,000 kWh/yr using 90% of the roof for solar. The secondary form of power production shall be an off-shore wind turbine. The hub height, 94 meters, and rotor diameter, 95 meters, were optimized in relation to one another to produce an annual energy production of ~10,000,000 kWh/year at a SPB of 1.05 years. Lastly, a series of ten, 10m diameter, tidal turbines are located in the current beneath the wind turbine, optimized to fit within the footprint of the wind turbine. In total, 3,000,000 kWh/yr of tidal energy can be produced at a SPB of 2.1 years. The building is designed to use approximately 2,342,000 kBtu/year of electricity while producing 4,298,000 kBtu/yr of electricity, making it net energy positive by nearly a factor of 2! Excess energy can be exported to the local community, or stored onsite with H2O electrolyzers as hydrogen to be used later by Fuel Cells. All AHUs are dedicated outdoor air systems that provide ventilation air to the zones. Dual regenerative core air-side energy recovery allows for latent and sensible heat recovery of up to 95% in the winter, removing the need for humidification, and reducing the supplemental heating load to the point where it can be satisfied using waste heat. A second desiccant wheel has been added for reheat or added dehumidification. Heat recovery chillers are used to balance simultaneous heating and cooling loads. All units are over-sized in order to meet the needs of an extreme heat event or period of extended cold weather. All supplemental heating and cooling shall come from the same heat pumps, which shall reject or reclaim heat from heat exchangers connected to the local water.




Site EUI



Solar Energy: 3,735 m2 2-axis tracking array
Peak: 561 kW
Annual: 1,250,000 kWh



Offshore Wind Energy: One 91m Diameter Turbine
Peak: 1,142 kW
Annual: 10,000,000 kWh



Tidal Energy: Ten(10) 10m Diameter Turbines
Peak: 86 kW
Annual: 750,000 kWh