

Errata: Parametric Study of Single-Pipe Diffusers in Stratified Chilled Water Storage Tanks

Jing Song
Student Member ASHRAE

William P. Bahnfleth, PhD, PE
Member ASHRAE

John M. Cimbala, PhD

The two lines at the top of page 350 currently read:

...definitions of inlet width for the axisymmetric and three-dimensional cases are consistent if l is formally defined as the ratio of inlet area to inlet perimeter.

This should read:

...definitions of inlet width for the axisymmetric and three-dimensional cases are consistent if l is defined to be twice the inlet area divided by the inlet perimeter length (i.e., the hydraulic radius).