

Errata to
Water-Cooled Servers—Common Designs, Components, and Processes (whitepaper)
(2019)

October 10, 2019

Page 20: In the TCS column of Table 1, the Total Hardness should be <20 ppm and not <0 ppm.

For online access to these errata as well as updates to other publications, visit www.ashrae.org/publicationupdates.

Please notify ASHRAE of any other errors you might find by using the Comment on Publications form at www.ashrae.org/resources--publications.

