



# ADDENDA

**ANSI/ASHRAE Addenda a, b, and c to  
ANSI/ASHRAE Standard 145.2-2011**

# **Laboratory Test Method for Assessing the Performance of Gas-Phase Air-Cleaning Systems: Air-Cleaning Devices**

Approved by the ASHRAE Standards Committee on June 28, 2014; by the ASHRAE Board of Directors on July 2, 2014; and by the American National Standards Institute on July 3, 2014.

These addenda were approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or in paper form from the Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2014 ASHRAE

ISSN 1041-2336



**ASHRAE Standing Standard Project Committee 145**  
**Cognizant TC: TC 2.3, Gaseous Air Contaminants and Gas-Containment Removal Equipment**  
**SPLS Liaison: Charles S. Barnaby**

Kathleen Owen, *Chair\**

Matt Middlebrooks, *Vice Chair\**

Carolyn M. L. Kerr, *Secretary\**

Nick H. Agopian\*

Peter Freeman\*

Sanjeev K. Hingorani\*

Chang-Seo Lee\*

Paula J. Levasseur\*

Kartik Potukuchi\*

David A. Schaaf, Jr.\*

W. Brad M. Stanley\*

*\*Denotes members of voting status when the document was approved for publication*

---

**ASHRAE STANDARDS COMMITTEE 2013–2014**

William F. Walter, *Chair*

Richard L. Hall, *Vice-Chair*

Karim Amrane

Joseph R. Anderson

James Dale Aswegan

Charles S. Barnaby

Steven F. Bruning

John A. Clark

Waller S. Clements

David R. Conover

John F. Dunlap

James W. Earley, Jr.

Steven J. Emmerich

Julie M. Ferguson

Krishnan Gowri

Cecily M. Grzywacz

Rita M. Harrold

Adam W. Hinge

Debra H. Kennoy

Malcolm D. Knight

Rick A. Larson

Mark P. Modera

Cyrus H. Nasser

Janice C. Peterson

Heather L. Platt

Douglas T. Reindl

Julia A. Keen, *BOD ExO*

Thomas E. Werkema, Jr., *CO*

Stephanie C. Reiniche, *Manager of Standards*

---

**SPECIAL NOTE**

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

**FOREWORD**

In Table 6.1.4.1, the same compound is listed under two names: 2-butanone and MEK. This addendum fixes the dou-

ble entry. It also changes the table so that two different concentrations are no longer required for the same test.

**Note:** In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~strike through~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

**Addendum a to Standard 154.2-2011**

*Modify Table 6.1.4.1 as follows. All other values remain unchanged.*

**TABLE 6.1.4.1 Standard Test Challenge Gases**

Category / Chemical	CAS #	MW*	Low Conc. (ppb)	High Conc. (ppm)	NIOSH REL TWA (ppm)**	OSHA PEL TWA (ppm)**	High Conc. Rationale ***	Capacity Used****	Required Chemical
[ ... ]									
VOCs									
[ ... ]									
2-Butanone ( <u>MEK</u> )	78-93-3	72.1	400	65	200	200	AA	20%, z	
[ ... ]									
<del>MEK</del>	<del>78-93-3</del>	<del>72.1</del>	400	30	200	<del>200</del>	<del>AA</del>	10%, z	
[ ... ]									

**(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)**

## FOREWORD

*This change applies to the 100% efficiency test. This test depends on the test filter absolutely not breaking through at all. Experience has shown that even filters that exceed the requirements of 22+ pounds of sorbent can break through in less than an hour when a few ppb or less can be >1% breakthrough. Since the ability of the system to measure >99% efficiency can be determined in 5 to 10 minutes, shortening the test period for the 100% efficiency test makes sense.*

**Note:** In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

### Addendum b to Standard 154.2-2011

*Modify Section 5.10 as follows.*

**5.10 100% Efficiency Filter Test and Purge Time Determination.** An initial efficiency test shall be performed using a complete air cleaner as the test device to demonstrate that the test duct and sampling system are capable of providing a >99% efficiency measurement. The possible sources of error are inward leaks of clean air, losses to the test duct wall, or sampling-system leaks and/or dead spaces. This test shall be conducted with readily sorbed contaminants and a 10 kg (22 lb) or greater high-quality sorbent with moderate grain size. The air cleaner shall be installed to be leak-free and the test contaminant chosen shall be one that is easily removed. The computed efficiency values shall be greater than 99% for the test contaminant. For the purposes of the 100% efficiency test, the initial efficiency test only needs to be run long enough to show the >99% measurement. This must include at least five downstream measurements.

**(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)**

## FOREWORD

*The standard test end point for the initial efficiency test is 1 h. However, some filters can reach 0.95 to 1.00 penetration ( $\leq 5\%$  efficiency) within this hour. Allowing the test to stop sooner makes sense for these filters. Therefore, the initial performance test is modified to allow testing to stop when the penetration exceeds 0.95.*

**Note:** In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striking through~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

### Addendum c to Standard 154.2-2011

*Modify Section 6.1.3.1 as follows.*

**6.1.3.1** The standard initial performance test shall be conducted for a period of 1 hour. At this point, the low concentration challenge gas shall be removed. The standard capacity test should begin as soon as possible after this test. For initial performance tests that reach 0.95 to 1.00 penetration ( $\leq 5\%$  efficiency) before this hour is over, the initial performance test may stop at the point where the penetration is 0.95 or higher (the efficiency is  $\leq 5\%$ ) as long as at least five downstream data points have been collected with at least three of these points showing the penetration at 0.95 or higher. Then, the standard capacity test shall begin as soon as possible.



## **POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

