

Modify Table B-7 as shown (SI).

Table B-7 Performance Requirements for Heat Rejection Equipment—Minimum Efficiency Requirements (SI)
(Supersedes Table 6.8.1-7 in ANSI/ASHRAE/IES Standard 90.1)

Equipment Type	Total System Heat Rejection Capacity at Rated Conditions	Subcategory or Rating Condition ^g	Performance Required ^{a,b,c,d,e,f,i}	Test Procedure ^h
Propeller or axial fan open-circuit cooling towers	All	35.0°C entering water 29.4°C leaving water 23.9°C entering wb	HB.56 L/(s·kW)	CTI ATC-105 and CTI STD-201RS
Centrifugal fan open-circuit cooling towers	All	35.0°C entering water 29.4°C leaving water 23.9°C entering wb	HI.86 L/(s·kW)	CTI ATC-105 and CTI STD-201RS
Propeller or axial fan closed-circuit cooling towers	All	38.9°C entering water 32.2°C leaving water 23.9°C entering wb	HI.36 <u>HI.43</u> L/(s·kW)	CTI ATC-105 and CTI STD-201RS
Centrifugal fan closed-circuit cooling towers	All	38.9°C entering water 32.2°C leaving water 23.9°C entering wb	HI.68 <u>HI.71</u> L/(s·kW)	CTI ATC-106
<u>Propeller or axial fan dry coolers (air-cooled fluid coolers)</u>	<u>All</u>	<u>46.1°C entering water</u> <u>40.6°C leaving water</u> <u>35.0°C entering db</u>	<u>HI.41</u> L/(s·kW)	<u>CTI ATC-105DS</u>
Propeller or axial fan evaporative condensers	All	Ammonia test fluid 60.0°C entering gas temperature 35.7°C condensing temperature 23.9°C entering wb	HE.26 <u>HE.54</u> COP	CTI ATC-106
Centrifugal fan evaporative condensers	All	Ammonia test fluid 60.0°C entering gas temperature 35.7°C condensing temperature 23.9°C entering wb	HE.24 <u>HE.6</u> COP	CTI ATC-106
Propeller or axial fan evaporative condensers	All	R-507A-R-448A test fluid 73.9°C entering gas temperature 40.6°C condensing temperature 23.9°C entering wb	HE.76 <u>HE.5</u> COP	CTI ATC-106
Centrifugal fan evaporative condensers	All	R-507A-R-448A test fluid 73.9°C entering gas temperature 40.6°C condensing temperature 23.9°C entering wb	HE.34 <u>HE.54</u> COP	CTI ATC-106
Air-cooled condensers	All	88 <u>87.7</u> °C entering gas temperature 52 <u>51.7</u> °C condensing temperature 88.3 <u>88.3</u> °C subcooling 35 <u>35.0</u> °C entering wbdb	HE.97 <u>HE.72</u> COP	AHRI 460

- For purposes of this table, open-circuit cooling tower performance open-circuit cooling tower performance is defined as the water flow rating of the tower at the thermal rating condition listed in Table B-7 divided by the fan motor nameplate power.
- For purposes of this table, ~~closed-circuit cooling tower performance~~ "closed-circuit cooling tower performance" is defined as the process water flow rating of the tower at the thermal rating condition listed in Table B-7 divided by the sum of the fan motor nameplate power and the integral spray pump motor nameplate power.
- For purposes of this table, ~~evaporative condenser performance~~ "evaporative condenser performance" is defined as the heat rejected at the specified rating condition in the table divided by the sum of the fan motor nameplate power and the integral spray pump nameplate power.
- For purposes of this table, "dry-cooler performance" is defined as the process water flow rating of the unit at the thermal rating condition listed in Table B-7 divided by the total fan motor nameplate power of the unit, and For purposes of this table, ~~air-cooled condenser performance~~ "air-cooled condenser performance" is defined as the heat rejected from the refrigerant divided by the total fan motor nameplate power.
- The efficiencies and test procedures for both ~~open-open-circuit~~ and ~~closed-circuit cooling towers~~ ~~closed-circuit cooling towers~~ are not applicable to hybrid cooling towers that contain a combination of separate wet and dry heat exchange sections. The certification requirements do not apply to field erected cooling towers.
- All cooling towers, closed-circuit coolers, evaporative condensers, and air-cooled condensers shall comply with the minimum efficiency listed in the table for that specific type of equipment with the capacity effect of any project specific accessories and/or options included with the equipment.
- Requirements for evaporative condensers are listed with ammonia (R-717) and ~~R-507A-R-448A~~ as test fluids in the table. Evaporative condensers intended for use with ~~halo-carbon~~ refrigerants other than ~~R-507A-R-448A~~ must meet the minimum efficiency requirements listed for ~~R-507A-R-448A~~ as the test fluid.
- Informative Appendix G contains information on the referenced test procedures.
- Not applicable for air-cooled condensers applied to condenserless chillers. The air-cooled condenser and condenserless chiller shall comply with the requirements for air-cooled chillers as defined in ANSI/ASHRAE/IES Standard 90.1, Table 6.8.1-3.

**POLICY STATEMENT DEFINING ASHRAE'S CONCERN
FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

Standard 189.1 and the International Green Construction Code

Standard 189.1 serves as the complete technical content of the International Green Construction Code[®] (IgCC). The IgCC creates a regulatory framework for new and existing buildings, establishing minimum green requirements for buildings and complementing voluntary rating systems. For more information, visit www.iccsafe.org.

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous edition. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.