

**ANSI/ASHRAE/ICC/USGBC/IES Addendum aa to
ANSI/ASHRAE/ICC/USGBC/IES Standard 189.1-2023**

Standard for the Design of High-Performance Green Buildings

**Except Low-Rise
Residential Buildings**

The Complete Technical Content of the International Green Construction Code®

Approved by ASHRAE and the American National Standards Institute on September 30, 2026; by the International Code Council on September 28, 2026; by the Illuminating Engineering Society on September 23, 2026; and by the U.S. Green Building Council on September 25, 2026.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE® website (www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2026 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 189.1

Cognizant TC: 2.8, Building Environmental Impacts and Sustainability

SPLS Liaison: Rusty C. Tharp · ASHRAE Staff Liaison: Thomas Loxley

ICC Liaison: Russ Manning · IES Liaison: Mark Lien · USGBC Liaison: Wes Sullens

Donald Horn,* <i>Chair</i>	Steven J. Emmerich	Emily B. Lorenz	Michael Schmeida
Lawrence J. Schoen,* <i>Co-Vice Chair</i>	Anthony C. Floyd*	Mark P. Malkin	Terri Self
Charles N. Eley,* <i>Co-Vice Chair</i>	Ellen M. Franconi	C. Webster Marsh	Matthew Setzekorn
Josh Jacobs,* <i>Co-Vice Chair</i>	Eric Giannini	Jonathan R. McHugh*	Alexander T. Smith
Michael Jouaneh,* <i>Co-Vice Chair</i>	Anne Gire	Hailey N. Mick	Kent A. Sovocool*
Bryan Ahee	Tristan Grant*	Erik T. Miller-Klein	Dennis A. Stanke
Constantinos A. Balaras	Gregg Gress*	Brittany C. Moser*	Wayne H. Stoppelmoor*
Webly Bowles	Roger L. Hedrick*	Alyssa Mrvos	Christine A. Subasic*
Jeff Bradley*	Randall T. Higa	Saber K. Nikkho	Kyle Thompson
Ariel Brenner	Greg Johnson	Edward R. Osann*	John M. Topmiller
Frank M. Burns*	Jack Karlin	Andrew K. Persily	Martha G. VanGeem*
Glen Clapper	Paul A. Karrer	Max Puchtel	Michael Waite
Ernest A. Conrad*	Gerald J. Kettler	Tiffany Reed-Villarreal*	Lin Wang
John P. Cross*	Andrew S. Klein	Rock Ridolfi*	Theresa A. Weston*
Michael W. Cudahy*	Thomas M. Lawrence*	Jane Rohde	Daniel C. Whittet
Thomas D. Culp*	William Le Roy*	Steven Rosenstock*	Joe F. Winters*
Darryl Dixon	Hao Li	Aniruddh Roy	Jasmine Wong
Wanda D. Edwards	Richard Lord	Brent Rutherford	Jian Zhang*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2026–2027

Jennifer I. Pille, <i>Chair</i>	Jayson Bursill	Tatsuro Kobayashi	Nadja Tremblay
Justin M. Prosser, <i>Vice Chair</i>	Kelley P. Cramm	Toby K.W. Lau	Douglas K. Tucker
Anthony M. Abate	Abdel K. Darwich	Cesar L. Lim	Thomas E. Watson
Omar A. Abdelaziz	Drake Erbe	Paul A. Lindahl, Jr.	David P. Yuill
Charles S. Barnaby	Marcus Hassen	Kenneth A. Monroe	Patrick C. Marks, <i>BOD ExO</i>
John H. Bean	William M. Healy	Philip J. Naughton	Trenton S. Hunt, <i>CO</i>
Coleman L. Brumley, Jr.	Satish N. Iyengar	Michael P. Patton	
Brendon J. Burley	Derrick Knight	Rusty C. Tharp	

Ryan Shanley, *Group Manager of Codes and Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum aa updates requirements for many water using devices to use EPA WaterSense specifications. Water consumption limits are also revised for a number of devices. Specifically, clothes washers will use integrated water factor (IWF), and irrigation sprinkler bodies, irrigation controllers, and flushometer valve-type water closets will have to comply with new WaterSense requirements. Water consumption limits for dishwashers will be reduced.

Informative Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striking through~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum aa to Standard 189.1-2023

Revise Section 3 as follows.

integrated water factor (IWF): for clothes washers (residential and commercial), the quantity of per-cycle water consumption for all wash cycles divided by the volumetric capacity of the clothes washer.

~~**irrigation adequacy:** a representation of how well irrigation meets the needs of the plant material. This reflects the percentage of required water for turf or plant material supplied by rainfall and controller-scheduled irrigations.~~

~~**irrigation excess:** a representation of the amount of irrigation water applied beyond the needs of the plant material. This reflects the percentage of water applied in excess of 100% of required water.~~

water factor (WF):

- a. ~~**clothes washer (residential and commercial):** the quantity of water in gallons (litres) used to wash each cubic foot (cubic metre) of machine capacity.~~
- b. **for residential dishwashers,** the quantity of water use in gallons (~~litres~~ liters) per full machine wash and rinse cycle.

Revise Section 6.3.1.2 as follows.

6.3.1.2 Irrigation System Design. The design of the irrigation system shall be performed by an accredited or certified irrigation professional and shall be in accordance with the following:

- a. Irrigation systems
 1. Shall be based on *hydrozones*. *Turfgrass* areas shall be on their own *irrigation stations*.
 2. Shall have backflow prevention in accordance with the plumbing code.
 3. [JO] Shall have a master valve on municipally supplied water sources that allows pressurization of the irrigation mainline only when irrigation is scheduled.
 4. [JO] Shall have a flow sensor and monitoring equipment that will shut off the control valve if the flow exceeds normal flow from an *irrigation station*.
 5. Shall prevent piping from draining between irrigation events.
- b. Irrigation emission devices shall comply with ASABE/ICC 802.
- c. Irrigation sprinklers
 1. Shall not spray water directly on buildings or *hardscape* area
 2. Shall have matched precipitation rate nozzles within an *irrigation station*
 3. Shall be prohibited on landscape areas having any dimension less than 4 ft (1.2 m)
 4. Shall have an application rate less than or equal to 0.75 in. (19 mm) per hour on slopes greater than 1 unit vertical in 4 units horizontal
 5. Shall be limited to use with *turfgrass* or *ground cover* areas with vegetation maintained at 8 in. (200 mm) or less in height
 6. ~~Where of the pop-up~~ Pop-up configuration, sprinklers shall have a pop-up height of not less than 4 in. (100 mm)
 7. Sprinkler bodies shall meet the requirements of the USEPA WaterSense Specification for Spray Sprinkler Bodies.

- d. Microirrigation zones
 1. Shall be equipped with pressure regulators, filters, and flush assemblies
 2. Shall have indicators that allow confirmation of operation by visual inspection
 3. Drip emitters shall be of pressure-compensating type

Revise Section 6.3.1.3 as follows. The remainder of Section 6.3.1.3 remains unchanged.

6.3.1.3 Irrigation System Controls. Where any irrigation system for the project site uses an *automatic* controller, the system shall be controlled by a qualifying *smart controller* that uses *evapotranspiration (ET)* and weather data to adjust irrigation schedules and complies with the minimum requirements. Alternatively, the system shall be controlled by an on-site rain or moisture sensor that automatically shuts off the system after a predetermined amount of rainfall or sensed moisture in the soil. Qualifying *smart controllers* shall be labeled according to USEPA WaterSense Specification for Weather-Based Irrigation Controllers or USEPA WaterSense Specification for Soil Moisture-Based Irrigation Controllers, tested in accordance with Irrigation Association SWAT Climatologically Based Controllers, 8th Testing Protocol. ~~Smart controllers that use ET data shall provide the following irrigation amounts:~~

- a. ~~Irrigation adequacy—80% minimum ET_e~~
- b. ~~Irrigation excess—not to exceed 10% of ET_e~~

Revise Section 6.3.2.1 as follows. The remainder of Section 6.3.2.1 remains unchanged.

6.3.2.1 Plumbing Fixtures and Fittings. Plumbing fixtures (water closets and urinals) and fittings (faucets and showerheads) shall comply with the following requirements, as shown in Table 6.3.2.1:

- a. Water Closets (toilets)—Flushometer Valve Type: Flushometer valve-type water closets shall be certified to the performance criteria of the USEPA WaterSense Specification for Flushometer-Valve Water Closets. For single-flush, maximum flush volume shall be determined in accordance with ASME A112.19.2/CSA B45.1 and shall not exceed 1.28 gal (4.8 L). For dual-flush, the full-flush volume shall not exceed 1.28 gal (4.8 L) per flush. ~~Dual-flush fixtures shall also comply with the provisions of ASME A112.19.14.~~
- b. Water Closets (toilets)—Tank-Type: Tank-type water closets shall be certified to the performance criteria of the USEPA WaterSense Tank-Type Toilet Specification and shall have a maximum full-flush volume of 1.28 gal (4.8 L). ~~Dual-flush fixtures shall also comply with the provisions of ASME A112.19.14.~~

Revise Section 6.3.2.2 as follows:

6.3.2.2 Appliances

- a. Clothes washers and dishwashers installed within dwelling units shall comply with the ENERGY STAR® Program Requirements for Clothes Washers and ENERGY STAR Program Requirements Product Specification for Residential Dishwashers. Maximum water use shall be as follows:
 1. Clothes washers (residential)—Maximum integrated water factor (IWF) ~~(WF)~~ of 5.4–4.3 gal/ft³ of drum capacity ~~(0.72–0.57 L/L of drum capacity).~~
 2. Dishwashers—Standard-size dishwashers shall have a maximum WF of 3.8–3.2 gal/full operating cycle ~~(4.3–12.1 L/full operating cycle).~~ Compact sizes shall have a maximum WF of 3.5–2.0 gal/full operating cycle ~~(4.3–7.0 L/full operating cycle).~~ Standard and compact size shall be defined by ENERGY STAR criteria.
- b. Clothes washers installed in publicly accessible *spaces* (**Informative Note:** e.g., multifamily and hotel common areas), and coin- and card-operated clothes washers of any size used in laundromats, shall have a maximum IWF of 4.0 gal/ft³ of drum capacity normal cycle (0.53 L/L of drum capacity normal cycle).
- c. Commercial dishwashers in commercial food-service facilities shall ~~meet all ENERGY STAR requirements as listed in~~ comply with the ENERGY STAR Program Requirements for Commercial Dishwashers.

Revise Section 6.3.2.5 as follows:

6.3.2.5 Commercial Food Service Operations. (**Informative Note:** e.g., restaurants, cafeterias, food preparation kitchens, caterers, etc.). Commercial food service operations

- a. Shall use high-efficiency prerinse spray valves (i.e., valves that function at 1.3 gpm [4.9 L/min] or less and comply with a 26 second performance requirement when tested in accordance with ASTM F2324).
- b. Shall use dishwashers that comply with the requirements of the ENERGY STAR Program for Commercial Dishwashers.

- c. Shall use boilerless/connectionless food steamers that consume no more than 2.0 gal/h (7.5 L/h) in the full operational mode.
- d. Shall use combination ovens that comply with the requirements of the ENERGY STAR Program Requirements for Commercial Ovens ~~consume not more than 10 gal/h (38 L/h) in the full operational mode.~~
- e. Shall use air-cooled ice machines that comply with the requirements of the ENERGY STAR Program for Commercial Ice Makers.
- f. Shall be equipped with hands-free faucet controllers (foot controllers, sensor activated, or other) for all faucet fittings within the food preparation area of the kitchen and the dish room, including pot sinks and washing sinks.

Revise references in Section 11 as follows:

Reference	Title	Section
American Society of Mechanical Engineers (ASME) Three Park Avenue New York, NY 10016-5990, United States? 1-800-843-2763 and 1-973-882-1170; www.asme.org		
ASME A112.19.2-2018-2024/CSA B45.1-18-24	Ceramic Plumbing Fixtures	6.3.2.1
ASME A112.19.14 2013 (R2018)	Six Liter Water Closets Equipped with a Dual-Flushing Device	6.3.2.1
United States Environmental Protection Agency (USEPA) 1200 Pennsylvania Avenue, NW? Washington, DC 20460, United States www.epa.gov ENERGY STAR® (www.energystar.gov) WaterSense (www.epa.gov/watersense)		
<u>Version 1.0, February 2021</u>	<u>WaterSense Specification for Soil Moisture-Based Irrigation Controllers</u>	<u>6.3.1.3</u>
<u>Version 1.0, September 21, 2017</u>	<u>WaterSense Specification for Spray Sprinkler Bodies</u>	<u>6.3.1.2</u>
<u>Version 1.0, December 17, 2015</u>	<u>WaterSense Specification for Flushometer-Valve Water Closets</u>	<u>6.3.2.1</u>
<u>Version 1.1, September 2, 2021</u>	<u>WaterSense Specification for Weather-Based Irrigation Controllers</u>	<u>6.3.1.3</u>
Version 1.2 2.0, June 2, 2014 <u>May 2024</u>	<u>WaterSense Specification for Tank-Type Toilets-</u> Specification	6.3.2.1
Version 3.0, April 12, 2022	ENERGY STAR Program Requirements for Commercial Ovens	<u>6.3.2.5, 7.4.7.2</u>

**POLICY STATEMENT DEFINING ASHRAE'S CONCERN
FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

Standard 189.1 and the International Green Construction Code

Standard 189.1 serves as the complete technical content of the International Green Construction Code[®] (IgCC). The IgCC creates a regulatory framework for new and existing buildings, establishing minimum green requirements for buildings and complementing voluntary rating systems. For more information, visit www.iccsafe.org.

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous edition. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.