

ADDENDA

**ANSI/ASHRAE/IBPSA Addendum g to
ANSI/ASHRAE Standard 209-2018**

Energy Simulation Aided Design for Buildings Except Low-Rise Residential Buildings

Approved by ASHRAE and the American National Standards Institute on August 30, 2024, and by the International Building Performance Simulation Association on August 28, 2024.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE® website (www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2024 ASHRAE

ISSN 1041-2336



International
Building
Performance
Simulation
Association



ASHRAE Standing Standard Project Committee 209

Cognizant TC: 4.7, Energy Calculations

SPLS Liaison: Phillip A Johnson

Jason J. Glazer*, <i>Chair</i>	Clark R. Denson*	Christina M. LaPerle*	Eddy Santosa*
Drury B. Crawley*, <i>Vice Chair</i>	Shivraj Dhaka	Walter R. Lenzi, Sr.	Michael Sawford*
Erik P. Kolderup*, <i>Secretary</i>	Cory Duggin	Vrushali Mendon*	Christopher R. Schaffner*
Henry R. Amistadi	Ross C. Farris	Alexander Mitchell*	Huanan Shen
Shaheen Asif	Brendan Gardes*	Alimohammad Motavaselian	Justin S. Shultz
Christopher B. Baker*	Elliott K. Glazer	Demba Ndiaye*	Aaron R. Smith*
Heather Ray Beaudoin*	David Goldwasser*	Patrick Pease	Meziane Touati
Mahabir S. Bhandari*	Krishnan Gowri*	Emir A. Pekdemir*	Mohammad Wathaifi
Bill Bishop*	Edwin Guerra	John Pruett	Weili Xu
John D. Bynum	Alberto Hernandez-Neto	Sagar U. Rao*	
Yu Chen*	Daniel A. Katzenberger*	Vaibhav Rai Khare	
Adrian Chong	Ji Hyun Kim	David J. Reddy	

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2024–2025

Douglas D. Fick, <i>Chair</i>	Jennifer A. Isenbeck	Kenneth A. Monroe	Paolo M. Tronville
Adrienne G. Thomle, <i>Vice Chair</i>	Jaap Hogeling	Daniel H. Nall	Douglas K. Tucker
Hoy R. Bohanon, Jr.	Satish N. Iyengar	Philip J. Naughton	William F. Walter
Kelley P. Cramm	Phillip A. Johnson	Kathleen Owen	David P. Yuill
Abdel K. Darwich	Paul A. Lindahl, Jr.	Gwelen Paliaga	Susanna S. Hanson, <i>BOD ExO</i>
Drake H. Erbe	Julie Majurin	Karl L. Peterman	Wade H. Conlan, <i>CO</i>
Patricia Graef	Lawrence C. Markel	Justin M. Prosser	
William M. Healy	Margaret M. Mathison	Christopher J. Seeton	

Ryan Shanley, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

b(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum g modifies Section 5.7, “General Modeling Cycle Requirements” (excluding Sections 5.7.4 and 5.7.5) to expand beyond cost to other metrics, to add flexibility to the requirements regarding a financial analysis, and to add informative notes/clarify the language.

Informative Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~strike through~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum g to Standard 209-2018

Modify Section 3.2 as shown.

3.2 Definitions

baseline: the building design or level of energy performance used as the basis of comparison against other project alternatives, usually based on a hypothetical design defined by energy codes/building standards, the lowest first cost option, existing conditions, standard practice, or based on the ~~currently proposed current~~ building design at the time of modeling cycle analysis.

Modify Section 5.7 as shown.

5.7 General Modeling Cycle Requirements. This section lists requirements that are common to all of the *modeling cycles* included within the standard. Cycle-specific requirements are included in their respective sections.

5.7.1 Energy Baselines and Goals. Prior to engaging a specific *modeling cycle*, review and update the following project-level items:

- a. The *baseline* or *baselines* used for comparison during energy analysis
- b. The energy performance goals as reported in Section 5.6.4

5.7.2 Input Data

5.7.2.1 Prior to each *modeling cycle*, the *project team* shall discuss the purpose, input data, and analysis methodology for each *modeling cycle*.

5.7.2.2 The input data necessary to perform the analysis, in conjunction with the purpose and goals of each *modeling cycle*, shall be gathered by the *energy modeler* and jointly supplied by the *project team*.

5.7.2.3 Where project-specific modeling inputs are provided, they shall be used in place of ~~assumptions or simulation program default inputs.~~ user-defined assumptions, simulation program default inputs, or modeling inputs from Informative Appendix C.

Informative Note: It is important to clearly document all assumptions, including those related to plug and process equipment for other members of the design team. These assumptions may significantly affect equipment sizing and energy consumption. In addition, for predictive analysis, special consideration should be given to input values such as weather, occupant behavior, plug/process loads, and overlooked loads. See Informative Appendix X, “Predictive Energy Modeling,” for more details.

5.7.2.4 Input data shall be subject to quality assurance review as described in Section 5.7.4.2.

5.7.2.5 ~~When a modeling cycle requires the comparison of project alternatives, the project team shall identify the first-cost implications of each alternative. This shall include calculation of the incremental costs of individual strategies or bundles of strategies relative to a baseline cost. Include added construction costs as well as reductions in construction costs due to the~~ If first-cost implications of project alternatives are provided by the project team, the cost estimates shall include the impact of downsizing or elimination of building systems, such as in the case of alternatives that reduce heating or cooling loads.

~~**Exception to 5.7.2.5:** Quantification of first-cost impacts are not required for the Simple Box Modeling Cycles #1, and are only required for all modeling cycles if they are required by the owner/owner representative.~~

5.7.3 Reporting. At a minimum, provide the following information, and explicitly display all units of measure.

5.7.3.1 Narrative. For each *modeling cycle*, provide a written narrative of the following items:

- a. A discussion of energy consumption results and a comparison of the modeling results to the energy performance goal.
- b. A discussion of the impact to the building peak heating and cooling loads
- c. A financial analysis of the overall costs and savings if first cost implications of project alternatives are provided by the project team.
- d. Discussion of areas of uncertainty in the analysis
- e. Recommendations for building design strategies and acceptance, rejection, or modification of alternatives that were analyzed
- f. Recommendations for additional analysis
- g. Discussion of the impact on future maintenance and operations.

5.7.3.2 Input Data Reporting. For each *modeling cycle*, provide the following information:

- a. Project title
- b. Project location and weather station name and type
- c. A narrative description of the building, including use type, occupancy, *gross floor area*, conditioned floor area, number of stories, occupancy pattern or patterns, internal loads, and schedules
- d. *Simulation program* and version
- e. A narrative description of the *energy model baseline*, including discussion of why the selected *baseline* is appropriate for the current analysis (if applicable)
- f. Utility rates, greenhouse gas emission factors, site to source ratios as applicable
- g. A narrative description of any on-site energy generation
- h. For each *project alternative*, provide a narrative description of the alternative, including analysis methodology utilized, relevant *baseline*, and proposed parameters and values
- i. A summary table of the major *energy modeling* inputs

Informative Note: See Informative Appendix E for a list of *energy modeling inputs*.

5.7.3.3 Output Data Reporting. For the *baseline*, and for each *project alternative*, report the following annual results:

- a. Total *site energy* consumption
- b. Total *site energy* consumption per unit *gross floor area*
- c. *Site energy* consumption by *energy end use*
- d. Total energy cost, greenhouse gas emissions, source energy as applicable
- e. Consumption by *energy source*
- f. Cost, greenhouse gas emissions, source energy by *energy source as applicable*
- g. Peak cooling demand and time of occurrence (date, day of week, day type, hour)
- h. Peak heating demand and time of occurrence (date, day of week, day type, hour)
- i. Calendar month peak electric demand and time of occurrence (date, day of week, day type, hour)
- j. Calendar month peak energy consumption by *energy source*
- k. Unmet heating and cooling load hours
- l. Construction cost as determined per Section 5.7.2.5 as applicable
- m. On-site energy generation as applicable
- n. Any other modeling output relevant to the project performance goals.

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

ASHRAE · 180 Technology Parkway · Peachtree Corners, GA 30092 · www.ashrae.org

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.