

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1n – Publication Draft.

This wording is now consistent with the requirement found in Section 6.1.3(n). It allows gravity dampers for small exhaust and outdoor air intakes.

Addendum 90.1n

Exceptions to 6.2.3.2.4:

- (a) Gravity (non-motorized) dampers are acceptable in buildings less than 3 stories in height and for buildings of any height located in climates with less than 2700 HDD65 (1500 HDD18).
- (b) Gravity (non-motorized) dampers are acceptable in systems with a design outside air intake or exhaust capacity of 300 cfm (140 L/s) or less ~~that are equipped with motor operated dampers that open and close when the unit is energized and de-energized, respectively.~~