

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1z –Publication Draft. This addendum clarifies the language and intent of the standard. Requirements are unchanged

Addendum 90.1z

9.3.2 Exterior Building Lighting Power The exterior building facade lighting power shall not exceed 0.25 W/ft^2 of the illuminated area. The exterior lighting power allowance for all other exterior building applications is the sum of the lighting power limits permitted and specified in Table 9.3.2 for these applications. Exterior lighting for all applications (except those included in the exceptions to 9.1 and 9.3.2) shall comply with the requirements of 9.2.6.

**Table 9.3.2
Lighting Power Limits for Building Exteriors**

Applications	Power Limits
<i>Building entrance with canopy or free standing canopy</i>	3 W/ft ² (32.4 W/m ²) of canopied area
<i>Building entrance without canopy</i>	33 W/lin ft (108.3 W/lin m) of door width
<i>Building exit</i>	20 W/lin ft (65.6 W/lin m) of door width