ADDENDA

Informative Addendum ch to ANSI/ASHRAE/IES Standard 90.1-2019

Energy Standard for Buildings Except Low-Rise Residential Buildings

This addendum makes editorial changes to the standard.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE[®] website (https://www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway NW, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2024 ASHRAE ISSN 1041-2336



© ASHRAE. Per international copyright law, additional reproduction, distribution, or transmission in either

print or digital form is not permitted without ASHRAE's prior written permission. ASHRAE Standard Project Committee 90.1

ASHRAE Standard Project Committee 90.1 Cognizant TC: 7.6 Systems Energy Utilization SPLS Liaison: Charles Barnaby ASHRAE Staff Liaisons: Emily Toto IES Liaison: Mark Lien

Donald Brundage*, Chair Thomas Culp*, Co-Vice Chair Richard Lord*, Co-Vice Chair Rahul Athalye William Babbington John Bade* Sean Beilman* **Kyle Bergeron** Jeffrey Boldt* Scott Campbell Elizabeth Cassin Paula Cino* Glen Clapper Ernest Conrad* Jay Crandell* Brandon Damas* Julie Donovan* Craig Drumheller* **David Fouss** Phillip Gentry Jason Glazer*

Melissa Goren* Krishnan Gowri Aaron Gunzner David Handwork* David Herron* Armin Hauer Gary Heikkinen Mark Heizer Scott Hintz* **Emily Hoffman** Mike Houston* Jonathan Humble* Michael Ivanovich Harold Jepsen Greg Johnson Chad Johnson Duane Jonlin* Michael Jouaneh Maria Karpman* Andrew Klein Vladimir Kochkin

Michael Lane* Toby Lau Chonghui Liu Joel Martell* Christopher Mathis* Merle McBride James McClendon* Benjamin Meyer* Darren Meyers Harry Misuriello Frank Morrison* Michael Myer Frank Myers* James C. Moore Michael Patterson* Timothy Peglow* Tien Peng Amber Wood* Laura Petrillo-Groh* Catherine Rivest Michael Rosenberg*

Steven Rosenstock* Loren Ross Robert Ross* Marty Salzberg* Greg Schluterman Amy Schmidt Leonard Sciarra* Kelly Seeger* Sean Smith Wayne Stoppelmoor* Matthew Swenka Christian Taber* Steven Taylor* **Douglas Tucker** Martha VanGeem* McHenry Wallace* Jerry White* Jeremiah Williams*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2021-2022

Rick M. Heiden, *Chair* Susanna S. Hanson, *Vice-Chair* Charles S. Barnaby Robert B. Burkhead Thomas E. Cappellin Douglas D. Fick Michael W. Gallagher Patricia Graef Srinivas Katipamula Gerald J. Kettler Essam E. Khalil Malcolm D. Knight Jay A. Kohler Cesar L. Lim Paul A. Lindahl, Jr. James D. Lutz Julie Majurin Lawrence C. Markel Margret M. Mathison Gwelen Paliaga Justin M. Prosser David Robin Lawrence J. Schoen Steven C. Sill Christian R. Taber Russell C. Tharp William F. Walter Craig P. Wray Jaap Hogeling, BOD ExO Tim J. McGinn, CO

Connor Barbaree, Senior Manager of Standards

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary. In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. ANSI is a registered trademark of the American National Standards Institute. (This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum ch adds informative appendix to support jurisdictions and beyond-code programs that choose to use Normative Appendix G compliance metrics other than energy cost. The appendix includes building performance factor (BPF) tables based on site energy, source energy, or carbon emissions to replace the cost-based BPF values currently used. The alternate BPF values are calculated using national average values consistent with the current national average energy costs used for electricity and natural gas.

The new appendix also includes a methodology for calculating custom BPFs for jurisdictions and beyond-code programs that choose to use local energy conversion factors for the selected metric in lieu of default values included in the appendix. The regulated electricity and natural gas, annual site energy of each Pacific Northwest National Laboratory (PNNL) prototype was converted to a series of coefficients for each building type and climate zone. The methodology used to calculate the coefficients follows the same methodology that was previously used to calculate the cost-based BPF values. Using Equation X-1, the energy conversion factors in Table X5-1, and the coefficients in Tables X5-2 through X5-4, the reported BPF values in Tables X3-1 through X3-3 can be recreated. Similarly, a jurisdiction may create their own set of BPF values using local energy costs or alternative metrics. Carbon emissions conversion factors in Table X5-1 reflect values in ANSI/ASHRAE/ICC/USGBC/IES Standard 189-2020.

Finally, the Appendix includes an example of how a jurisdiction would amend ASHRAE/IES Standard 90.1 language to adopt alternate compliance metrics. The example shows the proper changes using strikethrough and underline.

The information include in this Appendix improves the usability of Normative Appendix G by allowing jurisdictions greater flexibility to establish BPF values that align with local compliance goals.

This addendum impacts an optional performance path in the standard designed to provide increased flexibility and therefore was not subjected to cost effectiveness analysis.

Note: In this addendum, changes to the current standard are indicated in the text by <u>underlining</u> (for additions) and strikethrough (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum ch to Standard 90.1-2019

Modify Section 4.2.1.1 as shown (I-P and SI).

4.2.1 Compliance Paths

4.2.1.1 New Buildings. New *buildings* shall comply with Sections 4.2.2 through 4.2.5 and either the provisions of

- a. Section 5, "Building Envelope"; Section 6, "Heating, Ventilating, and Air Conditioning"; Section 7, "Service Water Heating"; Section 8, "Power"; Section 9, "Lighting"; and Section 10, "Other Equipment," or
- b. Section 11, "Energy Cost Budget Method," or
- c. Normative Appendix G, "Performance Rating Method."

When using Normative Appendix G, the Performance Cost Index (PCI) of new *buildings*, *additions* to *existing buildings*, and/or *alterations* to *existing buildings* shall be less than or equal to the Performance Cost Index Target (PCI*t*) when calculated in accordance with the following:

[...]

<u>Informative Note:</u> See Informative Appendix X for using other metrics, including site *energy*, source *energy*, and carbon emissions, in conjunction with the Normative Appendix G Performance Rating Method when approved by the *rating authority*.

Modify Section G1.2.2 as shown (I-P and SI).

G1.2.2 Performance Rating Calculation. The performance of the *proposed design* is calculated in accordance with provisions of this appendix using the following formula:

Performance Cost Index = Proposed building performance/Baseline building performance

Both the *proposed building performance* and the *baseline building performance* shall include all end-use load components within and associated with the *building* when calculating the Performance Cost Index.

[...]

<u>Informative Note:</u> See Informative Appendix X for using other metrics, including site *energy*, source *energy*, and carbon emissions, in conjunction with the Normative Appendix G Performance Rating Method when approved by the *rating authority*.

Add a new Informative Appendix X to the standard ("X" is a placeholder). (Note: Areas highlighted in light gray indicate portions of the addenda where underline and strikethrough do not indicate a change but rather are intended to be illustrative.)

INFORMATIVE APPENDIX X USING OTHER METRICS IN CONJUNCTION WITH APPENDIX G PERFORMANCE RATING METHOD WHEN APPROVED BY THE RATING AUTHORITY

X1. GENERAL

This informative appendix describes changes to Section 3, Section 4, and Appendix G for using metrics other than *energy* cost—including site *energy*, source *energy*, and carbon emissions—that may be adopted by the *rating authority* for the Normative Appendix G Performance Rating Method. It also provides methodology for determining *building* performance factors (BPFs) that should be used in conjunction with custom *energy* conversion factors other than the national average defaults in Table X5-1.

X2. CHANGES TO SECTION 3

Replace references to "annual *energy* cost" with the reference to the selected metric in the definitions of *baseline building performance* and *proposed building performance*.

X3. CHANGES TO SECTION 4

- a. <u>Replace all references to "energy cost" in Section 4.2.1.1 with "site energy," "source energy," or</u> <u>"carbon emissions," as appropriate, throughout.</u>
- b. <u>Replace all references to "Performance Cost Index" in Section 4.2.1.1 with "Performance Index</u> (Site *Energy*)," "Performance Index (Source *Energy*)," or "Performance Index (Carbon Emissions)," as appropriate throughout.
- c. For site energy, replace Table 4.2.1.1 with Table X3-1.
- d. For carbon emissions, replace Table 4.2.1.1 with Table X3-2.
- e. For source energy, replace Table 4.2.1.1 with Table X3-3

X4. CHANGES TO APPENDIX G

- a. <u>Replace references to "energy cost" with references to site "energy," "source energy," or "carbon</u> emissions" as appropriate in Sections G1.2.2, G1.3.2, G2.1, G2.5 and G2.4.2 section heading.
- b. <u>Remove the first sentence and informative note in Section G2.4.2</u>, and replace it with the conversion factors from Table X4-1 for the selected metric.
- c. Add an exception to Section G2.4.2 to allow using alternative conversion factors as appropriate for *building* location and as approved by the *adopting authority*.

X5. METHODOLOGY FOR BPF ADJUSTMENT TO ACCOUNT FOR LOCALIZED CONVERSION FACTORS

The BPF values in Table 4.2.1.1, based on *energy* cost, and the values in Tables X3-1, X3-2, and X3-3 are based on the coefficients in Tables X5-2 through X5-4 and the electricity and fossil fuel conversion factors in Table X5-1. The values in Table X5-1 represent U.S. national average values.

The U.S. national conversion factors may not be appropriate for all locations, and some jurisdictions may want to adopt custom conversion factors other than those shown in Table X5-1. When *energy* conversion factors other than those specified in Table X5-1 are used, the BPFs should also be updated in accordance with Equation X-1.

	<u>Climate Zone</u>																		
<u>Building Area Type</u>	<u>0A</u>	<u>0B</u>	<u>1A</u>	<u>1B</u>	<u>2A</u>	<u>2B</u>	<u>3A</u>	<u>3B</u>	<u>3C</u>	<u>4A</u>	<u>4B</u>	<u>4C</u>	<u>5A</u>	<u>5B</u>	<u>5C</u>	<u>6A</u>	<u>6B</u>	<u>7</u>	<u>8</u>
Multifamily	<u>0.72</u>	<u>0.71</u>	<u>0.75</u>	<u>0.73</u>	<u>0.76</u>	<u>0.76</u>	<u>0.77</u>	<u>0.75</u>	<u>0.70</u>	<u>0.61</u>	<u>0.71</u>	<u>0.64</u>	<u>0.56</u>	<u>0.63</u>	<u>0.63</u>	<u>0.54</u>	<u>0.57</u>	<u>0.54</u>	<u>0.56</u>
Healthcare/hospital	<u>0.67</u>	<u>0.66</u>	<u>0.68</u>	<u>0.65</u>	<u>0.65</u>	<u>0.61</u>	<u>0.62</u>	<u>0.64</u>	<u>0.63</u>	<u>0.62</u>	<u>0.63</u>	<u>0.61</u>	<u>0.65</u>	<u>0.63</u>	<u>0.68</u>	<u>0.64</u>	<u>0.68</u>	<u>0.69</u>	<u>0.71</u>
Hotel/motel	<u>0.69</u>	<u>0.69</u>	<u>0.72</u>	<u>0.68</u>	<u>0.69</u>	<u>0.68</u>	<u>0.69</u>	<u>0.70</u>	<u>0.71</u>	<u>0.65</u>	<u>0.69</u>	<u>0.68</u>	<u>0.63</u>	<u>0.66</u>	<u>0.67</u>	<u>0.60</u>	<u>0.64</u>	<u>0.59</u>	<u>0.58</u>
Office	<u>0.54</u>	<u>0.54</u>	<u>0.53</u>	<u>0.52</u>	<u>0.52</u>	<u>0.52</u>	<u>0.50</u>	<u>0.54</u>	<u>0.47</u>	<u>0.47</u>	<u>0.52</u>	<u>0.48</u>	<u>0.49</u>	<u>0.52</u>	<u>0.49</u>	<u>0.48</u>	<u>0.50</u>	<u>0.43</u>	<u>0.46</u>
Restaurant	<u>0.64</u>	<u>0.61</u>	<u>0.60</u>	<u>0.59</u>	<u>0.60</u>	<u>0.57</u>	<u>0.61</u>	<u>0.62</u>	<u>0.61</u>	<u>0.66</u>	<u>0.65</u>	<u>0.66</u>	<u>0.69</u>	<u>0.69</u>	<u>0.68</u>	<u>0.71</u>	<u>0.71</u>	<u>0.72</u>	<u>0.74</u>
Retail	<u>0.51</u>	<u>0.49</u>	<u>0.48</u>	<u>0.48</u>	<u>0.44</u>	<u>0.43</u>	<u>0.43</u>	<u>0.44</u>	<u>0.44</u>	<u>0.47</u>	<u>0.45</u>	<u>0.50</u>	<u>0.52</u>	<u>0.47</u>	<u>0.52</u>	<u>0.52</u>	<u>0.50</u>	<u>0.48</u>	<u>0.49</u>
School	<u>0.52</u>	<u>0.57</u>	<u>0.57</u>	<u>0.56</u>	<u>0.52</u>	<u>0.53</u>	<u>0.53</u>	<u>0.52</u>	<u>0.55</u>	<u>0.42</u>	<u>0.49</u>	<u>0.53</u>	<u>0.44</u>	<u>0.50</u>	<u>0.51</u>	<u>0.43</u>	<u>0.42</u>	<u>0.42</u>	<u>0.44</u>
Warehouse	<u>0.26</u>	<u>0.26</u>	<u>0.22</u>	<u>0.25</u>	<u>0.21</u>	<u>0.22</u>	<u>0.25</u>	<u>0.21</u>	<u>0.18</u>	<u>0.38</u>	<u>0.27</u>	<u>0.31</u>	<u>0.46</u>	<u>0.37</u>	<u>0.31</u>	<u>0.49</u>	<u>0.42</u>	<u>0.43</u>	<u>0.47</u>
All others	<u>0.63</u>	<u>0.62</u>	<u>0.65</u>	<u>0.61</u>	<u>0.56</u>	<u>0.53</u>	<u>0.55</u>	<u>0.55</u>	<u>0.59</u>	<u>0.55</u>	<u>0.55</u>	<u>0.58</u>	<u>0.57</u>	<u>0.57</u>	<u>0.61</u>	<u>0.57</u>	<u>0.57</u>	<u>0.56</u>	<u>0.58</u>

Table X3-1 Building Performance Factors (BPF), Site Energy

Table X3-2	Building	Performance	Factors	(BPF).	Carbon Emission
				_	

		<u>Climate Zone</u>																	
Building Area Type	<u>0A</u>	<u>0B</u>	<u>1A</u>	<u>1B</u>	<u>2A</u>	<u>2B</u>	<u>3A</u>	<u>3B</u>	<u>3C</u>	<u>4A</u>	<u>4B</u>	<u>4C</u>	<u>5A</u>	<u>5B</u>	<u>5C</u>	<u>6A</u>	<u>6B</u>	<u>7</u>	<u>8</u>
Multifamily	<u>0.71</u>	<u>0.69</u>	<u>0.73</u>	<u>0.71</u>	<u>0.74</u>	<u>0.74</u>	<u>0.74</u>	<u>0.75</u>	<u>0.67</u>	<u>0.64</u>	<u>0.73</u>	<u>0.67</u>	<u>0.60</u>	<u>0.67</u>	<u>0.66</u>	<u>0.59</u>	<u>0.61</u>	<u>0.58</u>	<u>0.60</u>
Healthcare/hospital	<u>0.68</u>	<u>0.67</u>	<u>0.69</u>	<u>0.67</u>	<u>0.66</u>	<u>0.63</u>	<u>0.64</u>	<u>0.65</u>	<u>0.63</u>	<u>0.63</u>	<u>0.65</u>	<u>0.62</u>	<u>0.66</u>	<u>0.64</u>	<u>0.67</u>	<u>0.65</u>	<u>0.67</u>	<u>0.69</u>	<u>0.70</u>
Hotel/motel	<u>0.67</u>	<u>0.67</u>	<u>0.70</u>	<u>0.66</u>	<u>0.67</u>	<u>0.66</u>	<u>0.66</u>	<u>0.68</u>	<u>0.68</u>	<u>0.64</u>	<u>0.67</u>	<u>0.65</u>	<u>0.63</u>	<u>0.65</u>	<u>0.65</u>	<u>0.61</u>	<u>0.63</u>	<u>0.59</u>	<u>0.58</u>
Office	<u>0.54</u>	<u>0.54</u>	<u>0.53</u>	<u>0.52</u>	<u>0.52</u>	<u>0.52</u>	<u>0.50</u>	<u>0.54</u>	<u>0.48</u>	<u>0.47</u>	<u>0.52</u>	<u>0.48</u>	<u>0.49</u>	<u>0.52</u>	<u>0.49</u>	<u>0.48</u>	<u>0.50</u>	<u>0.45</u>	<u>0.47</u>
Restaurant	<u>0.63</u>	<u>0.60</u>	<u>0.59</u>	<u>0.58</u>	<u>0.58</u>	<u>0.55</u>	<u>0.59</u>	<u>0.58</u>	<u>0.56</u>	<u>0.61</u>	<u>0.60</u>	<u>0.60</u>	<u>0.64</u>	<u>0.63</u>	<u>0.62</u>	<u>0.66</u>	<u>0.66</u>	<u>0.68</u>	<u>0.70</u>
Retail	<u>0.51</u>	<u>0.49</u>	<u>0.48</u>	<u>0.48</u>	<u>0.44</u>	<u>0.43</u>	<u>0.43</u>	<u>0.43</u>	<u>0.44</u>	<u>0.44</u>	<u>0.44</u>	<u>0.48</u>	<u>0.47</u>	<u>0.45</u>	<u>0.49</u>	<u>0.47</u>	<u>0.46</u>	<u>0.45</u>	<u>0.47</u>
<u>School</u>	<u>0.52</u>	<u>0.57</u>	<u>0.57</u>	<u>0.56</u>	<u>0.52</u>	<u>0.53</u>	<u>0.53</u>	<u>0.51</u>	<u>0.52</u>	<u>0.44</u>	<u>0.48</u>	<u>0.50</u>	<u>0.45</u>	<u>0.48</u>	<u>0.48</u>	<u>0.45</u>	<u>0.43</u>	<u>0.43</u>	<u>0.45</u>
Warehouse	<u>0.26</u>	<u>0.26</u>	<u>0.22</u>	<u>0.25</u>	<u>0.21</u>	<u>0.22</u>	<u>0.25</u>	<u>0.21</u>	<u>0.18</u>	<u>0.31</u>	<u>0.24</u>	<u>0.27</u>	<u>0.38</u>	<u>0.31</u>	<u>0.26</u>	<u>0.41</u>	<u>0.36</u>	<u>0.37</u>	<u>0.41</u>
<u>All others</u>	<u>0.63</u>	<u>0.61</u>	<u>0.63</u>	<u>0.60</u>	<u>0.55</u>	<u>0.52</u>	<u>0.54</u>	<u>0.54</u>	<u>0.57</u>	<u>0.54</u>	<u>0.53</u>	<u>0.56</u>	<u>0.55</u>	<u>0.55</u>	<u>0.58</u>	<u>0.56</u>	<u>0.56</u>	<u>0.55</u>	<u>0.56</u>

Table X3-3 Building Performance Factors (BPF), Source Energy

	<u>Climate Zone</u>																		
Building Area Type	<u>0A</u>	<u>0B</u>	<u>1A</u>	<u>1B</u>	<u>2A</u>	<u>2B</u>	<u>3A</u>	<u>3B</u>	<u>3C</u>	<u>4A</u>	<u>4B</u>	<u>4C</u>	<u>5A</u>	<u>5B</u>	<u>5C</u>	<u>6A</u>	<u>6B</u>	7	<u>8</u>
Multifamily	<u>0.70</u>	<u>0.69</u>	<u>0.72</u>	<u>0.71</u>	<u>0.73</u>	<u>0.73</u>	<u>0.73</u>	<u>0.75</u>	<u>0.65</u>	<u>0.66</u>	<u>0.74</u>	<u>0.69</u>	<u>0.63</u>	<u>0.69</u>	<u>0.68</u>	<u>0.61</u>	<u>0.63</u>	<u>0.60</u>	<u>0.63</u>
Healthcare/hospital	<u>0.69</u>	<u>0.68</u>	<u>0.70</u>	<u>0.67</u>	<u>0.66</u>	<u>0.64</u>	<u>0.64</u>	<u>0.66</u>	<u>0.64</u>	<u>0.64</u>	<u>0.65</u>	<u>0.63</u>	<u>0.66</u>	<u>0.64</u>	<u>0.66</u>	<u>0.66</u>	<u>0.67</u>	<u>0.68</u>	<u>0.70</u>
Hotel/motel	<u>0.66</u>	<u>0.67</u>	<u>0.70</u>	<u>0.66</u>	<u>0.66</u>	<u>0.65</u>	<u>0.65</u>	<u>0.67</u>	<u>0.66</u>	<u>0.63</u>	<u>0.66</u>	<u>0.64</u>	<u>0.62</u>	<u>0.64</u>	<u>0.64</u>	<u>0.61</u>	<u>0.62</u>	<u>0.59</u>	<u>0.58</u>
Office	<u>0.54</u>	<u>0.54</u>	<u>0.53</u>	<u>0.52</u>	<u>0.52</u>	<u>0.52</u>	<u>0.50</u>	<u>0.54</u>	<u>0.48</u>	<u>0.47</u>	<u>0.53</u>	<u>0.48</u>	<u>0.49</u>	<u>0.52</u>	<u>0.49</u>	<u>0.48</u>	<u>0.50</u>	<u>0.45</u>	<u>0.47</u>
Restaurant	<u>0.63</u>	<u>0.59</u>	<u>0.58</u>	<u>0.57</u>	<u>0.58</u>	<u>0.54</u>	<u>0.58</u>	<u>0.56</u>	<u>0.54</u>	<u>0.59</u>	<u>0.57</u>	<u>0.57</u>	<u>0.61</u>	<u>0.60</u>	<u>0.59</u>	<u>0.64</u>	<u>0.62</u>	<u>0.65</u>	<u>0.68</u>
Retail	<u>0.51</u>	<u>0.49</u>	<u>0.48</u>	<u>0.48</u>	<u>0.44</u>	<u>0.43</u>	<u>0.43</u>	<u>0.43</u>	<u>0.44</u>	<u>0.43</u>	<u>0.43</u>	<u>0.47</u>	<u>0.45</u>	<u>0.43</u>	<u>0.48</u>	<u>0.45</u>	<u>0.45</u>	<u>0.43</u>	<u>0.45</u>
<u>School</u>	<u>0.52</u>	<u>0.57</u>	<u>0.57</u>	<u>0.56</u>	<u>0.52</u>	<u>0.53</u>	<u>0.53</u>	<u>0.50</u>	<u>0.51</u>	<u>0.44</u>	<u>0.47</u>	<u>0.49</u>	<u>0.46</u>	<u>0.47</u>	<u>0.47</u>	<u>0.45</u>	<u>0.43</u>	<u>0.44</u>	<u>0.45</u>
Warehouse	<u>0.26</u>	<u>0.26</u>	<u>0.22</u>	<u>0.25</u>	<u>0.21</u>	<u>0.22</u>	<u>0.25</u>	<u>0.21</u>	<u>0.18</u>	<u>0.28</u>	<u>0.23</u>	<u>0.25</u>	<u>0.34</u>	<u>0.28</u>	<u>0.25</u>	<u>0.37</u>	<u>0.32</u>	<u>0.34</u>	<u>0.37</u>
All others	<u>0.62</u>	<u>0.61</u>	<u>0.63</u>	<u>0.60</u>	<u>0.55</u>	<u>0.52</u>	<u>0.54</u>	<u>0.53</u>	<u>0.56</u>	<u>0.54</u>	<u>0.53</u>	<u>0.56</u>	<u>0.54</u>	<u>0.54</u>	<u>0.57</u>	<u>0.55</u>	<u>0.55</u>	<u>0.55</u>	<u>0.56</u>

Table X4-1 Energy Conversion Factors (see Note 1)

<u>Building Project Energy</u> <u>Source</u>	<u>Units</u>	<u>Carbon Emissions CO_{2e}. lb/unit (kg/unit)</u>	<u>Site Energy.</u> <u>Btu/unit (kWh/unit)</u> <u>(see Note 2)</u>	<u>Source Energy.</u> <u>Btu/unit (kWh/unit)</u>
Electricity	<u>kWh</u>	<u>1.205 (0.547)</u>	<u>3,412 (1.000)</u>	<u>9,008 (2.64)</u>
Natural gas	Therm (GJ)	<u>19.960 (85.833)</u>	<u>100,000 (277.778)</u>	<u>109,000 (302.778)</u>
Propane	Therm (GJ)	<u>19.080 (76.367)</u>	<u>100,000 (277.778)</u>	<u>115,000 (319.445)</u>
Distillate fuel oil	<u>Gallon (L)</u>	28.330 (13.077)	<u>137,600 (10.651)</u>	<u>163,744 (12.674)</u>

Notes:

1. These conversions are based on national averages for the United States and may not be representative for other locations. Jurisdictions that choose to use localized conversion factors for source *energy* or carbon emissions should update the corresponding BPF table for consistency using methodology in Section X5. Jurisdictions may add conversion factors for other *energy* sources.

2. Site *energy* only accounts for *energy* as measured at the building site. It does not account for the *energy* consumed in the extraction, processing, and transport of primary *energy*, nor *energy* consumed in conversion to electricity in power-generation plants.

Table X5-1	National Average	Energy Conversion	Factors Used to Calculat	e BPF

<u>Metric</u>	Site Energy	<u>Carbon Emissions CO_{2e}</u>	Source Energy	<u>Energy Cost</u>
Units	<u>site kBtu/site kBtu</u> (site kWh/site kWh)	<u>lb/site kBtu</u> (kg/site kWh)	<u>source kBtu/site kBtu</u> (source kWh/site kWh)	<u>\$/site kBtu</u> (\$/site kWh)
Electric conversion factors	<u>1.0</u>	<u>0.353 (0.547)</u>	<u>2.64</u>	<u>0.03221 (0.1099)</u>
Natural gas conversion factors	<u>1.0</u>	<u>0.200 (0.309)</u>	<u>1.090</u>	0.00802 (0.02737)

Table X5-2 Coefficient A Values

Ruilding									<u>C1</u>	imate Zo	one								
Area Type	<u>0A</u>	<u>0B</u>	<u>1A</u>	<u>1B</u>	<u>2A</u>	<u>2B</u>	<u>3A</u>	<u>3B</u>	<u>3C</u>	<u>4A</u>	<u>4B</u>	<u>4C</u>	<u>5A</u>	<u>5B</u>	<u>5C</u>	<u>6A</u>	<u>6B</u>	<u>7</u>	<u>8</u>
Multifamily	<u>0.3006</u>	<u>0.3261</u>	<u>0.4321</u>	<u>0.4064</u>	<u>0.5158</u>	<u>0.5445</u>	<u>0.7128</u>	<u>0.6952</u>	<u>1.1709</u>	<u>1.1302</u>	<u>0.8644</u>	<u>1.2685</u>	<u>1.5138</u>	<u>1.1288</u>	<u>1.3067</u>	<u>1.7228</u>	<u>1.5398</u>	<u>1.8543</u>	<u>2.1737</u>
Healthcare/ hospital	<u>0.1250</u>	<u>0.1412</u>	<u>0.1507</u>	<u>0.1544</u>	<u>0.1979</u>	<u>0.1602</u>	<u>0.2319</u>	<u>0.2098</u>	<u>0.2688</u>	<u>0.3262</u>	<u>0.2596</u>	<u>0.3865</u>	<u>0.4926</u>	<u>0.3624</u>	<u>0.5972</u>	<u>0.6143</u>	<u>0.6194</u>	<u>0.8438</u>	<u>1.0747</u>
Hotel/motel	<u>0.2711</u>	<u>0.2833</u>	<u>0.3267</u>	<u>0.3373</u>	<u>0.3922</u>	<u>0.4544</u>	<u>0.5143</u>	<u>0.6042</u>	<u>0.6922</u>	<u>0.8420</u>	<u>0.7668</u>	<u>0.9723</u>	<u>1.0639</u>	<u>0.9353</u>	<u>1.0888</u>	<u>1.2454</u>	<u>1.1995</u>	<u>1.4783</u>	<u>1.9709</u>
Office	<u>0.0000</u>	<u>0.0425</u>	<u>0.0105</u>	<u>0.2479</u>	<u>0.0868</u>	<u>0.2155</u>	<u>0.4409</u>	<u>0.2496</u>	<u>0.2634</u>	<u>0.6874</u>	<u>0.5018</u>	<u>0.6405</u>	<u>0.9613</u>						
Restaurant	<u>0.2210</u>	<u>0.2418</u>	<u>0.3366</u>	<u>0.3120</u>	<u>0.3984</u>	<u>0.4813</u>	<u>0.5416</u>	<u>0.8752</u>	<u>1.0794</u>	<u>1.8987</u>	<u>1.3855</u>	<u>2.0956</u>	<u>2.9552</u>	<u>2.1791</u>	<u>2.6220</u>	<u>3.7419</u>	<u>3.1353</u>	<u>4.8743</u>	<u>7.2168</u>
Retail	0.0000	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	<u>0.0509</u>	<u>0.0056</u>	<u>0.4874</u>	<u>0.1141</u>	<u>0.3074</u>	<u>0.8526</u>	<u>0.3748</u>	<u>0.3778</u>	<u>1.1246</u>	<u>0.6886</u>	<u>1.1802</u>	<u>1.5119</u>
School	<u>0.0346</u>	<u>0.0368</u>	<u>0.0447</u>	<u>0.0461</u>	<u>0.0581</u>	<u>0.0703</u>	<u>0.0791</u>	<u>0.2052</u>	<u>0.2586</u>	<u>0.3806</u>	<u>0.3220</u>	<u>0.7076</u>	<u>0.6664</u>	<u>0.6527</u>	<u>0.7928</u>	<u>0.9529</u>	<u>0.7842</u>	<u>1.1857</u>	<u>2.0419</u>
Warehouse	0.0000	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	0.0000	<u>0.0000</u>	<u>0.1323</u>	<u>0.0158</u>	<u>2.6058</u>	<u>0.8393</u>	<u>1.2916</u>	4.6583	<u>2.2657</u>	<u>1.2302</u>	<u>6.2218</u>	<u>3.8034</u>	<u>5.9278</u>	<u>6.3860</u>
All others	<u>0.1552</u>	<u>0.1668</u>	<u>0.2257</u>	<u>0.2050</u>	<u>0.1784</u>	<u>0.1568</u>	<u>0.2015</u>	<u>0.3111</u>	<u>0.4107</u>	<u>0.7223</u>	<u>0.3880</u>	<u>0.7372</u>	<u>1.0594</u>	<u>0.7105</u>	<u>0.7100</u>	<u>1.2640</u>	<u>0.9793</u>	<u>1.2947</u>	<u>1.8802</u>

Table X5-3 Coefficient B Values

	<u>Climate Zone</u>																		
Building Area Type	<u>0A</u>	<u>0B</u>	<u>1A</u>	<u>1B</u>	<u>2A</u>	<u>2B</u>	<u>3A</u>	<u>3B</u>	<u>3C</u>	<u>4A</u>	<u>4B</u>	<u>4C</u>	<u>5A</u>	<u>5B</u>	<u>5C</u>	<u>6A</u>	<u>6B</u>	<u>7</u>	<u>8</u>
Multifamily	<u>1.472</u>	<u>1.504</u>	<u>1.440</u>	<u>1.472</u>	<u>1.434</u>	<u>1.433</u>	<u>1.455</u>	<u>1.318</u>	<u>1.701</u>	<u>1.314</u>	<u>1.263</u>	<u>1.305</u>	<u>1.283</u>	<u>1.259</u>	<u>1.288</u>	<u>1.248</u>	<u>1.278</u>	<u>1.251</u>	<u>1.153</u>
Healthcare/hospital	<u>1.423</u>	<u>1.437</u>	<u>1.400</u>	<u>1.449</u>	<u>1.475</u>	1.506	<u>1.510</u>	<u>1.492</u>	<u>1.546</u>	<u>1.520</u>	<u>1.505</u>	<u>1.548</u>	<u>1.483</u>	<u>1.519</u>	<u>1.572</u>	<u>1.483</u>	<u>1.513</u>	<u>1.488</u>	<u>1.447</u>
Hotel/motel	<u>1.547</u>	<u>1.545</u>	<u>1.480</u>	<u>1.580</u>	<u>1.574</u>	1.623	<u>1.626</u>	<u>1.582</u>	<u>1.627</u>	<u>1.637</u>	<u>1.610</u>	<u>1.665</u>	<u>1.627</u>	<u>1.628</u>	<u>1.677</u>	<u>1.640</u>	<u>1.660</u>	<u>1.688</u>	<u>1.719</u>
Office	<u>1.855</u>	<u>1.869</u>	<u>1.900</u>	<u>1.915</u>	<u>1.913</u>	<u>1.923</u>	<u>1.982</u>	<u>1.845</u>	<u>2.058</u>	<u>2.071</u>	<u>1.883</u>	<u>2.080</u>	<u>2.040</u>	<u>1.936</u>	<u>2.089</u>	<u>2.100</u>	<u>2.033</u>	<u>2.098</u>	<u>2.031</u>
<u>Restaurant</u>	<u>1.622</u>	<u>1.724</u>	<u>1.788</u>	<u>1.807</u>	<u>1.813</u>	<u>1.978</u>	<u>1.837</u>	<u>2.036</u>	<u>2.172</u>	<u>2.086</u>	<u>2.118</u>	<u>2.219</u>	<u>2.122</u>	<u>2.164</u>	<u>2.232</u>	<u>2.113</u>	<u>2.160</u>	<u>2.156</u>	<u>2.192</u>
Retail	<u>1.961</u>	<u>2.057</u>	<u>2.078</u>	<u>2.090</u>	<u>2.286</u>	<u>2.353</u>	<u>2.345</u>	<u>2.372</u>	<u>2.296</u>	<u>2.511</u>	<u>2.360</u>	<u>2.233</u>	<u>2.573</u>	<u>2.486</u>	<u>2.187</u>	<u>2.649</u>	<u>2.516</u>	<u>2.715</u>	<u>2.525</u>
<u>School</u>	<u>1.921</u>	<u>1.748</u>	<u>1.747</u>	<u>1.778</u>	<u>1.941</u>	<u>1.901</u>	<u>1.914</u>	<u>2.074</u>	<u>2.093</u>	<u>2.102</u>	<u>2.192</u>	<u>2.275</u>	<u>2.089</u>	<u>2.256</u>	<u>2.328</u>	<u>2.073</u>	<u>2.241</u>	<u>2.102</u>	<u>2.146</u>
Warehouse	<u>3.885</u>	<u>3.804</u>	<u>4.454</u>	<u>3.994</u>	<u>4.692</u>	<u>4.591</u>	<u>3.967</u>	<u>4.884</u>	<u>5.296</u>	<u>5.724</u>	<u>5.241</u>	<u>5.472</u>	<u>6.045</u>	<u>5.572</u>	<u>5.419</u>	<u>5.962</u>	<u>5.558</u>	<u>5.935</u>	<u>5.477</u>
All others	<u>1.621</u>	<u>1.667</u>	<u>1.632</u>	<u>1.712</u>	<u>1.852</u>	<u>1.973</u>	<u>1.902</u>	<u>1.950</u>	<u>1.863</u>	<u>1.899</u>	<u>1.985</u>	<u>1.870</u>	<u>1.970</u>	<u>1.966</u>	<u>1.866</u>	<u>1.906</u>	<u>1.902</u>	<u>1.881</u>	<u>1.933</u>

Table X5-4 Coefficient C Values

Puilding									<u>C1</u>	imate Zo	one								
Area Type	<u>0A</u>	<u>0B</u>	<u>1A</u>	<u>1B</u>	<u>2A</u>	<u>2B</u>	<u>3A</u>	<u>3B</u>	<u>3C</u>	<u>4A</u>	<u>4B</u>	<u>4C</u>	<u>5A</u>	<u>5B</u>	<u>5C</u>	<u>6A</u>	<u>6B</u>	<u>7</u>	<u>8</u>
Multifamily	<u>0.3268</u>	<u>0.3547</u>	<u>0.4698</u>	<u>0.4419</u>	<u>0.5608</u>	<u>0.5921</u>	<u>0.7751</u>	<u>0.9461</u>	<u>1.3802</u>	<u>2.1938</u>	<u>1.3725</u>	<u>2.2150</u>	<u>3.1673</u>	<u>2.1109</u>	<u>2.3514</u>	<u>3.7613</u>	<u>3.2073</u>	<u>4.0765</u>	<u>4.5499</u>
Healthcare/ hospital	<u>0.2538</u>	<u>0.2952</u>	<u>0.2924</u>	<u>0.3186</u>	<u>0.3728</u>	<u>0.3966</u>	<u>0.4705</u>	<u>0.3979</u>	<u>0.4800</u>	<u>0.6318</u>	<u>0.4830</u>	<u>0.7239</u>	<u>0.8189</u>	<u>0.6407</u>	<u>0.7623</u>	<u>1.0245</u>	<u>0.8759</u>	<u>1.1802</u>	<u>1.4851</u>
Hotel/motel	<u>0.3054</u>	<u>0.3192</u>	<u>0.3674</u>	<u>0.3794</u>	<u>0.4401</u>	<u>0.5104</u>	<u>0.5758</u>	<u>0.7070</u>	<u>0.7578</u>	<u>1.1950</u>	<u>0.9496</u>	<u>1.2431</u>	<u>1.6502</u>	<u>1.2861</u>	<u>1.4319</u>	<u>2.0806</u>	<u>1.7910</u>	<u>2.4916</u>	<u>3.3918</u>
Office	<u>0.0000</u>	<u>0.0776</u>	<u>0.0890</u>	<u>0.6078</u>	<u>0.2077</u>	<u>0.4525</u>	<u>0.9224</u>	<u>0.4828</u>	<u>0.4656</u>	<u>1.4263</u>	<u>0.9818</u>	<u>1.6892</u>	<u>2.2766</u>						
Restaurant	<u>0.2876</u>	<u>0.3147</u>	<u>0.4309</u>	<u>0.4001</u>	<u>0.5043</u>	<u>0.6085</u>	<u>0.6731</u>	<u>0.9800</u>	<u>1.2400</u>	<u>2.3208</u>	<u>1.5298</u>	<u>2.4918</u>	<u>3.6117</u>	<u>2.4166</u>	<u>3.1189</u>	<u>4.5816</u>	<u>3.6641</u>	<u>5.9587</u>	<u>8.8807</u>
Retail	<u>0.0000</u>	<u>0.0268</u>	<u>0.0031</u>	<u>0.6502</u>	<u>0.1292</u>	<u>0.4050</u>	<u>1.0239</u>	<u>0.4191</u>	<u>0.4873</u>	<u>1.4196</u>	<u>0.8469</u>	<u>1.8038</u>	<u>2.5674</u>						
School	<u>0.0574</u>	<u>0.0605</u>	<u>0.0716</u>	<u>0.0734</u>	<u>0.0906</u>	<u>0.1091</u>	<u>0.1185</u>	<u>0.2332</u>	<u>0.2124</u>	<u>1.2081</u>	<u>0.5076</u>	<u>0.9354</u>	<u>1.6698</u>	<u>1.0708</u>	<u>1.1824</u>	<u>2.4336</u>	<u>1.9958</u>	<u>3.1587</u>	<u>4.7541</u>
Warehouse	0.0000	<u>0.0000</u>	0.0000	0.0000	<u>0.0000</u>	<u>0.0000</u>	0.0000	0.4289	<u>0.3731</u>	<u>3.7923</u>	1.5264	<u>1.8399</u>	<u>6.1674</u>	<u>3.2986</u>	1.7394	<u>8.7227</u>	<u>5.8554</u>	<u>10.164</u>	10.401
All others	<u>0.2029</u>	<u>0.2198</u>	<u>0.2640</u>	<u>0.2659</u>	<u>0.2354</u>	<u>0.2239</u>	<u>0.2697</u>	<u>0.4152</u>	<u>0.5288</u>	<u>1.2546</u>	<u>0.5421</u>	<u>1.1404</u>	<u>1.6641</u>	<u>1.0498</u>	<u>0.9435</u>	<u>2.0621</u>	<u>1.5669</u>	<u>2.2440</u>	<u>3.0603</u>

$$\underline{BPF}_{i,j} = (\underline{EC} + \underline{A}_{i,j} \times \underline{GC}) / (\underline{B}_{i,j} \times \underline{EC} + \underline{C}_{i,j} \times \underline{GC})$$
(X-1)

$$\underline{A_{i,j}}, \underline{B_{i,j}}, \underline{C_{i,j}} \equiv \frac{\text{coefficients from Tables X5-2, X5-3, and X5-4 for building area type i and climate}{\frac{\text{zone } j}{2}}$$

X6. SITE ENERGY USE LANGUAGE EXAMPLE

The following example shows the recommended changes to Section 3, Section 4.2.1.1, and Table 4.2.1.1, and Sections G1.2.2, G1.3.2, G2.4.2, and G2.5, if the site *energy* alternative compliance metric is adopted. Example changes are illustrated in strikethrough and underline.

Modify Section 3 as follows:

baseline building performance: the annual <u>site energy cost</u> for a *building* design intended for use as a baseline for rating above-standard design or when using the *Performance Rating Method* as an alternative path for minimum standard compliance in accordance with Section 4.2.1.1.

proposed building performance: the annual site energy cost calculated for a proposed design.

Modify Section 4.2.1.1 as follows:

When using Normative Appendix G, the Performance Cost Index (Site Energy) of new buildings, additions to existing buildings, and/or alterations to existing buildings shall be less than or equal to the Performance Cost Index Target (PCIt) when calculated in accordance with the following:

$\underline{PI}_{t} = [BBUEC + (BPF_{site} \times BBREC) - PRE]/BBP$

where		
₽ € І	=	Performance Index (Site Energy) calculated in accordance with Section G1.2.
BBUE C	-	baseline <i>building</i> unregulated <u>site energy</u> cost , the portion of the annual site energy cost of a <i>baseline building design</i> that is due to <i>unregulated energy use</i> .
BBRE	-	baseline <i>building</i> regulated <u>site</u> <i>energy</i> cost , the portion of the annual site <i>energy</i> cost of a <i>baseline building design</i> that is due to <i>regulated energy use</i> .
BPF		<i>building</i> performance factor from Table 4.2.1.1. For <i>building</i> area types not listed in Table 4.2.1.1 use "All others." Where a <i>building</i> has multiple <i>building</i> area types, the required BPF shall be equal to the area-weighted average of the <i>building</i> area types based on their <i>gross floor area</i> .
BBP	=	baseline <i>building</i> performance.

PBP	=	<i>proposed building performance</i> , including the reduced, annual <u>purchased site</u> <i>energy</i> cost associated with all <i>on-site renewable energy</i> generation systems.
PBPnre	=	<i>proposed building performance</i> without any credit for reduced annual <i>energy</i> costs from <i>on-site renewable energy</i> generation systems.
PBP _{pre}		<i>proposed building performance</i> , excluding any <i>renewable energy</i> system in the <i>proposed design</i> and including an <i>on-site renewable energy</i> system that meets but does not exceed the requirements of Section 10.5.1.1 modeled following the requirements for a budget building design in Table 11.5.1.
PRE	-	$PBP_{nre} - PBP_{pre}$

When $(PBP_{pre} - PBP)/BBP > 0.05$, new *buildings*, *additions* to *existing buildings*, and/or *alterations* to *existing buildings* shall comply with the following:

 $P \in I + [(PBP_{pre} - PBP)/BBP] - 0.05 < P \in I_t$

Regulated site *energy* cost shall be calculated by multiplying the total site *energy* cost by the ratio of *regulated energy* use to total *energy* use for each *fuel* type. Unregulated *energy* cost shall be calculated by subtracting regulated *energy* cost from total *energy* cost.

Informative Notes:

- 1. PBP_{nre} = proposed building performance, no renewable *energy*
- 2. PBP_{pre} = proposed building performance, prescriptive renewable *energy*
- 3. PRE = prescriptive renewable *energy*

<u>Replace values in Table 4.2.1.1 with the values from Table X3-1 (deleted values not shown):</u>

	Climate Zone																		
Building Area Type	0A	0B	1A	1B	2A	2B	3A	3B	3 C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
Multifamily	<u>0.72</u>	0.71	0.75	0.73	<u>0.76</u>	0.76	0.77	<u>0.75</u>	<u>0.70</u>	0.61	<u>0.71</u>	0.64	<u>0.56</u>	0.63	0.63	<u>0.54</u>	0.57	0.54	0.56
Healthcare/hospital	0.67	<u>0.66</u>	0.68	0.65	<u>0.65</u>	0.61	0.62	0.64	0.63	0.62	<u>0.63</u>	0.61	<u>0.65</u>	0.63	0.68	0.64	0.68	<u>0.69</u>	0.71
Hotel/motel	<u>0.69</u>	0.69	0.72	0.68	<u>0.69</u>	0.68	<u>0.69</u>	<u>0.70</u>	0.71	<u>0.65</u>	<u>0.69</u>	0.68	0.63	<u>0.66</u>	0.67	0.60	0.64	<u>0.59</u>	0.58
Office	<u>0.54</u>	0.54	0.53	0.52	0.52	0.52	0.50	0.54	0.47	0.47	0.52	0.48	0.49	0.52	0.49	0.48	0.50	0.43	0.46
Restaurant	0.64	0.61	0.60	<u>0.59</u>	0.60	0.57	0.61	0.62	0.61	<u>0.66</u>	<u>0.65</u>	<u>0.66</u>	<u>0.69</u>	<u>0.69</u>	0.68	0.71	0.71	0.72	0.74
Retail	0.51	<u>0.49</u>	0.48	0.48	<u>0.44</u>	0.43	0.43	0.44	0.44	0.47	0.45	<u>0.50</u>	0.52	0.47	0.52	0.52	<u>0.50</u>	0.48	0.49
School	0.52	0.57	0.57	0.56	0.52	0.53	0.53	0.52	0.55	0.42	<u>0.49</u>	0.53	0.44	0.50	0.51	0.43	0.42	0.42	0.44
Warehouse	0.26	0.26	0.22	0.25	0.21	0.22	0.25	0.21	0.18	0.38	0.27	0.31	0.46	0.37	0.31	0.49	0.42	0.43	0.47
All others	0.63	0.62	0.65	0.61	0.56	0.53	0.55	0.55	0.59	0.55	0.55	0.58	0.57	0.57	0.61	0.57	0.57	0.56	0.58

Table 4.2.1.1 Building Performance Factors (BPF). Site Energy

Modify Section G1.2.2 as follows:

The performance of the *proposed design* is calculated in accordance with provisions of this appendix using the following formula:

Performance Cost-Index =

Proposed building performance/Baseline building performance

Both the *proposed building performance* and the *baseline building performance* shall include all end-use load components within and associated with the *building* when calculating the Performance Cost-Site Energy Index.

Modify Section G1.3.2(a) and G1.3.2(p) as follows:

 $[\ldots]$

The following documentation shall be submitted to the *rating authority*:

a. The *simulation program* used, the version of the *simulation program*, and the results of the *energy* analysis including the calculated values for the baseline *building* unregulated <u>site energy</u> cost (BBUEC), baseline *building* regulated <u>site energy</u> cost (BBREC), *building* performance factor (BPF), *baseline building performance*, the *proposed building performance*, Performance <u>Cost Site Energy</u> Index (PCI), and Performance <u>Cost Site Energy</u> Index Target (PCIt).

 $[\ldots]$

p. For any exceptional calculation methods employed, document the predicted *energy* savings by *energy* type, the <u>site energy</u> cost savings, a narrative explaining the exceptional calculation method performed, and theoretical or empirical information supporting the accuracy of the method.

Modify Section G2.4.2 as follows:

G2.4.2 Annual <u>Energy Costs</u> <u>Site Energy</u>. The design energy cost and baseline energy cost shall be determined using either actual rates for *purchased energy* or state average energy prices published by DOE's Energy Information Administration (EIA) for commercial building customers, but rates from different sources may not be mixed in the same project.

<u>**G2.4.2.1**</u> The baseline building performance and proposed building performance shall be determined using conversion factors in Table G2.1.

Building Project Energy Source	<u>Units</u>	<u>Site Energy.</u> Btu/unit (W·h/unit)
Electricity	<u>kWh</u>	3,412
Natural Gas	therm (GJ)	100,000 (277,778)
Propane	therm (GJ)	100,000 (277,778)
Distillate fuel oil	<u>gal (L)</u>	137,600 (10,651)

Table G2.1 Units of Fuel to Site Energy Conversion Factors

<u>G2.4.2.2</u> Where on-site renewable energy or site-recovered energy is used, the baseline building design shall be based on the energy source used as the backup energy source, or the baseline system energy source in that category if no backup energy source has been specified, except where the baseline energy source is prescribed in Tables G3.1.1-2 and G3.1.1-3. Where the proposed design includes on-site electricity generation systems other than on-site renewable energy systems, the baseline design shall include the same generation systems excluding its site-recovered energy.

Informative Note: The above provision allows users to gain credit for features that yield load management benefits. Where such features are not present, users can simply use state average unit prices from EIA, which are updated annually and readily available on EIA's web site (http://www.cia.gov).

Modify Section G2.5(e) as follows:

[...]

e. The Performance Cost-Index calculated with and without the exceptional calculation method.

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

ASHRAE · 180 Technology Parkway NW · Peachtree Corners, GA 30092 · www.ashrae.org

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.