

ADDENDA

**ANSI/ASHRAE/IES Addendum ci to
ANSI/ASHRAE/IES Standard 90.1-2019**

Energy Standard for Buildings Except Low-Rise Residential Buildings

Approved by ASHRAE and the American National Standards Institute on April 29, 2022, and by the Illuminating Engineering Society on April 27, 2022.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE® website (<https://www.ashrae.org/continuous-maintenance>).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway NW, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2022 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 90.1
Cognizant TC: 7.6 Systems Energy Utilization
SPLS Liaison: Charles Barnaby
ASHRAE Staff Liaisons: Emily Toto
IES Liaison: Mark Lien

Donald Brundage*, <i>Chair</i>	Melissa Goren*	Michael Lane*	Steven Rosenstock*
Thomas Culp*, <i>Co-Vice Chair</i>	Krishnan Gowri	Toby Lau	Loren Ross
Richard Lord*, <i>Co-Vice Chair</i>	Aaron Gunzner	Chonghui Liu	Robert Ross*
Rahul Athalye	David Handwork*	Joel Martell*	Marty Salzberg*
William Babbington	David Herron*	Christopher Mathis*	Greg Schluterman
John Bade*	Armin Hauer	Merle McBride	Amy Schmidt
Sean Beilman*	Gary Heikkinen	James McClendon*	Leonard Sciarra*
Kyle Bergeron	Mark Heizer	Benjamin Meyer*	Kelly Seeger*
Jeffrey Boldt*	Scott Hintz*	Darren Meyers	Sean Smith
Scott Campbell	Emily Hoffman	Harry Misuriello	Wayne Stoppelmoor*
Elizabeth Cassin	Mike Houston*	Frank Morrison*	Matthew Swenka
Paula Cino*	Jonathan Humble*	Michael Myer	Christian Taber*
Glen Clapper	Michael Ivanovich	Frank Myers*	Steven Taylor*
Ernest Conrad*	Harold Jepsen	James C. Moore	Douglas Tucker
Jay Crandell*	Greg Johnson	Michael Patterson*	Martha VanGeem*
Brandon Damas*	Chad Johnson	Timothy Peglow*	McHenry Wallace*
Julie Donovan*	Duane Jonlin*	Tien Peng	Jerry White*
Craig Drumheller*	Michael Jouaneh	Amber Wood*	Jeremiah Williams*
David Fouss	Maria Karpman*	Laura Petrillo-Groh*	
Phillip Gentry	Andrew Klein	Catherine Rivest	
Jason Glazer*	Vladimir Kochkin	Michael Rosenberg*	

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2021–2022

Rick M. Heiden, <i>Chair</i>	Srinivas Katipamula	Julie Majurin	Christian R. Taber
Susanna S. Hanson, <i>Vice-Chair</i>	Gerald J. Kettler	Lawrence C. Markel	Russell C. Tharp
Charles S. Barnaby	Essam E. Khalil	Margret M. Mathison	William F. Walter
Robert B. Burkhead	Malcolm D. Knight	Gwelen Paliaga	Craig P. Wray
Thomas E. Cappellin	Jay A. Kohler	Justin M. Prosser	Jaap Hogeling, BOD ExO
Douglas D. Fick	Cesar L. Lim	David Robin	Tim J. McGinn, CO
Michael W. Gallagher	Paul A. Lindahl, Jr.	Lawrence J. Schoen	
Patricia Graef	James D. Lutz	Steven C. Sill	

Connor Barbaree, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum ci extends the economizer requirements down to 33,000 Btu/h (9.7 kW), which limits the required addition of economizers with a capacity range of 33,000 Btu/h (9.7 kW) to less than 54,000 Btu/h to individual fan-cooling units located outside the envelope of the building.

Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~strike through~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum ci to Standard 90.1-2019

Modify table 6.5.1-1 to extend the requirements for economizer down to 33,000 Btu/h (9.7 kW) (I-P and SI).

Table 6.5.1-1 Minimum Fan-Cooling Unit Size for which an Economizer Is Required

Climate Zone	Cooling Capacity for which an Economizer Is Required	Application
0A, 0B, 1A, 1B	No economizer requirement	<u>All</u>
2A, 2B, 3A, 4A, 5A, 6A, 3B, 3C, 4B, 4C, 5B, 5C, 6B, 7, 8	<u>≥33,000 Btu/h (≥9.7 kW)</u>	<u>Fan-cooling units located outside the building</u>
	≥54,000 Btu/h (≥16 kW)	<u>All other fan-cooling-unit locations</u>

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

ASHRAE · 180 Technology Parkway NW · Peachtree Corners, GA 30092 · www.ashrae.org

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.