

ERRATA SHEET FOR ANSI/ASHRAE STANDARD 55-2023
Thermal Environmental Conditions for Human Occupancy

March 21, 2024

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 55-2023. The first printing is identified on the outside back cover as “Product code: 86897 11/23”.

Page **Erratum**

10 **5.3.3 Solar Radiation Adjustment.** In Section 5.3.3.b.1 change the reference to Section 5.3.5.3 to Section 5.3.5.4 as shown below.

(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

5.3.3 Solar Radiation Adjustment. ...

[...]

b. Use a mean radiant temperature t_r that is 2.8°C (5°F) higher than average air temperature t_a if all of the following conditions are met:

1. The space has air temperature stratification that meets the requirements of Section 5.3.5.4 ~~5.3.5.3~~.

[...]