

ERRATA SHEET FOR ANSI/ASHRAE STANDARD 110-2016 (RA 2025)
Method of Testing Performance of Laboratory Hoods
June 24, 2026

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 110-2016 (RA 2025). The first printing is identified on the outside back cover as “Product code: 86678 9/25”.

(Note: Additions are shown in underline and deletions are shown in ~~striketrough~~.)

<u>Page</u>	<u>Erratum</u>
8	4.7.2 The thermal anemometer shall be capable of measuring in the range of 30 to 400 fpm (0.15 to 2.0 m/s) with an accuracy of $\pm 3\%$ of reading or ± 3 fpm (<u>0.015 m/s</u>)(0.15 m/s), whichever is greater.