

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 111-2024**  
**Measurement, Testing, Adjusting, and Balancing of Building HVAC Systems**

**September 5, 2025**

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 111-2024. The first printing is identified on the outside back cover as “Product code: 86920 11/24”.

<b><u>Page</u></b>	<b><u>Erratum</u></b>
--------------------	-----------------------

- |          |  |
|----------|--|
| <b>3</b> | <b>3. DEFINITIONS AND SYMBOLS.</b> In the definition of <i>AK factor</i> change the word “grill” to “grille” as shown below. |
|----------|--|

*(Note: Additions are shown in underline and deletions are shown in ~~striketrough~~.)*

***Ak factor:*** the effective area of an air terminal (grille ~~grill~~, diffuser, slot, air terminal box, airflow measuring station, etc.) equal to the measured airflow rate divided by the velocity reading of an instrument used in a prescribed manner.