## BACnet *Errata*ANSI/ASHRAE ADDENDUM d to ANSI/ASHRAE STANDARD 135-2004

August 9, 2006

This document lists all known *errata* to ANSI/ASHRAE Addendum d to ANSI/ASHRAE 135-2004 as of the above date. Addendum d to Standard 135-2004 is available for free on the ASHRAE website.

Erratum - Add the following to page 20 of ANSI/ASHRAE Addendum d to ANSI/ASHRAE Standard 135-2004:

[Add a new entry to **History of Revisions**, p.598]

(This History of Revisions is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard)

## HISTORY OF REVISIONS

| Protocol |          | Summary of Changes to the Standard  |
|----------|----------|---|
| Version  | Revision |   |
|          |          |   |
| 1        | 5        | Addendum <i>d</i> to ANSI/ASHRAE 135-2004 Approved by the ASHRAE Standards Committee June 24, 2006 and by the ASHRAE Board of Directors June 29, 2006; and by the American National Standards Institute June 30, 2006.  1. Add a new Structured View object type. 2. Allow acknowledgement of unseen TO-OFFNORMAL event notifications.  |
|          |          | <ol> <li>Relax the Private Transfer and Text Message BIBB requirements.</li> <li>Exclude LIFE_SAFETY and BUFFER_READY notifications from the Alarm Notifications BIBBs.</li> <li>Establish the minimum requirements for a BACnet device with an application layer.</li> <li>Remove the requirement for the DM-DOB-A BIBB from the B-OWS and B-BC device profiles.</li> <li>Relax mandated values for APDU timeouts and retries when configurable, and change default values.</li> <li>Fix EventCount handling error in MS/TP Master Node State Machine.</li> <li>Permit routers to use a local network number in Device_Address_Binding.</li> <li>Identify conditionally writable properties.</li> <li>Specify Error returns for the AcknowledgeAlarm service.</li> </ol> |