

**ERRATA SHEET FOR FIRST AND SECOND PRINTING OF
ANSI/ASHRAE STANDARD 15-2007,
Safety Standard for Refrigeration Systems**

October 1, 2009

The corrections listed in this errata sheet apply to the first and second printing of ANSI/ASHRAE Standard 15-2007. The outside back cover marking identifying the first printing is “86017 PC 4/07” and the outside back cover marking identifying the second printing is “Product Code: 86017 3/09 *Errata noted in the list dated 3/4/09 have been corrected*”. The shaded items have been added since the previously published errata sheet dated March 4, 2009 was distributed. Only the shaded items apply to the second printing.

Page Erratum

2 **Foreword.** In the second column, second to last paragraph, change “TLV-TWV” to read “TLV-TWA”.

8 **Section 7.2.2 Industrial Occupancies and Refrigerated Rooms.** Change the first sentence of Section 7.2.2 to read as follows:

(Note: Additions are shown in underline and deletions in ~~strikethrough~~.)

“Section 7.2 ~~7.3~~ does not apply in industrial occupancies and refrigerated rooms where the following seven conditions are met:”

11 **Section 8.11.5.** In the equation at the top of page 11 add spaces to separate the I-P equation and the SI equation (that immediately follows in parenthesis) as follows:

$$Q = 100 \times G^{0.5} \qquad (Q = 70 \times G^{0.5})$$

11 **Section 8.11.5c.** Delete the comma “,” that follows the equation in Section 8.11.5c and add spaces to separate the I-P equation and the SI equation (that immediately follows in parenthesis) as follow:

(Note: Deletions are shown in ~~strikethrough~~.)

$$F = G^{0.5} \qquad (F = 0.138G^{0.5}) ;$$