

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2019,
Safety Standard for Refrigeration Systems**

October 21, 2020

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15-2019. The outside back cover marking identifying the first printing is “Product code: 86015 5/19”. **Shaded** items have been added since the previously published errata sheet dated August 20, 2019 was distributed.

Page Erratum

7 **7.2.2 Industrial Occupancies and Refrigerated Rooms.** In Section 7.2.2 change “seven conditions” to “six conditions” as shown below.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

7.2.2 Industrial Occupancies and Refrigerated Rooms. Section 7.2 does not apply in industrial *occupancies* and refrigerated rooms where the following six ~~seven~~ conditions are met:
[...]

14 **Table 8-2 Level 1 Ventilation Rate for Class 2L Refrigerants.** In Column two of Table 8-1 change item a as shown below.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

a. 0.5 ft³/min per ft² ~~ft³~~ (2.54 L/s per m³) of *machinery room* area or

14 **Table 8-2 Level 1 Ventilation Rate for Class 2L Refrigerants.** In Column two of Table 8-1 change item a as shown below.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

a. 0.5 ft³/min per ft² (2.54 L/s per m² ~~m³~~) of *machinery room* area or