ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2019, Safety Standard for Refrigeration Systems

September 19, 2022

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15-2019. The outside back cover marking identifying the first printing is "Product code: 86015 5/19". Shaded items have been added since the previously published errata sheet dated October 21, 2020 was distributed.

<u>Page</u> <u>Erratum</u>

3.1 Defined Terms. In Section 3.1 change the definition of *pressure limiting device* as shown below.

(Note: Additions are shown in <u>underline</u> and deletions are shown in strikethrough.)

pressure limiting device: a pressure responsive electronic or mechanical control designed to automatically stop the operation of the pressure <u>imposing limiting</u> element at a predetermined pressure.

7 7.2.2 Industrial Occupancies and Refrigerated Rooms. In Section 7.2.2 change "seven conditions" to "six conditions" as shown below.
(Note: Additions are shown in <u>underline</u> and deletions are shown in <u>strikethrough</u>.)

7.2.2 Industrial *Occupancies* **and Refrigerated Rooms.** Section 7.2 does not apply in industrial *occupancies* and refrigerated rooms where the following <u>six seven</u> conditions are met:

[...]

Table 8-2 Level 1 Ventilation Rate for Class 2L *Refrigerants.* In Column two of Table 8-1 change item a as shown below.
(*Note: Additions are shown in <u>underline</u> and deletions are shown in <u>strikethrough</u>.)*

a. 0.5 ft³/min per $\frac{\text{ft}^2 \text{ft}^3}{2.54}$ L/s per m³) of machinery room area or

Table 8-2 Level 1 Ventilation Rate for Class 2L *Refrigerants.* In Column two of Table 8-1 change item a as shown below.
(*Note: Additions are shown in <u>underline</u> and deletions are shown in <u>strikethrough</u>.)*

a. 0.5 ft³/min per ft² (2.54 L/s per $\frac{m^2 m^3}{m^3}$) of machinery room area or