

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2022,
Safety Standard for Refrigeration Systems**

February 16, 2023

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15-2022. The outside back cover marking identifying the first printing is “Product code: 86306 9/22”.

Page Erratum

- 18** **7.6.1.2* Other Refrigeration Systems.** Revise Section 7.6.1.2 as shown below.
(Note: Additions are shown in underline and deletions are shown in ~~striketrough~~.)

7.6.1.2* Other Refrigeration Systems. For any refrigeration system not meeting the requirements of Section 7.6.1.1, the *refrigerant* charge of the largest *independent circuit* of the system (*ms*) shall not exceed the value from Equation 7-9:

$$EDVC = M_{def} \times F_{LFL} \times F_{occ} \tag{7-9}$$

where

EDVC = effective dispersal volume charge, lb (kg) ~~ft³ (m³)~~
[...]