

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15.2-2022**  
**Safety Standard for Refrigeration Systems in Residential Applications**

**January 5, 2023**

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15.2-2022. The first printing is identified on the outside back cover as “Product code: 86010 4/22”.

**Page Erratum**

**13 Table 9-1 Flammable A2L Refrigerant Charge Levels for Mitigation.** Revise Table 9-1 as shown. Changes are highlighted in yellow.

*(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)*

**Table 9-1 Flammable A2L Refrigerant Charge Levels for Mitigation**

	<i>m</i> <sub>1</sub> Charge Level		<i>m</i> <sub>2</sub> Charge Level	
	lb <sub>m</sub>	kg	lb <sub>m</sub>	kg
R-32	<u>4.14.0</u>	1.8	<del>35.1</del> <u>35.0</u>	15.9
R-452B	<u>4.14.2</u>	1.9	<del>35.6</del> <u>35.4</u>	16.1
R-454A	3.7	1.7	<del>32.3</del> <u>32.1</u>	14.6
R-454B	<u>3.94.0</u>	1.8	<del>34.0</del> <u>33.9</u>	15.4
R-454C	<u>3.94.0</u>	1.8	33.4	15.2
R-457A	2.9	1.3	<del>24.8</del> <u>24.6</u>	11.2