

ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15.2-2024
Safety Standard for Refrigeration Systems in Residential Applications

June 08, 2026

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15.2-2024. The first printing is identified on the outside back cover as “Product code: 86939 10/24”. Shaded items have been added since the previously published errata sheet dated May 13, 2025 was distributed.

<u>Page</u>	<u>Erratum</u>
2	<p>Foreword. Revise the first sentence in the Foreword as shown below. <i>(Note: Deletions are shown in strikethrough.)</i></p> <p>FOREWORD</p> <p>Standard 15.2 is the low-rise residential companion to ANSI/ASHRAE Standard 15, Safety Standard for Refrigeration Systems. ...</p>
13	<p>9.6* Releasable Refrigerant Charge (<i>mrel</i>). <i>Releasable refrigerant charge (<i>mrel</i>) shall be determined as shown in the following subsections.</i></p> <p>9.6.1 For systems without safety shut-off valves safety shut-off valves, the <i>releasable refrigerant charge (<i>mrel</i>) shall be the system refrigerant charge (<i>ms</i>).</i></p> <p>9.6.2 For systems using <i>safety shut-off valves</i>, the <i>releasable refrigerant charge (<i>mrel</i>) shall be determined according to Section 9.6.3.</i></p>