

**ERRATA SHEET FOR ANSI/ASHRAE/ASHE STANDARD 170-2021  
Ventilation of Health Care Facilities**

**March 26, 2021**

The corrections listed in this errata sheet apply to ANSI/ASHRAE/ASHE Standard 170-2021. The first printing is identified on the outside back cover as “Product code: 86536 3/21”. **Shaded** items have been added since the previously published errata sheet dated March 23, 2021 was distributed.

**Page      Erratum**

**14**      **Table 7-1 Design Parameters—Inpatient Spaces.** In Table 7-1 change the heading “NURSING UNITS AND OTH & ER PATIENT CARE AREAS” to “NURSING UNITS AND OTHER PATIENT CARE AREAS”.

**26**      **Table 8-1 Design Parameters—Specialized Outpatient Spaces.** Remove the FGI reference for Specialty IC exam room in Table 8-1 as shown in the attached. Changes highlighted in yellow.  
*(Note: Deletions are shown in ~~strikethrough~~.)*

**29**      **Table 8-2 Design Parameters—General Outpatient Spaces (q).** Remove the FGI reference for Specialty IC exam room in Table 8-2 as shown in the attached. Changes highlighted in yellow.  
*(Note: Deletions are shown in ~~strikethrough~~.)*

**Table 8-1 Design Parameters—Specialized Outpatient Spaces**

Function of Space (f)	Pressure Relationship to Adjacent Areas (n)	Minimum Outdoor ach	Minimum Total ach	All Room Air Exhausted Directly to Outdoors (j)	Air Recirculated by Means of Room Units (a)	Minimum Filter Efficiencies (c)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
DIAGNOSTIC AND TREATMENT <i>(Continued)</i>								
Specialty IC exam room <del>(FGI 2.1.3.2.1.3)</del> (y)	Negative	2	6	Yes	NR	MERV-8	Max 60	70–75/21–24

**Table 8-2 Design Parameters—General Outpatient Spaces (q)**

Function of Space (f)	Pressure Relationship to Adjacent Areas (d)	ach Design Option		All Room Air Exhausted Directly to Outdoors (j)	Air Recirculated by Means of Room Units (a)	Min. Filter Efficiencies (c)	Design RH% (i)	Design Temperature °F/°C (k)	$R_p$ - $R_a$ Air-Class Design Option			
		Min. Outdoor ach (q)	Min. Total ach (q)						Air Class (q)	$R_p$ cfm/(L·s)/ person and Min. Space Population (q)	$R_a$ cfm/ft/(L·s/m) (q)	
GENERAL DIAGNOSTIC AND TREATMENT												
Specialty IC exam room <del>(FGI 2.5.3.2.3)</del> (b)	Negative	2	3	Yes	NR	MERV-8	Max 60	70–75/21–24	3	10 (5) / 3	0.18 / (0.9)	