

**ERRATA SHEET FOR ANSI/ASHRAE/ASHE Addendum a to
ANSI/ASHRAE/ASHE STANDARD 170-2017
Ventilation of Health Care Facilities**

September 16, 2020

The corrections listed in this errata sheet apply to ANSI/ASHRAE/ASHE Addendum a to ANSI/ASHRAE/ASHE Standard 170-2017. The first printing of Addendum a is identified on the outside back cover as “9/20”.

<u>Page</u>	<u>Erratum</u>
--------------------	-----------------------

- | | |
|----------|--|
| 4 | Table 7.1 Design Parameters – Inpatient Spaces (<i>Continued</i>) . For Behavioral and Mental Health Facilities change the Minimum Filter Efficiency for the two spaces listed in Table 7.1 from MERV-14 to MERV-8 as shown in the attached. These spaces were added by Addendum m to 170-2017.
<i>(Note: Additions are shown in <u>underline</u> and deletions are shown in striketrough.)</i> |
|----------|--|

Table 7.1 Design Parameters—Inpatient Spaces (Continued)

Function of Space (f)	Pressure Relationship to Adjacent Areas (n)	Minimum Outdoor ach	Minimum Total ach	All Room Air Exhausted Directly to Outdoors (j)	Air Recirculated by Means of Room Units (a)	Unoccupied Turndown	Minimum Filter Efficiencies (cc)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
BEHAVIORAL AND MENTAL HEALTH FACILITIES (k)									
Patient bedroom, resident room (2.5–2.2.2)	NR	2	2	NR	NR	Yes	MERV-8 MERV-14	NR	NR
Seclusion room (2.5–2.24.3)	NR	4	2	NR	NR	Yes	MERV-8 MERV-14	NR	NR