

**ERRATA SHEET FOR ANSI/ASHRAE/ASHE Addendum m to
ANSI/ASHRAE/ASHE STANDARD 170-2017
Ventilation of Health Care Facilities**

November 15, 2021

The corrections listed in this errata sheet apply to ANSI/ASHRAE/ASHE Addendum m to ANSI/ASHRAE/ASHE Standard 170-2017. The first printing of Addendum m is identified on the outside back cover as “7/20”.

<u>Page</u>	<u>Erratum</u>
--------------------	-----------------------

- | | |
|----------|--|
| 3 | Table 8.1 Design Parameters – Outpatient Spaces (<i>Continued</i>). For Sterilizer equipment room change the Air Recirculated by Means of Room Units listed in Table 8.1 from “No” to “NR” as shown in the attached. Changes highlighted in yellow. <i>(Note: Additions are shown in <u>underline</u> and deletions are shown in strikethrough.)</i> |
|----------|--|

Revise Table 8.1 as shown below. The remainder of Table 8.1 is unchanged.

Function of Space (f)	Pressure Relationship to Adjacent Areas (n)	Minimum Outdoor ach	Minimum Total ach	All Room Air Exhausted Directly to Outdoors (j)	Air Recirculated by Means of Room Units (a)	Minimum Filter Efficiencies (c)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
STERILE PROCESSING ^(aa)								
Sterilizer equipment room (FGI 2.1-4.3.2.2)	Negative	NR	10	Yes	NR No	MERV-8	NR	NR